

**MERAMEC ENERGY CENTER**

Pond MCPE (489)  
Annual Inspection Check Sheet

Date	July 13, 2018
Inspector	Gene Campbell Jim Healey
Pool Level	NA – Pond is Closed
River Level	392.9 feet
Temperature	85°F
Weather	Sunny

**Date of Previous Annual Inspection:** July 17, 2017

**Date of Previous Periodic Inspection:** Not Applicable

**Description of Emergency (EC) or Immediate Maintenance (IM) conditions observed since the last annual inspection:**

None

**Describe any action taken to restore or improve safety and integrity of impounding structure:**

None

**Describe any modifications to the geometry of the impounding structure since the previous annual inspection:**

None

**Describe any modifications to the operation of the impounding structure since the previous annual inspection:**

The Pond was closed on April 6, 2018. The pond is no longer receiving any processed water or CCR material.

**List the approximate remaining storage capacity of the impounding structure:**

N/A. The Pond was closed on April 6, 2018. There is no more storage capacity of the impounding structure.

**List the approximate maximum, minimum and present depth and elevation of the impounded water since the previous annual inspection:**

N/A. The Pond was closed on April 6, 2018. There is no impounded water. The pond will no longer receive any processed water.

**List the approximate maximum, minimum and present depth and elevation of the impounded CCR since the previous annual inspection:**

The Pond was closed on April 6, 2018. Maximum elevation is 434 ft. and maximum depth is 32 ft. Minimum elevation is 398 and minimum depth is 0 ft. Present average elevation is 414 ft. and Present average depth is 12 ft.

**Approximate volume of impounded water and CCR at the time of the inspection:**

The Pond was closed on April 6, 2018. There is no impounded water. The approximate volume of CCR in the closed pond is 685,000 CY.

**Describe any changes to the downstream watershed:**

None