

CORRECTIVE MEASURES ASSESSMENT
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

by
Haley & Aldrich, Inc.
Cleveland, Ohio

for
Ameren Missouri
St. Louis, Missouri

May 2019



Overview

This Corrective Measures Assessment (CMA) was prepared by Haley & Aldrich, Inc. (Haley & Aldrich) for Union Electric Company d/b/a Ameren Missouri (Ameren) for the Coal Combustion Residual (CCR) surface impoundment (LCPA) located at the Ameren Labadie Energy Center (LEC). The LEC is a coal-fired power plant located along the Missouri River in Franklin County, Missouri. The CMA was completed in accordance with requirements stated in the U.S. Environmental Protection Agency's (USEPA) rule entitled *Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities*. 80 Fed. Reg. 21302 (Apr. 17, 2015) (promulgating 40 CFR §257.61); 83 Fed. Reg. 36435 (July 30, 2018) (amending 40 CFR §257.61) (CCR Rule).

Ameren implemented groundwater monitoring under the CCR Rule through a phased approach to allow for a graduated response and evaluation of steps to address groundwater quality. Assessment monitoring completed in 2018 evaluated the presence and concentration of constituents in groundwater specified in the CCR Rule (i.e. Appendix IV). Of the 23 CCR parameters evaluated, only one constituent of concern (COC), molybdenum, exceeded the Groundwater Protection Standards (GWPS) established for the LCPA in a very limited number of wells and to a limited extent. As described in **Section 3.3.1**, 96% of Appendix IV parameters tested comply with CCR Rule requirements.

Ameren completed a detailed environmental evaluation of the LCPA and surrounding area, including voluntary, supplemental surface water sampling and bedrock groundwater sampling. In 2018, a risk evaluation was undertaken to identify whether current groundwater conditions pose an unacceptable risk to human health and the environment, and whether corrective measures mitigate such an unacceptable risk, if present. The risk evaluations concluded that there are **no adverse effects on human health or the environment currently or under reasonably anticipated future uses** from either surface water or groundwater due to CCR management practices at LEC.

In performing this CMA, Haley & Aldrich considered the following: presence and distribution of molybdenum, LCPA configuration, hydrogeologic setting, and the results of the detailed risk evaluation. Within the LCPA, CCR is managed in an impoundment that extends to a depth of approximately 100 feet (ft) below ground surface (bgs). Groundwater within the Missouri River valley ranges in thickness from 0 ft thick at the aquifer pinch-out along the bedrock bluff to the south of the LCPA near the railroad, to up to greater than 120 ft thick where the sedimentary bedrock surface has been eroded by the Missouri River. Although flow direction is influenced by elevation changes of surface water in the Missouri River, groundwater generally/predominantly flows from the south to north beneath the LCPA, towards the Missouri River.

To provide a comprehensive CMA, this effort included surface impoundment closures and groundwater remediation alternatives, including:

- **Alternative 1:** Closure in place (CIP) with low permeability capping and monitored natural attenuation (MNA);
- **Alternative 2:** CIP with in-situ stabilization (ISS), low permeability capping and MNA;
- **Alternative 3:** CIP with low permeability capping and in-situ groundwater treatment;
- **Alternative 4:** CIP with low permeability capping, hydraulic containment (HC) of groundwater, and ex-situ groundwater treatment; and

- Alternative 5: Closure by removal (CBR) with MNA.

These five alternatives were evaluated based on the threshold criteria provided in the CCR Rule and then compared to three of the four balancing criteria stated in the CCR Rule. The four balancing criteria consider:

1. The long- and short-term effectiveness and protectiveness of the potential remedy(s), along with the degree of certainty that the remedy will prove successful;
2. The effectiveness of the remedy in controlling the source to reduce further releases;
3. The ease or difficulty of implementing a potential remedy; and
4. The degree to which community concerns are addressed by a potential remedy.

Balancing criteria four, which considers community concerns, will be evaluated following a public information session scheduled for May 2019.

The following observations are made regarding closure scenarios and groundwater remedial alternatives for the LCPA and are described more fully in this report:

- **Cap Integrity and Hydrogeologic Conditions:** For all CIP alternatives, Ameren intends to install a geomembrane and soil cover system that exceeds, by two orders-of-magnitude, the performance criteria set forth in the CCR Rule and is referred to in this CMA as a "low permeability cap." Vertical infiltration via precipitation is virtually eliminated following installation of the geomembrane cover system. Modelling predicts that post-closure, 99% of groundwater travels horizontally around the unit via a preferential pathway in the surrounding soils.
- **No Risk:** Risk assessment evaluations confirm that the LCPA, even prior to closure, presents **no unacceptable risk** to human health or the environment. In fact, concentration levels of molybdenum would need to be **more than 40,000 times higher**, than currently measured levels before an adverse impact in the Missouri River could occur. Therefore, since no adverse risk currently exists, implementation of any of the remedies considered will not result in a meaningful reduction in risk.
- **Groundwater Compliance:** Molybdenum concentrations are predicted to reduce below GWPS within an estimated 22 years after closure due to geochemical conditions of the groundwater. Such timeframe reduces to approximately 16 years following in-situ treatment according to predictive modeling performed by Gredell Engineering Resourcing, Inc. (Gredell). See **Figure 4-2**. Ameren has retained XDD Environmental (XDD) to evaluate and develop groundwater treatment methods to address molybdenum and potentially accelerate this timeframe.
- **Excavation Timeframe:** As described in an Extraction & Transportation Study prepared by the Lochmueller Group (Lochmueller), removal of large volumes of stored CCR creates extensive logistical challenges – including excavation, transportation, and disposal, and could take decades to complete during which time the impoundment would remain open and the would be subject to ongoing infiltration from precipitation.

- **Groundwater Treatment:** As noted, laboratory bench-scale testing and in-situ treatment evaluations are being performed by XDD. XDD expects to complete these evaluations this summer.
- **Residential Supply Wells:** Bedrock groundwater sampling performed to respond to expressed concerns about drinking water quality **confirms that the LEC is not impacting the groundwater used for drinking water.** Residential supply wells draw groundwater from the bedrock aquifer at depths of 500 to 700 ft bgs. The investigations demonstrate that the bedrock groundwater in the bluff area is upgradient of the LEC and all results meet drinking water standards. Even under extreme flood conditions, modeling confirms that such wells would not be impacted by CCR operations at the LEC.

In accordance with §257.98, Ameren will implement a groundwater monitoring program to document the effectiveness of the selected remedial alternative. Corrective measures are considered complete when monitoring reflects groundwater downgradient of the LCPA does not exceed the Appendix IV GWPS for three consecutive years. USEPA is in the process of modifying certain CCR Rule requirements and, depending upon the nature of such changes, assessments made herein could be modified or supplemented to reflect such future regulatory revisions. See *Federal Register (March 15, 2018; 83 FR 11584)*.

Table of Contents

	Page
Overview	i
List of Tables	vi
List of Figures	vi
List of Acronyms and Abbreviations	vii
1. Introduction	1
1.1 FACILITY DESCRIPTION/BACKGROUND	1
1.2 SITE CHARACTERIZATION WORK SUMMARY	1
1.3 GROUNDWATER MONITORING	2
1.4 CORRECTIVE MEASURES ASSESSMENT PROCESS	3
1.5 RISK REDUCTION AND REMEDY	3
2. Groundwater Conceptual Site Model	5
2.1 SITE SETTING	5
2.2 SITE TOPOGRAPHY	5
2.3 GEOLOGY AND HYDROGEOLOGY	5
2.4 GROUNDWATER PROTECTION STANDARDS	8
2.5 NATURE AND EXTENT OF GROUNDWATER IMPACTS	8
2.6 SURFACE WATER SAMPLING	8
2.7 BEDROCK WELL SAMPLING	9
3. Risk Assessment and Exposure Evaluation	10
3.1 APPROACH	10
3.2 CONCEPTUAL SITE MODEL	11
3.3 RESULTS	11
3.3.1 Alluvial Aquifer	11
3.3.2 Surface Water	12
3.3.3 National Pollutant Discharge Elimination System Outfall	12
3.3.4 Off-Site Bedrock Groundwater	12
3.4 CONCLUSION	12
3.4.1 Trace Elements in Coal Ash	13
3.4.2 Molybdenum	13
3.5 EVALUATION OF RISK IN THE CORRECTIVE MEASURES ASSESSMENT	14
4. Corrective Measures Alternatives	16
4.1 CORRECTIVE MEASURES ASSESSMENT GOALS	16

Table of Contents

	Page	
4.2	GROUNDWATER MODELING	16
4.3	GROUNDWATER TREATMENT EVALUATION	16
4.4	CORRECTIVE MEASURES ALTERNATIVES	17
4.4.1	Alternative 1 – Closure in Place with Capping and Monitored Natural Attenuation	17
4.4.2	Alternative 2 – CIP with In-Situ Stabilization, Capping and Monitored Natural Attenuation	18
4.4.3	Alternative 3 – CIP with Capping and In-Situ Groundwater Treatment	19
4.4.4	Alternative 4 – CIP with Capping and Hydraulic Containment Through Groundwater Pumping and Ex-Situ Treatment	19
4.4.5	Alternative 5 – Closure by Removal with Monitored Natural Attenuation	19
5.	Comparison of Corrective Measures Alternatives	22
5.1	EVALUATION CRITERIA	22
5.2	COMPARISON OF ALTERNATIVES	22
5.2.1	The Long- and Short-Term Effectiveness and Protectiveness of the Potential Remedy, along with the Degree of Certainty That the Remedy Will Prove Successful	22
5.2.2	The Effectiveness of the Remedy in Controlling the Source to Reduce Further Releases	27
5.2.3	The Ease or Difficulty of Implementing a Potential Remedy	28
6.	Summary	32
	References	33
	Tables	
	Figures	
	Appendix A – Surface Water Screening Tables	
	Appendix B – What You Need to Know About Molybdenum	
	Appendix C – Extraction and Transportation Study	

List of Tables

Table No.	Title
I	Groundwater Analytical Results – Appendix IV Constituents

List of Figures

Figure No.	Title
1-1	Site Location Map
1-2	Site Features
2-1	Monitoring Well Locations
2-2	Surface Water Sampling Locations
2-3	Bedrock Monitoring Well Locations
4-1	Remedial Alternatives Roadmap
4-2	Modeled Molybdenum Concentrations After Capping and Closing the LCPA

List of Acronyms and Abbreviations

Ameren	Ameren Missouri
AMSL	Above Mean Sea Level
bgs	Below Ground Surface
CBR	Closure by Removal
CCR	Coal Combustion Residuals
CIP	Closure In-Place
CMA	Corrective Measures Assessment
cm/sec	Centimeters per Second
COC	Constituents of Concern
CSM	Conceptual Site Model
DSI	Detailed Site Investigation
ft	Feet
Golder	Golder Associates Inc.
GMP	Groundwater Monitoring Plan
Gredell	Gredell Engineering Resources, Inc.
GWPS	Groundwater Protection Standards
Haley & Aldrich	Haley & Aldrich, Inc.
HC	Hydraulic Containment
ISS	In-Situ Solidification
LCPA	Bottom Ash Surface Impoundment
LCPB	Fly Ash Surface Impoundment
LCL1	Utility Waste Landfill Cell 1
LEC	Labadie Energy Center
Lochmueller	Lochmueller Group
MM CY	Million Cubic Yards
mg/kg	Milligrams per kilogram
mg/l	Milligrams per liter
MNA	Monitored Natural Attenuation
N&E	Nature and Extent
NAS	U.S. National Academy of Sciences
O&M	Operations and Maintenance
ORP	Oxidation Reduction Potential
ppm	Parts per Million
PRB	Permeable Reactive Barrier
RDA	Recommended Daily Allowance
RO	Reverse Osmosis
SSI	Statistically Significant Increase
SSL	Statistically Significant Level
ug/L	Micrograms per liter
UL	Tolerable Upper Limit
USEPA	U.S. Environmental Protection Agency
USGS	U.S. Geological Survey
XDD	XDD Environmental

1. Introduction

Haley & Aldrich, Inc. (Haley & Aldrich) has prepared this Corrective Measures Assessment (CMA) for the Coal Combustion Residual (CCR) surface impoundment (LCPA) located at the Ameren Missouri (Ameren) Labadie Energy Center (LEC) located approximately 35 miles west of downtown St. Louis in Franklin County, Missouri. Ameren has conducted detailed geologic and hydrogeologic investigations under Missouri's utility and solid waste landfill requirements as well as the USEPA rule entitled *Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities*. 80 Fed. Reg. 21302 (Apr. 17, 2015) (promulgating 40 CFR §257.61); 83 Fed. Reg. 36435 (July 30, 2018) (amending 40 CFR §257.61) (CCR Rule). These investigations were, in part, related to determination of requirements related to the potential for both LCPA closure and groundwater corrective action.

This CMA includes a summary of the results of groundwater and site investigations at the LEC. Groundwater impacted by the LCPA exceeds statistically-derived GWPS for only molybdenum at only five monitoring well locations. This report evaluates potential corrective measures to address the limited exceedances of the GWPS.

1.1 FACILITY DESCRIPTION/BACKGROUND

The LEC is located in rural Franklin County and surrounded by agricultural fields. The facility is bounded to the north by the Missouri River, to the west by Labadie Creek, and to the south by a railroad line and bedrock bluffs (**Figure 1-1**). The LCPA is an unlined impoundment approximately 165 acres in size and is the focus of this CMA. Directly northeast of the LCPA is the lined fly ash surface impoundment (LCPB). East of LCPB is the utility waste landfill (UWL) used for managing dry CCR. Site features are illustrated on **Figure 1-2**.



Labadie Energy Center

Both fly ash and bottom ash have been historically managed in this LCPA.

Construction drawings indicate that the base depth of CCR in the LCPA extends down approximately 100 ft bgs in the deepest portions of the unit. Over the past 17 years, Ameren has been able to beneficially use 64% of the bottom ash material with the remaining managed in the LCPA. The estimated volume of CCR currently within the limits of the LCPA is approximately 17.3 million cubic yards (MM CY). Ameren is constructing wastewater treatment facilities and will terminate usage of the impoundment system in September 2019 and commence closure of both the lined (LCPB) and unlined (LCBA) impoundments shortly thereafter.

1.2 SITE CHARACTERIZATION WORK SUMMARY

Extensive subsurface investigations have occurred pursuant to Missouri's utility and solid waste landfill requirements as well as the CCR Rule. In addition, in 2012 Ameren voluntarily installed an off-site well network to confirm groundwater flow direction and bedrock water quality in response to community

concerns. Ameren also voluntarily conducted surface water sampling. In 2011, and as part of state permitting requirements for UWLs, Gredell and Reitz & Jens, Inc., prepared a Detailed Site Investigation (DSI) Report to characterize geology and hydrogeology conditions. Haley & Aldrich used, in part, the DSI to support the development of a hydrogeologic Conceptual Site Model (CSM). The DSI investigation included:

- Soil borings and sampling;
- Geotechnical testing;
- Rock coring;
- Well and piezometer installation;
- Slug testing; and
- Groundwater sampling.

The CSM has been further enhanced with ongoing CCR groundwater monitoring and supplemental subsurface investigation activities performed by Golder Associates, Inc. (Golder). Findings from these extensive and updated series of geologic, geotechnical, and hydrogeologic investigations including voluntary surface water sampling conducted, have produced a robust CSM that supports the CMA activities discussed in this report.

1.3 GROUNDWATER MONITORING

Groundwater monitoring under the CCR Rule occurs through a phased approach to allow for a graduated response (i.e., baseline, detection, and assessment monitoring as applicable) and evaluation of steps to address groundwater quality associated with a CCR unit. Golder prepared a Groundwater Monitoring Plan (GMP) as required by the CCR Rule. The GMP presents the design of the groundwater monitoring system, groundwater sampling and analysis procedures, and groundwater statistical analysis methods.

Monitoring wells were installed in November 2015 and February 2016 and includes two background wells (BMW-1D and BMW-2D) that are located off-site (west of the CCR unit) and nine downgradient monitoring wells (UMW-1 through UMW-9) located around the perimeter of the LCPA. In general, the monitoring wells are screened in the alluvial aquifer zone near the base elevation of the LCPA.



Groundwater Monitoring Well Locations

Detection monitoring sampling events occurred in 2017 and 2018. The results of the sampling events were then compared to background, or natural groundwater values, using statistical methods to determine if Appendix III constituents at the base of the ash basin are present at concentrations above background, called statistically significant increases (SSI). Detection of Appendix III analytes triggered a verification sampling event in January 2018 and verified SSIs. The results of this analysis indicated SSIs necessitating the establishment of an Assessment Monitoring Program and respective notification of the same.

CCR Rule Monitoring Constituents			
Appendix III	Boron	Appendix IV	Antimony
	Calcium		Arsenic
	Chloride		Barium
	Fluoride		Beryllium
	Sulfate		Cadmium
	pH		Chromium
	Tot. Dissolved Solids		Cobalt
	Fluoride		
	Lead		
	Lithium		
	Mercury		
	Molybdenum		
	Selenium		
	Thallium		
	Radium 226 & 228		

During the Assessment Monitoring phase, CCR groundwater monitoring well samples were collected during April, May and November 2018 and subsequently analyzed for Appendix IV constituents. Appendix IV analytical results for the baseline and Assessment Monitoring events are summarized in **Table I**.

1.4 CORRECTIVE MEASURES ASSESSMENT PROCESS

The CMA process involves development of groundwater remediation technologies that will result in the following threshold criteria: protection of human health and the environment, attainment of GWPS, source control, COC removal and compliance with standards for waste management. Once these technologies are demonstrated to meet these criteria, they are then compared to one another with respect to long- and short-term effectiveness, source control, and implementability. Input from the community on such proposed measures will occur as part of a public meeting scheduled for May 2019.

1.5 RISK REDUCTION AND REMEDY

The CCR Rule at §257.97 (Selection of Remedy) at (b)(1) requires that remedies must be protective of human health and the environment. Further, at (c) the CCR Rule requires that in selecting a remedy, the owner or operator of the CCR unit shall consider specific evaluation factors, including the risk reduction achieved by each of the proposed corrective measures. Each of the evaluation factors listed here and discussed in **Section 4** are those that consider risk to human health or the environment.

(1)(i) Magnitude of reduction of existing risks;

(1)(ii) Magnitude of residual risks in terms of likelihood of further releases due to CCR remaining following implementation of a remedy;

(1)(iv) Short-term risks that might be posed to the community or the environment during implementation of such a remedy, including potential threats to human health and the environment associated with excavation, transportation, and re-disposal of contaminant;

(1)(vi) Potential for exposure of humans and environmental receptors to remaining wastes, considering the potential threat to human health and the environment associated with excavation, transportation, re-disposal, or containment;

(4) Potential risks to human health and the environment from exposure to contamination prior to completion of the remedy¹;

(5)(i) Current and future uses of the aquifer;

(5)(ii) Proximity and withdrawal rate of users; and

(5)(iv) The potential damage to wildlife, crops, vegetation, and physical structures caused by exposure to CCR constituents.

¹ Factors 4 and 5 are not part of the CMA evaluation process as described in §257.97(d)(4), §257.97(d)(5)(i)(ii)(iv); rather they are factors the owner or operator must consider as part of the schedule for remedy implementation.

2. Groundwater Conceptual Site Model


To evaluate the magnitude of risk reduction, the degree of existing risk must first be identified. Prior risk evaluations and data collected are summarized below.

2.1 SITE SETTING

The LEC is located in Franklin County adjacent to the Missouri River within a wide area known as the Missouri River Bottoms. The facility is surrounded by agricultural fields. Residential homes are located in the bluffs to the south and there are no residential structures within the bottoms area. The LEC is connected to a public water supply provided by the town of Labadie, Missouri. Residences within the bluffs area draw water from private supply wells drilled deep into the bedrock aquifer.

2.2 SITE TOPOGRAPHY

Ground surface elevation near the LEC ranges between roughly 468 ft to 495 ft above mean sea level (AMSL). A lined ash impoundment and a UWL are located northeast of the LCPA and all such CCR Units are protected by berms. The plant property was elevated during construction of the LEC and agricultural fields located to the south are at a lower elevation ranging from approximately 465 to 475 ft AMSL. South of bottoms, bedrock bluffs rise to an elevation of over 550 ft AMSL. The western side of the LCPA is bounded by Labadie Creek, which flows north to the Missouri River.




Topographic Map

2.3 GEOLOGY AND HYDROGEOLOGY

The geology immediately surrounding the LEC is composed of two distinctly different geological terrains; (1) floodplain deposits of the Missouri River Valley and (2) older sedimentary bedrock formations. The river valley in this region is an approximately 2 to 3-mile-wide area of floodplain with alluvial deposits (alluvium) that are the result of the water flow and deposition from the Missouri River². The alluvial aquifer varies in thickness from 0 ft thick at the aquifer pinch-out along the bedrock bluff to the South near the railroad, to up to greater than 120 ft thick where the sedimentary bedrock surface has been eroded by the Missouri River.


² 40 CFR Part 257, Groundwater Monitoring Plan LCPA, Labadie Energy Center, Franklin County, Missouri (Golder 2017)

The cross-section provides a depiction of the LCPA in relation to the bedrock and alluvial aquifers along with alluvial deposits consisting primarily of alluvial sands with some silt, clay, and gravel. This alluvium overlies Ordovician-aged sedimentary bedrock formations comprised of relatively flat-lying Ordovician-aged limestones, sandstones and dolomites.



Generalized Cross-Section
 Image from Figure 3, Groundwater Monitoring Plan, LCPA LEC (Golder 2017)

Groundwater flow direction within the alluvium flows from the south (bluffs area) to the north (Missouri River) under normal river conditions. However, during periods of high river levels, groundwater can temporarily reverse flow until such time as the river surface elevation decreases. During these times of high river stage and temporary flow direction changes, horizontal groundwater gradients generally decrease, and little net movement of groundwater occurs. Modelling performed by Golder confirms that even under the most extreme flood event (i.e. a flood of record lasting 55 days), such temporary reversal does not impact the bedrock aquifer from which residents draw water.



Groundwater Flow Map-November 7, 2018
 Image from Figure C3, 2018 Annual Groundwater Monitoring and Corrective Action Report (Golder 2019)

Groundwater flow direction and gradient were estimated for the downgradient CCR monitoring wells using the USEPA’s On-line Tool for Site Assessment Calculation for Hydraulic Gradient (Magnitude and Direction) (USEPA, 2016). Results from this assessment indicate that

the overall net groundwater flow at the LCPA is from the bluffs toward the river^{3 4}. Horizontal gradients calculated by the program ranged from 0.0003 to 0.0006 ft/ft with an estimated net annual groundwater velocity of approximately 19 ft per year under current conditions⁵.

Vertical hydraulic gradients from areas away from the LCPA are relatively variable and fluctuate between upward and downward with no consistent vertical gradient present between shallow and deeper zones of the alluvial aquifer. Areas adjacent to the LCPA demonstrate a downward gradient. While results vary, overall gradients are typically downward ranging up to 0.4 ft difference between the groundwater levels. Vertical gradients within the LCPA and the underlying alluvial groundwater zone changes seasonally based on river levels and fluctuating alluvial aquifer groundwater levels.

Groundwater flow modeling completed by Gredell evaluated the flux of groundwater passing through the CCR, following closure and dewatering of the LCPA. As shown in the figure below, the model results indicated that over 99% of groundwater moving laterally through the alluvial aquifer preferentially flows under (and around) the LCPA, due to the notably lower horizontal hydraulic conductivity of the CCR.

Groundwater Preferentially Flows Under/Around the LCPA




Image provided by Golder 2019

³ Labadie Energy Center Groundwater Modeling Technical Memorandum (Golder 2015)

⁴ 2016 Ground and Surface Water Assessment Labadie Energy Center (Ferrara, R.A., 2016)

⁵ 2018 Annual Groundwater Monitoring and Corrective Action Report, LCPA Surface Impoundment, LEC, Franklin County, Missouri (Golder 2019)

2.4 GROUNDWATER PROTECTION STANDARDS

Golder completed a statistical evaluation of groundwater samples using the methods and procedures outlined in the Groundwater Monitoring Plan's *Statistical Analysis Plan* (Golder 2017) to develop site-specific GWPS for each Appendix IV constituents.

Groundwater results were compared to the site-specific GWPS. Statistically significant levels (SSL) above the GWPS are limited to five monitoring wells (UMW-3D, UMW-4D, UMW-5D, UMW-6D and UMW-7D) and only for one parameter, molybdenum.

2.5 NATURE AND EXTENT OF GROUNDWATER IMPACTS

Ameren initiated a nature and extent (N&E) investigation as required by the CCR Rule in 2018 and installed additional monitoring wells and piezometers (N&E wells). The N&E wells are screened in three different, generalized zones of the alluvial aquifer: shallow zone, middle/intermediate zone, and deep zone. Well screen lengths range from 5 to 10 ft long and total depths range from approximately 24 to 98 ft bgs.

Analytical results from the N&E wells indicate that molybdenum concentrations are limited in their extent. In the shallow alluvial aquifer zone, the results from monitoring wells at the property boundary are below the GWPS. In the intermediate and deep alluvial aquifer zone, molybdenum concentrations are below the GWPS at nested wells located east of the LCPA (TP-1, TP-4 and TP-5). Results from wells to the north of the LCPA are above the GWPS (TP-2, TP-3 and AM-1D). Concentrations of molybdenum are highest in the intermediate and deep alluvial aquifer zone samples. Monitoring Well locations are shown on **Figure 2-1**.

The extent of molybdenum above the GWPS is limited to the alluvial aquifer and does not extend into the bedrock beneath and adjacent to the LCPA or the offsite bedrock well network. Results from the N&E wells were used to develop corrective measures alternatives.

2.6 SURFACE WATER SAMPLING

The limited elevated levels of molybdenum have not impacted surface waters. Prior to the CCR Rule, Ameren voluntarily collected samples of surface water from the Missouri River and Labadie Creek to evaluate whether ash management operations at the LEC have impacted these surface water bodies. Surface water sampling locations for these events are shown on **Figure 2-2**.

Golder collected surface water samples from 12 locations in the Missouri River and six locations in Labadie Creek. At each sample location, shallow samples were collected near the surface of the river. Where the depth of water was greater than four feet, a second sample was collected mid-depth in the

Parameter	Site GWPS	Units
Antimony	6	µg/L
Arsenic	42.6	µg/L
Barium	2000	µg/L
Beryllium	4	µg/L
Cadmium	5	µg/L
Chromium	100	µg/L
Cobalt	6	µg/L
Fluoride	4	mg/l
Lead	15	µg/L
Lithium	54.85	µg/L
Mercury	2	µg/L
Molybdenum	100	µg/L
Radium 226+228	5	pCi/L
Selenium	50	µg/L
Thallium	2	µg/L

Groundwater Protection Standards
 ug/L – micrograms per liter
 mg/l – milligrams per liter
 pCi/L – picoCuries per liter

river (referred to here as a deep sample). A total of 55 samples were collected from the Missouri River and a total of 12 samples were collected in Labadie Creek.

Samples were analyzed for the same Appendix III and Appendix IV constituents listed in **Section 1.3**, with the exception of radium (all CCR monitoring well data are below the GWPS for radium). Sample results were also compared to human health and ecological risk-based screening levels. The screening levels and comparison of the surface water results to the screening levels are provided in **Appendix A**.

In summary, the results of this investigation demonstrate that the Missouri River and Labadie Creek sampling **do not** show evidence of impact of CCR constituents including molybdenum⁶.

2.7 BEDROCK WELL SAMPLING

Ameren installed an off-site monitoring network to evaluate water quality within the bedrock aquifer and to confirm groundwater flow direction. In 2012 and 2014, Golder installed seven monitoring wells with screened intervals in bedrock at similar depths to residential water wells closest to the LEC property boundary (south of the LEC, in the bluff area). The bedrock groundwater monitoring well locations are shown on **Figure 2-3**. Bedrock groundwater sampling results **fully comply with federal and state drinking water standards**. See **Appendix A**.

⁶ In some river samples, the concentrations of arsenic or lithium exceeded screening levels, however, the results are statistically **no different** in upstream and downstream samples indicating that the LCPA is not the source of the constituents detected in the rivers. At the LCPA, arsenic and lithium groundwater results comply with the CCR Rule's GWPS.

3. Risk Assessment and Exposure Evaluation

As described in this report, Ameren has conducted detailed environmental evaluations of the LEC and its environs. These investigations have been detailed in two risk evaluation reports available to the public on the Ameren website:

- January 2014: Groundwater and Surface Water Data Demonstrate No Adverse Human Health Impact from Coal Ash Management at the Ameren Labadie Energy Center. Available at: <https://www.ameren.com/-/media/corporate-site/files/environment/reports/amerenlabadiereport.ashx?la=en&hash=3B8226534EAF26E0A904A1D2C8453E5D9DAC1424>
- February 2018: Human Health and Ecological Assessment of the Labadie Energy Center. Available at: <https://www.ameren.com/-/media/corporate-site/files/environment/ccr-rule/2017/groundwater-monitoring/labadie-haley-aldrich-report.ashx?la=en&hash=76A0B8C34676EA9D3A7C8F61284917F50E02ED46>

The purpose of the risk evaluations is to identify whether current groundwater conditions pose a risk to human health and the environment and, if so, whether the corrective measures identified in this report mitigate such risk.

3.1 APPROACH

The risk evaluation provided in the 2018 risk assessment report evaluated the environmental setting of the LEC, which has been in operation for 48 years, including its location and ash management operations at the facility. Golder provided information on groundwater location and direction, the rate(s) of groundwater flow, and where waterbodies may intercept groundwater flow.

A conceptual model was then developed based on this physical setting information and used to identify whether human populations could contact groundwater and/or surface water in the area of the facility. This information was also used to identify locations where ecological populations could come into contact with surface water. Based on this conceptual model approach, Ameren’s environmental consultants and risk assessors identified sampling locations to evaluate potential impact to the environment. Sampling results were then evaluated, as appropriate, on both a human health and ecological risk basis.

Human health risk assessment is a process used to estimate the chance that contact with constituents in the environment may result in harm to people. Generally, there are four components to the process (USEPA, 1989): (1) Hazard Identification, (2) Toxicity Assessment, (3) Exposure Assessment, and (4) Risk Characterization.

The USEPA develops “screening levels” of constituent concentrations in groundwater (and other media) that are considered to be protective of specific human exposures. These screening levels are referred to as “Regional Screening Levels” and are published by USEPA and updated twice yearly (USEPA, 2018a). In developing the screening levels, USEPA uses a specific target risk level (component 4) combined with an assumed exposure scenario (component 3) and toxicity information from USEPA (component 2) to derive an estimate of a concentration of a constituent in an environmental medium, for example groundwater, (component 1) that is protective of a person in that exposure scenario (for example,

drinking water). Similarly, ecological screening levels for surface water are developed by Federal and State agencies to be protective of the wide range of potential aquatic ecological resources, or receptors.

Risk-based screening levels are designed to provide a conservative estimate of the concentration to which a receptor (human or ecological) can be exposed without experiencing adverse health effects. Due to the conservative methods used to derive risk-based screening levels, it can be assumed with reasonable certainty that concentrations below screening levels will not result in adverse health effects, and that no further evaluation is necessary. Concentrations above conservative risk-based screening levels do not necessarily indicate that a potential risk exists but indicate that further evaluation may be warranted.

The surface water and groundwater data were evaluated using human health risk-based and ecological risk-based screening levels drawn from Federal sources. The screening levels are used to determine if the concentration levels of constituents could pose an unacceptable risk to human health or the environment. The evaluation also considers whether constituents are present in groundwater and surface water above screening levels, and if so, if the results could be due to the ash management operations.

3.2 CONCEPTUAL SITE MODEL

There are no on-site users of alluvial groundwater adjacent to LEC. As documented in the 2018 risk assessment report, while there are approximately 76 private wells recorded within a one-mile radius of the facility, all are located in the bluff area south and upgradient of the facility (a detailed discussion of the wells is presented in the AECOM 2014 report). Thus, there are **no users** of groundwater impacted by molybdenum or any other CCR constituent in the vicinity of the LEC ash management areas and sampling results from the off-site network demonstrate that bedrock groundwater fully complies with federal and state drinking water standards.

3.3 RESULTS

3.3.1 Alluvial Aquifer

Figure 1-2 shows the location of the CCR monitoring wells at the LCPA. A summary of the screening results is presented in the table below:

Table: Assessment Monitoring Reflects High Percentage Compliance

	Labadie Energy Center LCPA – Shallow Alluvial Aquifer
Percent of Assessment Monitoring Parameter Compliance	96%
Percent of Assessment Monitoring Parameter Results Requiring Corrective Action (Constituents)	4% Molybdenum

This is striking, given that the wells are located directly adjacent to and at the base of the ash management area, and the facility has been in operation for 48 years. Note that out of the 2,170

groundwater analyses conducted, only 55 results are above the GWPS. Put another way, over 96% of the groundwater results for the CCR Rule monitoring wells located at the edges of LCPA (UMW-1D through UMW-9D) are below the GWPS.

3.3.2 Surface Water

The Missouri River and Labadie Creek sampling results do not show evidence of impact of constituents derived from LEC. There are no analytical results for the Labadie Creek that are above drinking water screening levels. While arsenic concentrations in the Missouri River and Labadie Creek are slightly above the human health recreational screening levels and lithium concentrations are above the drinking water screening level in the Missouri River, the concentrations are statistically no different in upstream and downstream samples for both arsenic and lithium indicating that **the facility is not the source**.

3.3.3 National Pollutant Discharge Elimination System Outfall

The outfall for the LCPA is identified as 002 and is shown on **Figure 2-2**. This is a permitted outfall under the National Pollutant Discharge Elimination System program. The outfall effluent water is tested for toxicity on a periodic basis as required by the permit. The biological toxicity testing results for Outfall 002 at the LCPA shows no evidence of aquatic toxicity in the outfall effluent.

3.3.4 Off-Site Bedrock Groundwater

The deep groundwater at locations south of the Site are upgradient of the LCPA, as shown on **Figure 2-3**. All results meet drinking water standards and do not show evidence of impact from coal ash (see **Appendix A**). This confirms that the coal ash management practices at the LEC have not had an impact on groundwater used as a source of drinking water.

3.4 CONCLUSION

The sampling results for the Missouri River and Labadie Creek are important. Although groundwater at the edge of ash shows that one constituent is present in some wells are above the GWPS, less than 4% of the results are above a GWPS, and the adjacent surface water bodies do not show evidence of impact of constituents derived from the LCPA. This is important because the absence of concentrations above risk-based screening levels means that there is not a significant pathway of exposure.

Impacts to groundwater do not mean that surface waters are impaired. The degree of interface between groundwater and surface waters is variable and complex and dependent upon a variety of factors including gradient and flow rate. It is possible, however, to determine the maximum concentration level that would need to be present on-site in groundwater and still be protective of the surface water environment. Groundwater and surface waters flow at very different rates and volumes. The Missouri River is the longest river system in North America and as groundwater at the facility flows into the river, it is diluted by more than 100,000 times.

This conservative estimate of dilution is used to further understand how high a molybdenum groundwater concentration would have to be to potentially have an adverse impact on the Missouri River. The table below shows how this factor is applied to the most conservative of the human health and ecological risk-based screening levels for surface water.

CALCULATING RISK-BASED SCREENING LEVELS FOR LCPA GROUNDWATER BASED ON THE MISSOURI RIVER

	Estimated Dilution Factor for the Missouri River				
		100,000			
Constituents	Lowest of the Human Health and Ecological Screening Levels (mg/L)	Groundwater Risk-Based Screening Level* (mg/L)	Maximum LCPA Groundwater Concentration (mg/L)		Ratio Between Groundwater Risk-Based Screening Level and the Maximum LEC Groundwater Concentration
Molybdenum	0.1	10000	0.674	L-UMW-6D	>40,000

*Where the Groundwater Risk-Based Screening Level = Screening Level x Dilution Factor.

The groundwater alternative risk-based screening levels are calculated in units of milligrams of constituent per liter of water (mg/L). One mg/L is equivalent to one part per one million parts.

The table identifies the maximum groundwater concentration of molybdenum detected in the LCPA monitoring wells. The comparison between the target levels and the maximum concentrations indicates that there is a wide margin of safety between the two values. This margin is shown in the last column of the table. To illustrate, concentration levels molybdenum would need to be **more than 40,000 times higher** than currently measured levels before an adverse impact in the Missouri River could occur.

The comprehensive evaluation summarized here demonstrates that there are no adverse impacts on human health from either surface water or groundwater uses resulting from coal ash management practices at the LCPA.

3.4.1 Trace Elements in Coal Ash

All of the inorganic minerals and elements that are present in coal ash are also present naturally in our environment. Molybdenum is referred to as a trace element, so called because they are present in soils (and in coal ash) at such low concentrations (in the milligrams per kilogram (mg/kg) or part per million (ppm) range). Together, the trace elements generally make up less than 1 percent of the total mass of these materials. To put these concentrations into context, a mg/kg or ppm is equivalent to:

- 1 penny in a large container holding \$10,000 worth of pennies, or
- 1 second in 11.5 days, or
- 1 inch in 15.8 miles

All of the constituents present in coal ash occur naturally in our environment. U.S. Geological Survey (USGS) data demonstrate the presence of these constituents in the soils across the U.S. These soils are found in our backyards, schools, parks, etc., and because of their presence in soil, these constituents are also present in the foods we eat. Some of these constituents are present in our vitamins, such as molybdenum. Thus, we are exposed to these trace elements in our natural environment every day, and in many ways.

3.4.2 Molybdenum

Haley & Aldrich has prepared a fact sheet (**Appendix B**) that provides information on molybdenum so that the groundwater data can be considered in context. There is no public exposure to groundwater at

the LEC and concentration levels of molybdenum in adjacent surface waters are all well below health-based regulatory standards.

As discussed in more detail in **Appendix B**, molybdenum is an essential nutrient for humans, and the Institute of Medicine of the U.S. National Academy of Sciences (NAS) has provided recommended daily allowances (RDA) and tolerable upper limits (UL) to be used as guidelines for vitamins and supplements and other exposures (NAS, 2001).

The RDA for a nutrient is “the average daily dietary nutrient intake level sufficient to meet the nutrient requirement of nearly all (97 to 98 percent) health individuals” (NAS, 2001). The RDA for molybdenum for adults set by the NAS in 2001 is 0.045 mg/day and is based on the amount of molybdenum needed to achieve a steady healthy balance in the body for the majority of the population.

The UL for molybdenum set by the NAS is 2 mg/day. This level is based on an evaluation of the potential toxicity of molybdenum at high levels of intake. Based on the UL, a safe drinking water level for molybdenum is 0.6 mg/L or 600 ug/L, or six-fold higher than the level set by USEPA of 0.1 mg/L or 100 ug/L in the CCR Rule. This difference serves to underscore the conservatism of the USEPA value when evaluating groundwater under the CCR Rule. Below is a chart that depicts groundwater and surface water samples collected from Ameren’s four energy centers and compares concentration levels based on both the NAS UL and the GWPS established by the USEPA in the CCR Rule. As reflected in the chart below, over 90% of the GW results across all four energy centers and all but **three samples** at Labadie are below the standard the National Academy of Science developed for vitamins and supplements.

	Labadie	Meramec	Rush Island	Sioux
Groundwater				
Number of Samples	208	88	77	244
Molybdenum greater than CCR GWPS of 0.1 mg/L (a)	81	35	38	77
Molybdenum greater than NAS standard of 0.6 mg/L (b)	3	1	11	49
Surface Water				
Number of Samples	67	74	50	80
Molybdenum greater than 0.1 mg/L (a)	0	0	0	0

Notes:

mg/L - milligrams per liter.

(a) - Drinking water-based on GWPS specified in the CCR Rule.

(b) - Alternative health-protective drinking water screening level based on the NAS

3.5 EVALUATION OF RISK IN THE CORRECTIVE MEASURES ASSESSMENT

In summary, there are no adverse impacts resulting from coal ash management practices at the LCPA on human health or the environment from either surface water or groundwater uses. There are no users of groundwater near LCPA. In fact, as described above, concentrations of molybdenum detected in groundwater would need to be more than **40,000 times higher** before such an unacceptable risk could exist under current and reasonable anticipated future uses of the surface water.

Although the purpose of this CMA is to evaluate remedies to address the SSLs, the current conditions at the LCPA, even prior to closure, do not pose an unacceptable risk to human health or the environment. Therefore, the risk-based evaluation provides additional support for the selection of a remedy moving forward.

4. Corrective Measures Alternatives

4.1 CORRECTIVE MEASURES ASSESSMENT GOALS

The overall goal of this CMA is to identify and evaluate the appropriateness of potential corrective measures to prevent further releases of Appendix IV constituents above their GWPS, to remediate releases of Appendix IV constituents detected during groundwater monitoring above their GWPS that have already occurred, and to restore groundwater in the affected area to conditions that do not exceed the GWPS for these Appendix IV constituents. The corrective measures evaluation that is discussed below and subsequent sections provides an analysis of the effectiveness of five potential corrective measures in meeting the requirements and objectives of remedies as described under §257.97 (also shown graphically on **Figure 4-1**). This assessment also meets the requirements promulgated in §257.96 which require the assessment to evaluate:

- The performance, reliability, ease of implementation, and potential impacts of appropriate potential remedies, including safety impacts, cross-media impacts, and control of exposure to residual contamination;
- The time required to complete the remedy; and
- The institutional requirements, such as state or local permit requirements or other environmental or public health requirements that may substantially affect implementation of the remedy.

The criteria listed above are included in the balancing criteria considered during the corrective measures evaluation, described in **Section 5**.

4.2 GROUNDWATER MODELING

Modeling is an analytical tool used to create estimates based on computer-simulated conditions. Groundwater flow and geochemical modeling⁷ performed by Gredell evaluated the hydrogeologic and geochemical conditions at the LCPA. Gredell used MT3DMS to model contaminant transport at the LCPA, conservatively assuming that hydrodynamic dispersion is the only process that attenuates the concentration molybdenum during transport in groundwater.

4.3 GROUNDWATER TREATMENT EVALUATION

In-situ treatment to reduce the concentrations of dissolved metals in groundwater can occur via stabilization of metals through precipitation of a metal compound, co-precipitation of the target metal within the structure of another compound, and/or sorption of the target metal onto other compounds in the subsurface. In simple terms, groundwater amendments are injected into the aquifer to create a chemical reaction that attenuates metals through precipitation or sorption.


Chemical precipitation is an available and demonstrated groundwater treatment technology recognized by USEPA⁸. Groundwater geochemistry (including oxidation reduction potential (ORP)) can greatly

⁷Groundwater flow modeling was performed using MODFLOW 2000.

⁸ EPA, "Effluent Limitations Guidelines and Standards for the Steam Electric Power Generating Point Source Category: EPA's Response to Public Comments; Part 7 of 10", SE05958A6, p. 7-20

impact metals mobility at a site, where some metal compounds may be more soluble under highly oxidative (positive ORP) conditions while others are more soluble under reduced conditions (negative ORP). Also, the solubilities of many metal compounds are highly dependent on pH.

Ameren has retained XDD to research and develop appropriate treatment options for molybdenum and is performing bench-scale treatability studies to demonstrate the effectiveness of treatment options on site-specific basis. Evaluations of the Rush and Meramec Energy Centers commenced earlier this year and XDD has collected soil and groundwater samples from the LEC impoundment area. Laboratory results for Rush Island indicate that molybdenum concentrations can decrease at certain pH levels. Bench-scale treatment results from such studies including potential treatment trains from all four of Ameren's energy centers are expected to be completed in the Summer of 2019.



pH and Water (USGS - Water Science School publication).

4.4 CORRECTIVE MEASURES ALTERNATIVES

Corrective measures can terminate when groundwater impacted by the LCPA does not exceed the Appendix IV GWPS for three consecutive years of groundwater monitoring. In accordance with §257.97, the groundwater corrective measures to be considered must meet, at a minimum, the following threshold criteria:

1. Be protective of human health and the environment;
2. Attain the GWPS;
3. Control the source(s) of releases so as to reduce or eliminate, to the maximum extent feasible, further releases of COCs to the environment;
4. Remove from the environment as much of the contaminated material that was released from the CCR unit as is feasible, considering factors such as avoiding inappropriate disturbance of sensitive ecosystems; and
5. Comply with standards (regulations) for waste management.

Each of the remedial alternatives assembled as part of this CMA meet the requirements of the threshold criteria listed above.

The remedial alternatives presented below contemplate both CIP (Alternative 1 through 4) and CBR (Alternative 5) of the LCPA. Both closure methods are expressly authorized under the CCR Rule.

4.4.1 Alternative 1 – Closure in Place with Capping and Monitored Natural Attenuation

The LCPA would be closed in place with a geomembrane and soil protective cap system to reduce infiltration of surface water to groundwater thereby isolating source material. This cap selection exceeds regulatory requirements by more than two orders of magnitude ($<1 \times 10^{-7}$ centimeters per second (cm/sec) planned versus 1×10^{-5} cm/sec required by the CCR Rule). Over time, depletion of COCs in CCR would allow the concentration of COCs in downgradient groundwater to decline and overall groundwater concentrations of COCs to attenuate. Geochemical modeling results indicate that post closure 99% of groundwater will flow around and not through the LCPA, thereby isolating the source.

The dissolved phase plume of molybdenum remaining above the GWPS post-closure eventually attenuates. The timeline for MNA duration for molybdenum is shown on **Figure 4-2**.

CIP can be completed safely, in compliance with applicable federal and state regulations, and be protective of public health and the environment. In general, CIP consists of installing a cap/cover designed to significantly reduce infiltration from surface water or rainwater, resist erosion, contain CCR materials, and prevent exposures to CCR. For this alternative, Ameren would install a geomembrane with a permeability that is 100 times lower than what the CCR Rule requires thus further reducing infiltration. At the LEC, site preparation, construction and installation of cap and cover systems will take approximately 18 to 24 months.

MNA is a viable remedial technology recognized by both state and federal regulators that is applicable to inorganic compounds in groundwater. The USEPA defines MNA as “the reliance on natural attenuation processes to achieve site-specific remediation objectives within a time frame that is reasonable compared to that offered by other more active methods”. The ‘natural attenuation processes’ that are at work in such a remediation approach include a variety of physical, chemical, or biological processes that, under favorable conditions, act without human intervention to reduce the mass, toxicity, mobility, volume, or concentration of contaminants in soil or groundwater. These in-situ processes include biodegradation; dispersion; dilution; sorption; volatilization; radioactive decay; and chemical or biological stabilization, transformation, or destruction of contaminants” (USEPA, 2015). When combined with a low-permeability cap to address the source by limiting the infiltration of precipitation into and through the CCR, MNA can over time reduce concentrations of molybdenum in groundwater at the LCPA boundary.

Following the installation of the cap system, Ameren would implement post-closure care activities. Post-closure care includes long-term groundwater monitoring until such time that groundwater conditions return to regulatory levels and cap system maintenance. Future development of the capped surface could be used for solar photovoltaic arrays or other site staging/ancillary operational needs.

4.4.2 Alternative 2 – CIP with In-Situ Stabilization, Capping and Monitored Natural Attenuation

In-situ stabilization is a technique that uses mixing of the CCR with amendments to solidify the material in place. Amendments typically include Portland Cement and the solidification is completed in-situ using large diameter augers. CCR located beneath the water table would be isolated by ISS, followed by capping of the surface impoundment. Groundwater impacts would be addressed through the processes of natural attenuation. This alternative would isolate the source, and over time, allow the concentrations of COCs in downgradient groundwater to decline and overall groundwater concentrations of COCs to attenuate.

In-situ stabilization of the LCPA is predicted to take a number of years to complete, depending on the availability of specialized contractors and equipment. Additionally, implementation of ISS will require a detailed design effort with bench scale testing to determine the appropriate amendment mix. Pilot testing will also be needed to verify the ability of equipment to solidify material at depth. ISS has not been commonly used to stabilize entire ash units as part of a closure strategy. Changes to groundwater chemistry relative to the mobility of Appendix IV constituents following completion of ISS, where large volumes of amendments (typically Portland cement) are added to the subsurface, are unknown and would require pilot testing.

Following the ISS completion and low-permeability final cover system ($<1 \times 10^{-7}$ cm/sec), Ameren would implement post-closure care activities that includes long-term groundwater monitoring and cover system maintenance; future development of the capped surface could be used for solar photovoltaic arrays or other site staging/ancillary operational needs.

4.4.3 Alternative 3 – CIP with Capping and In-Situ Groundwater Treatment

Similar to Alternative 1, the LCPA would be CIP with a low-permeability ($<1 \times 10^{-7}$ cm/sec) cap to reduce infiltration of surface water to groundwater and to isolate source material. Molybdenum would be addressed through in-situ injection of groundwater amendments downgradient of the LCPA with the objective of accelerating the time required to achieve the GWPS within the treatment zone.

Following the installation of the low-permeability cap and in-situ treatment system, Ameren would implement post-closure care activities that include periodic amendment injections or periodic replenishment of the treatment reagents within the permeable reactive barrier (PRB), long-term groundwater sampling to monitor treatment system performance, and cover system maintenance. Future development of the capped surface could be used for solar photovoltaic arrays or other site staging/ancillary operational needs.

4.4.4 Alternative 4 – CIP with Capping and Hydraulic Containment Through Groundwater Pumping and Ex-Situ Treatment

The LCPA would be closed in place with a low-permeability ($<1 \times 10^{-7}$ cm/sec) cap to reduce infiltration and isolate source material. Pumping wells would be used to hydraulically control the downgradient migration of molybdenum. However, pumping wells would generate large volumes of effluent that would require ex-situ treatment, likely with an ion exchange or a reverse osmosis (RO) treatment system. Both treatment systems are complex with ongoing operation and maintenance and would generate a secondary waste stream – including regeneration/replacement of the ion exchange media or concentration reject water from the RO system. Approvals and permitting would be required for the construction and installation of the treatment systems and discharge of the treated groundwater.

Implementation of a large-scale hydraulic containment system will require a detailed design effort with bench scale testing to verify groundwater treatment. Pilot testing, such as pumping tests and additional groundwater modeling, will be needed to verify the hydraulic capture zone. While hydraulic containment is a widely used remediation technology, it has not been commonly used as part of a large-scale CCR unit closure strategy.

Following the installation of the low-permeability cap, groundwater pumping well network, and ex-situ treatment system, Ameren would implement post-closure care activities that includes operation and maintenance of the hydraulic containment (HC) system, long-term groundwater sampling to monitor HC system performance, and cover system maintenance. Future development of the capped surface could be used for solar photovoltaic arrays or other site staging/ancillary operational needs.

4.4.5 Alternative 5 – Closure by Removal with Monitored Natural Attenuation

This alternative consists of removal of LCPA contents followed by natural attenuation of molybdenum in groundwater. While this alternative would eliminate (through removal) the source, it takes decades to implement during which time the LCPA would remain open and the ponded ash subject to ongoing

infiltration for the duration of the removal activities. As with Alternative 1, 2, and 3 concentration of molybdenum in downgradient groundwater would decline via natural attenuation processes.

Lochmueller Group prepared an Extraction and Transportation Assessment (Lochmueller Study) to evaluate CBR excavation and disposal scenarios. On-site and off-site disposal options were considered. The LEC presents unique challenges that can impact cost estimates and closure times. It is important to note that the existing on-site UWL was designed and permitted to manage ongoing production through the retirement dates of the LEC. Accordingly, excavated material would need to be transported off-site to a commercial landfill or Ameren Missouri would need to permit and construct a new on-site landfill. The regulatory process for construction of an on-site landfill could require multiple levels of approval including environmental permits, conditional use local authorization and, if necessary, certificate issuance from the Missouri Public Service Commission. Opposition to such projects and regulatory approval would take years to resolve *before* construction could commence. As a point of reference, efforts to permit and construct the existing UWL commenced in 2008. Following years of litigation and opposition from environmental groups, the UWL was placed in service in 2016⁹.

There are also several potential community impacts, safety concerns and project duration challenges associated with the CBR alternative for the off-site disposal option. Given the magnitude of the total estimated haul volume (17.3 MM CY) along with the travel distance required to transport the CCR to one or more off-site landfills, injuries and fatalities would be likely. The Lochmueller Study (**Appendix C**) estimated that the time period needed to transport off-site to a commercial landfill could be 35 years or greater. The Lochmueller Study bases its time estimate on assumed productivity rates that are subject to significant variability and potential disruptions (e.g., weather conditions, available landfill capacity, travel route traffic congestion, etc.) that could impact the overall CBR timeframe. As the report makes clear, there is simply a limit on how much excavation, and roundtrip truck hauls can occur on a given eight-hour workday.

Excavated materials from the LCPA would not be suitable for beneficial use applications, due to chemical reactions that occurred during the placement of class C fly ash via wet sluicing. Traditional beneficial use applications for class C fly ash, such as replacement for cement in the production of ready-mix concrete and concrete related products require the materials to be capable of reacting chemically to produce cementitious bonds. The capability to produce these chemical reactions have been expended with the wet-sluicing process of CCR into LCPA. In contrast, the chemistry of class F fly ash, produced at other utility sites, does not react with sluice water to create cementitious bonds, and thus may be suitable for recovery and processing for use in ready mix concrete and concrete related products¹⁰.

In addition to the logistical challenges of designing and construction an on-site landfill, technical and logistical challenges of implementing a large-scale ash removal project also need to be considered. Removal activities will be difficult and require full-time dewatering, implementation of CCR stabilization methods and temporary staging/stockpiling of material for drying prior to transportation; these

⁹ *See* Petition for Writ of Certiorari [to invalidate county landfill ordinance] Franklin County Circ. Ct., 11/23/11, Case # 11AB-C286; Appeal to Franklin County Board of Adjustment, #14-00002, Filed 1/8/14 (of Land Use Administrator 10/10/13 and 12/10/13 Decisions), Denied by BZA 6/24/14; Appealed to Circ. Ct. by Writ of Certiorari, Cause # 14AB-CC00155, 7/24/14; Intervention and Motion to Dismiss in PSC Case EA 2012-0281, Ameren Application to PSC for CCN to operate landfill (PSC overruled Motion to Dismiss on 4/17/13); Administrative Hearing Commission Petition for Review [of MDNR Solid Waste Disposal Construction Permit], Filed 1-30-15, #15-0136, dismissed by AHC 3/5/15. See also *Campbell v. County Commission of Franklin County*, 453 S.W.3d 762 (Mo. banc 2015).

¹⁰ Information provided by Ameren technical staff, May 2019.

considerations will affect productivity and increase removal duration. Excavation and construction safety during the removal duration is another major concern due to heavy equipment (bulldozers, excavators, front end loaders, off-road trucks) and dump truck operation within the active LEC site. Additional community impacts associated with the use of heavy equipment and truck traffic are also a consideration for this alternative. Lastly, further review of local restrictions and approvals would be required to verify that any selected landfill could receive the ash for disposal.

5. Comparison of Corrective Measures Alternatives

The purpose of this section is to evaluate, compare, and rank the five corrective measures alternatives using the balancing criteria described in §257.97.

5.1 EVALUATION CRITERIA

In accordance with §257.97, remedial alternatives that satisfy the threshold criteria are then compared to four balancing (evaluation) criteria. The balancing criteria allow a comparative analysis for each corrective measure, thereby providing the basis for final corrective measure selection. The four balancing criteria include the following:

1. The long- and short-term effectiveness and protectiveness of the potential remedy(s), along with the degree of certainty that the remedy will prove successful;
2. The effectiveness of the remedy in controlling the source to reduce further releases;
3. The ease or difficulty of implementing a potential remedy; and
4. The degree to which community concerns are addressed by a potential remedy.

Public input and feedback will be considered following a public information session to be held in May 2019.

5.2 COMPARISON OF ALTERNATIVES

This section compares the alternatives to each other based on evaluation of the balancing criteria listed above. The goal of this analysis is to identify the alternative that is technologically feasible, relevant and readily implementable, provides adequate protection to human health and the environment, and minimizes impacts to the community.

A graphic is provided within each subsection below to provide a visual snapshot of the favorability of each alternative, where green represents favorable, yellow represents less favorable, and red represents unfavorable.

5.2.1 The Long- and Short-Term Effectiveness and Protectiveness of the Potential Remedy, along with the Degree of Certainty That the Remedy Will Prove Successful

This balancing criterion takes into consideration the following sub criteria relative to the long-term and short-term effectiveness of the remedy, along with the anticipated success of the remedy.

5.2.1.1 *Magnitude of reduction of existing risks*

As summarized in **Section 3**, no unacceptable risk to human health and the environment exists with respect to the LCPA. Therefore, none of the remedial alternatives are necessary to reduce an assumed risk posed by Appendix IV constituents in groundwater because no such adverse risk currently exists. However, other types of impacts can be posed by the various remedial alternatives considered here. The remedial alternatives that pose the least external impact are Alternative 1 (CIP with MNA) and 3 (CIP with in-situ treatment) because they are implemented onsite and involve the least amount of construction and operations and maintenance (O&M) activities and associated impacts. Alternative 5

(CBR with MNA) has the highest potential impact due to prolonged truck traffic, which increases the likelihood of roadway accidents during the decades needed to complete the CBR project. Further, during the long removal process, CCR material will remain open to the environment. Construction and material transportation will also be required for Alternative 2 (CIP with ISS) during the process of solidifying the CCR. Aside from the cap construction, only minor construction will be required for Alternatives 3 (CIP with in-situ). Additional construction will be required for Alternative 4 (CIP with HC) during treatment system installation.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria i) Magnitude of reduction of risks					

5.2.1.2 Magnitude of residual risks in terms of likelihood of further releases due to CCR remaining following implementation of a remedy

Alternative 5 (CBR with MNA) has the lowest long-term residual risk in that the source material is removed. However, implementation of this alternative would take decades to implement during which time the source material (ash) is subject to ongoing infiltration (because it remains open to the environment during removal), relative to the other alternatives. For Alternatives 1 through 4, the CCR would be CIP with the installation of a low permeability (<1 x 10⁻⁷ cm/s) cap that virtually eliminates infiltration of precipitation and isolates the source material. Dissolved phase COCs to groundwater are addressed through MNA processes. Alternatives 3 and 4 also provide additional measures to address potential groundwater impacts through in-situ treatment and hydraulic controls. A low residual risk for releases exists with Alternative 2 (CIP with ISS) upon completion provided that solidification amendments do not have an adverse geochemical impact on the groundwater aquifer.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria ii) Magnitude of residual risk in terms of likelihood of further release					

5.2.1.3 The type and degree of long-term management required, including monitoring, operation, and maintenance

Alternative 1 (CIP with MNA) is the most favorable alternative with respect to this criterion because it requires the least amount of long-term management and involves no mechanical systems as part of the remedy. Alternative 5 (CBR with MNA) is least favorable because off-site removal is estimated to take approximately 40 years or greater to complete and involves coordination with off-site disposers (landfills). The design and construction of an on-site landfill is also logistically complex with the design, permitting, approvals and construction required and anticipated legal challenges. The remaining alternatives fall between Alternatives 1 and 5 because they involve more intensive systems to implement and/or maintain throughout their remediation life cycle.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria iii) Type and degree of long-term management required					

5.2.1.4 Short-term risks that might be posed to the community or the environment during implementation of such a remedy

The highest short-term impact posed to the community or environment would be during implementation of Alternative 5 (CBR with MNA) followed by Alternative 2 (CIP with ISS), making these alternatives least favorable. Potential environmental impacts include noise and emissions from heavy equipment, the potential for a release during excavation and dewatering, and fugitive dust emissions. Community impacts include general impacts to the community due to increased truck traffic on public roads during the entire project duration, along with an increased potential for traffic accidents and fatalities, noise, and truck emissions. As noted, Alternative 5 (whether off-site disposal or a new onsite landfill) will require a substantial period of time when the LCPA will remain open to the environment posing risk during implementation of this remedy.

For Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC), risk to the community during implementation is considered the same and would be minimal compared to the other alternatives. Periodic sampling of the monitoring well network to verify treatment system effectiveness will pose no risk to the community.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria iv) Short term risk to community or environment during implementation					

5.2.1.5 Time until full protection is achieved

There is currently no unacceptable risk to human health and the environment associated with groundwater at the LCPA; therefore, protection is already achieved. Based upon predictive modeling, Alternative 1 (CIP with MNA), molybdenum concentrations will attain GWPS in approximately 22 years (see **Figure 4-2**). With in-situ groundwater treatment, such time is predicted to occur in 16 years. Both Alternatives 3 (CIP with in-situ treatment) and 4 (CIP with HC) take the least amount of time to reduce COC concentrations (see **Figure 4-2**). These two alternatives are favorable given the shorter timeframe to achieve the requisite performance standard.

Alternative 5 (CBR with MNA) could take approximately 35 to 40 years to fully implement followed by a period of groundwater monitoring to verify natural attenuation of the existing groundwater plume, which makes this alternative unfavorable. As detailed in the Lochmueller report, implementation is limited mainly by the amount of material that can be excavated and hauled during a workday, disposal facility capacity, and the volume of ash. If a new on-site landfill is considered, the permitting and approval process will be lengthy and legal challenges are expected.

Implementation of Alternative 2 (CIP with ISS) would require extensive engineering analysis and field testing. Assuming such studies confirm the viability of ISS technology at the LCPA and equipment availability, field implementation could take a significant amount of time to implement due to the

volume of ash. Ongoing groundwater monitoring will be required as the MNA process addresses the existing dissolved phase plume. Including a five-year time horizon for planning and regulatory approvals, the total timeframe until achieving the GWPS for this alternative is comparable to the timeframe estimated for Alternatives 1, 3, and 4.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria v) Time until full protection is achieved					

5.2.1.6 Potential for exposure of humans and environmental receptors to remaining wastes, considering the potential threat to human health and the environment associated with excavation, transportation, re-disposal, or containment

Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC) all have similar, minimal potential for exposure to humans and environmental receptors during regrading and cap construction; monitoring well system installation; and installation of the in-situ treatment system, or HC system. Alternative 1 (CIP with MNA) is the most favorable alternative since, aside from capping, no additional contact with CCR or impacted groundwater would be needed. Alternative 3 (CIP with in-situ treatment) is also favorable because treatment occurs below ground and no waste stream is generated. A waste stream would be generated under Alternative 4 (CIP with HC) and need to be managed either on-site or off-site, which creates a potential for exposure.

Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) have moderate and high potential for exposure, respectively, which makes them the least favorable remedy for this criterion. A high potential for exposure exists during the excavation and transport (both off-site and on-site) of the CCR over local roadways if Alternative 5 is implemented. A moderate potential to exposure exists during ISS construction (Alternative 2) if some CCR needs to be disposed off-site as part of the preliminary removal effort prior to ISS implementation.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria vi) Potential for exposure of humans and environmental receptors to remaining wastes					

5.2.1.7 Long-term reliability of the engineering and institutional controls

Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC) are all expected to have high long-term reliability, as capping and long-term monitoring are common methods for long-term waste management. HC and ex-situ treatment (Alternative 4) are considered reliable, proven technologies and would have high long-term reliability, but require bench scale testing and rely on mechanical systems to operate. Alternative 3 will require bench scale and pilot scale testing to confirm treatability of molybdenum. Of the CIP alternatives, Alternative 1 (CIP with MNA) is considered the most favorable because no additional ongoing O&M would be needed, other than periodic groundwater sampling and verification of decreasing concentrations.

For Alternatives 1 through 4, which include CIP, institutional controls such as the recording of an environmental covenant restricting the use of groundwater can easily be implemented because the LPCA is located on property owned by Ameren.

Alternative 5 (CBR with MNA) engineering and institutional controls would have high long-term reliability because the CCR will have been removed from the LPCA. With the CCR no longer in place, no additional engineering and institutional controls are anticipated. Alternative 2 (CIP with ISS) is also expected to have a high long-term reliability because the CCR would be isolated within the ISS monolith.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria vii) Long-term reliability of engineering and institutional controls					

5.2.1.8 Potential need for replacement of the remedy

CIP of the LPCA with ISS (Alternatives 2) and CBR (Alternative 5) are both considered permanent and can be effective in appropriate circumstances. For Alternative 2 (CIP with ISS) detailed engineering assessments would need to be completed before the viability of such an approach could be considered at a unit such as the LPCA given its depth and volume. Field pilot testing would also be needed for ISS to confirm the ability of equipment to reach the bottom of CCR. From the perspective of needing to replace the remedy, source removal (Alternative 5) is permanent but takes decades to implement.

Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC) are expected to have permanent closures with capping in place. Should monitoring results indicate that the selected remedial alternative is not effective at reducing the concentration of COCs over time, alternate and/or additional active remedial methods for groundwater may be considered in the future.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 1 - Subcriteria viii) Potential need for replacement of the remedy					

5.2.1.9 Long- and short-term effectiveness and protectiveness criterion summary

The graphic below provides a summary of the long- and short-term effectiveness and protectiveness of the potential remedy, along with the degree of certainty that the remedy will prove successful. Alternatives 1 (CIP with MNA) and 3 (CIP with in-situ treatment) are the most favorable, while Alternative 5 (CBR with MNA) is the least favorable. Alternative 1 is expected to be effective both short- and long-term and does not include additional treatment technology aside from MNA. Alternative 3 (CIP with in-situ treatment) is comparable to Alternative 1 because it has a shorter timeframe to meet the GWPS despite requiring treatment. Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) will require a lengthy design and construction period, and therefore are not effective in the short-term. Further, to implement Alternative 5, the impoundment will be open to the environment during the lengthy removal process.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
CATEGORY 1 Long- and Short Term Effectiveness, Protectiveness, and Certainty of Success					

5.2.2 The Effectiveness of the Remedy in Controlling the Source to Reduce Further Releases

This balancing criterion takes into consideration the ability of the remedy to control a future release, and the extensiveness of treatment technologies that will be required.

5.2.2.1 The extent to which containment practices will reduce further releases

For remedial Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC) installation of the low permeability cap will reduce the infiltration of surface water into the LCPA and decrease the flux of COCs passing from ash porewater to groundwater over time. Groundwater mounding, and associated outward hydraulic gradient, present at the LCPA during operation is expected to dissipate after closure. Alternatives 3 and 4 are considered the most favorable because treatment technologies (in-situ treatment and HC) will be implemented to limit down-gradient migration of COCs in groundwater.

Under Alternatives 2 (CIP with ISS) and 5 (CBR with MNA), no further releases are anticipated following solidification or removal of the CCR material. However, the implementation of each of these alternatives is anticipated to require multiple years to complete with MNA monitoring following completion of construction. During the period of construction for Alternatives 2 and 5, the CCR material remains open to the environment.

For Alternatives 3 (CIP with in-situ treatment) and 4 (CIP with HC), additional containment or treatment practices (in-situ treatment and HC with ex-situ treatment) will address COCs in groundwater migrating downgradient, achieving the performance criteria at the waste boundary. Alternative 4, however, will create additional waste streams requiring management on and off site. Alternative 1 will not have an additional containment technology beyond natural attenuation but is expected to reduce the concentrations below the GWPS over time.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
<i>Category 2 - Subcriteria i)</i> Extent to which containment practices will reduce further releases					

5.2.2.2 The extent to which treatment technologies may be used

No groundwater treatment technologies, other than natural attenuation, will be used for Alternatives 1 and 5. There would be no ongoing operation and maintenance of a treatment technology, other than periodic groundwater monitoring. Alternative 1 relies only on low-permeability capping, and therefore is the most favorable.

Alternative 2 (CIP with ISS) uses solidification of the CCR below the water table to address COCs in groundwater.

Alternative 3 will use one additional technology, in-situ treatment, while Alternative 4 will use two additional technologies, HC and ex-situ treatment. The operation of an ex-situ treatment system will create a secondary waste stream, such as concentrated reject water (RO) requiring off-site disposal, or depleted resin (ion exchange), requiring regeneration or off-site disposal.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 2 - Subcriteria ij Extent to which treatment technologies may be used					

5.2.2.3 Effectiveness of the remedy in controlling the source to reduce further releases summary

The graphic below provides a summary of the effectiveness of the remedial alternatives to control the source to reduce further releases. Alternative 3 (CIP with in-situ treatment) is the most favorable, while Alternatives 1, 2, 4, and 5 are less favorable. The construction period for Alternative 3 (CIP with in-situ treatment) is expected to be brief and will begin treating groundwater at the unit boundary immediately. Further releases under Alternative 2 (CIP with ISS) and Alternative 5 (CBR with MNA) will not be addressed until construction is complete.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
CATEGORY 2 Effectiveness in controlling the source to reduce further releases					

5.2.3 The Ease or Difficulty of Implementing a Potential Remedy

This balancing criterion takes into consideration technical and logistical challenges required to implement a remedy, including practical considerations such as equipment availability and disposal facility capacity.

5.2.3.1 Degree of difficulty associated with constructing the technology

CIP with a low permeability cap will be straightforward and can be implemented with common construction methods for Alternatives 1 (CIP with MNA), 3 (CIP with in-situ treatment), and 4 (CIP with HC). No construction difficulties are anticipated if Alternatives 1, 3, and 4 are implemented. Specialty equipment or contractors are not required. Alternative 3 may be slightly more difficult to implement should a subsurface trench be required for a permeable barrier. For Alternative 1, no additional treatment technology is needed other than monitoring wells for groundwater monitoring. Installation of an in-situ treatment system (Alternative 3) or groundwater pumping wells with an ex-situ treatment system (Alternative 4) is expected to be straightforward, although with Alternative 4, an additional waste stream will require handling.

Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) will be difficult to implement due to technical and logistical challenges. Alternative 5 will include a deep excavation below the water table, ongoing excavation dewatering, and the transportation of 17.3 MM CY of CCR over local roadways. If an on-site landfill is considered, complex and lengthy design, permitting and construction is required, and litigation is expected. Under Alternative 2, the successful completion of ISS to target depths will be technically challenging and will require field pilot testing to confirm equipment reach. Alternatives 2 and 5 will both

include large-scale construction, specialty equipment and contractors, long project durations, and significant technical challenges.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 3 - Subcriteria i) Degree of difficulty associated with constructing the technology					

5.2.3.2 Expected operational reliability of the technologies

Alternative 1 (CIP with MNA) is considered the most favorable from an operational perspective because capping with MNA has a proven track record and requires limited O&M. While Alternative 2 (CIP with ISS) is a proven technology and isolates the ponded material, pilot testing would be required to ensure ISS will be able to solidify CCR at depth and implementation is challenging. The potential for geochemical impact on the groundwater aquifer from the solidification amendments would need to be evaluated. Alternatives 3 and 4 are expected to be reliable but will utilize additional groundwater treatment technologies. Alternative 5 (CBR with MNA) is considered a reliable alternative as all CCR material would be removed, although implementation would be challenging (whether by off-site disposal or a new on-site landfill).

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 3 - Subcriteria ii) Expected operational reliability of the technologies					

5.2.3.3 Need to coordinate with and obtain necessary approvals and permits from other agencies

Alternative 1 (CIP with MNA) is the most favorable since the implementation of the remedy is straightforward and only includes capping and MNA. Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) will require extensive permitting and approvals for large-scale construction whereas the permitting is expected to be straightforward for CIP Alternatives 1, 3, and 4. Alternative 5 in particular, has the potential to present the greatest need for coordination of and obtaining numerous permits and approvals if on-site landfilling is selected. Additional approval and permitting may be required for Alternative 3 (CIP with in-situ treatment) because this alternative may include subsurface treatment via groundwater amendment and permitting would likely be required for Alternative 4 for the construction and installation of the treatment systems and discharge of treated groundwater.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 3 - Subcriteria iii) Need to coordinate with and obtain necessary approvals and permits from other agencies					

5.2.3.4 Availability of necessary equipment and specialists

Alternative 1 (CIP with MNA) is the most favorable since specialty equipment and specialists will not be required to implement the MNA remedy. For Alternative 3, specialists have already been retained by Ameren. Alternative 4 will require equipment for pumping and treatment and is less favorable than Alternatives 1 and 3 but equipment required should not present great challenge.

Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) are the least favorable since both will require specialty remediation contractors to implement ISS or full removal, respectively, which will include large-scale construction dewatering and effluent management and treatment, deep excavations below the water table, transportation of material to off-site disposal facilities, and implementation of ISS at depth (for Alternative 2 only). Alternative 4 does require the availability of necessary equipment so this Alternative is less favorable than Alternative 1. The specialists for Alternative 3 have already been retained so Alternative 3 is favorable as well.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 3 - Subcriteria iv) Availability of necessary equipment and specialists					

5.2.3.5 Available capacity and location of needed treatment, storage, and disposal services

The Lochmueller Study assists in the consideration of the CBR alternative (Alternative 5) by evaluating available capacity at landfills reasonably proximate to the LEC that could potentially receive CCR for disposal. Three such landfills were identified. However, as Lochmueller notes, Ameren intends to close ash impoundments at **all** of its energy centers over the next four years and it is uncertain whether these landfills would have sufficient available capacity to accommodate such massive excavation projects in addition to their general municipal solid waste requirements. Due to the disposal requirements, Alternative 5 (CBR with MNA) is the least favorable alternative. Alternative 2 (CIP with ISS), includes amendments such as Portland Cement and would need to be imported to the LEC to solidify the material in-situ.

Because the LCPA will be CIP for Alternatives 1, 2, 3, and 4, storage, and disposal services for CCR material will not be needed. Temporary stockpiling of CCR during regrading and capping can be completed within the current boundaries of the ash unit. Alternative 1 is the most favorable alternative since no active treatment is included. Both Alternatives 2 & 3 include treatment. For Alternative 4, the ex-situ treatment system may generate a concentrated waste stream which would require onsite treatment or off-site transportation and disposal that the other alternatives would not require. For Alternative 5, the existing on-site UWL was designed and permitted to manage ongoing production through the retirement date of the LEC and not ponded CCR material. As such there is no available on-site capacity. Excavated material would need to be transported off-site to a commercial landfill or Ameren Missouri would need to permit and construct a new on-site landfill.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
Category 3 - Subcriteria v) Available capacity and location of needed treatment, storage, and disposal services					

5.2.3.6 *Ease or difficulty of implementation summary*

The graphic below provides a summary of the ease or difficulty that will be needed to implement each alternative. Alternatives 1 (CIP with MNA) is the most favorable, while Alternatives 2 (CIP with ISS) and 5 (CBR with MNA) are the least favorable.

	Alternative 1 CIP with Cap & MNA	Alternative 2 CIP with Cap, ISS, & MNA	Alternative 3 CIP with Cap & In-Situ GW Treatment	Alternative 4 CIP with Cap & Hydraulic Containment	Alternative 5 CBR with MNA
CATEGORY 3 Ease of implementation					

6. Summary

This Corrective Measures Assessment has evaluated the following alternatives:

- Alternative 1 – Closure in Place with Capping and Monitored Natural Attenuation
- Alternative 2 – CIP with In-Situ Stabilization, Capping and MNA
- Alternative 3 – CIP with Capping and In-Situ Groundwater Treatment
- Alternative 4 – CIP with Capping and Hydraulic Containment Through Groundwater Pumping and Ex-situ Treatment
- Alternative 5 – Closure by Removal with MNA

In accordance with §257.97, each of these alternatives has been evaluated in the context of the following threshold criteria:

- Be protective of human health and the environment;
- Attain the GWPS;
- Control the source(s) of releases so as to reduce or eliminate, to the maximum extent feasible, further releases of COCs to the environment;
- Remove from the environment as much of the contaminated material that was released from the CCR unit as is feasible, considering factors such as avoiding inappropriate disturbance of sensitive ecosystems; and
- Comply with standards (regulations) for waste management.

In addition, in accordance with §257.96, each of the alternatives has been evaluated in the context of the following balancing criteria:

- The performance, reliability, ease of implementation, and potential impacts of appropriate potential remedies, including safety impacts, cross-media impacts, and control of exposure to residual contamination;
- The time required to complete the remedy; and
- The institutional requirements, such as state or local permit requirements or other environmental or public health requirements that may substantially affect implementation of the remedy.

This Corrective Measures Assessment, and the input received during the public comment period, will be used to identify a final corrective measure for implementation at the LEC.

References

1. AECOM 2014, Groundwater and Surface Water Data Demonstrate No Adverse Human Health Impact from Coal Ash Management at the Ameren Labadie Energy Center”
<https://www.ameren.com/company/environment-and-sustainability/managing-coal-combustion/water-quality>.
2. Golder Associates Inc. 2015. Labadie energy Center Groundwater Modeling Technical Memorandum.
3. Golder Associates Inc. 2017. 40 CFR Part 257 Groundwater Monitoring Plan, LCPA, Labadie Energy Center-Franklin County, Missouri, USA.
4. Golder Associates Inc. 2018. Technical Memorandum Assessment Monitoring Statistical Evaluation for the LCPA Surface Impoundment, Labadie Energy Center-Franklin County, Missouri.
5. Golder Associates Inc. 2018. 2017 Annual Groundwater Monitoring Report, LCPA, Labadie Energy Center-Franklin County, Missouri, USA.
6. Golder Associates Inc. 2019. 2018 Annual Groundwater Monitoring and Corrective Action Report, LCPA Surface Impoundment, Labadie Energy Center-Franklin County, Missouri, USA.
7. Golder Associates Inc. 2019. Technical Memorandum, Progress Update on LCPA Nature and Extent Investigation, Labadie Energy Center, Missouri.
8. Gredell Engineering Resources, Inc. and Reitz & Jens, Inc. 2011, Detailed Site Investigation Report, Proposed Utility Waste Disposal Area Franklin County, Missouri.
9. Gredell Engineering Resources, Inc. 2019, Ameren Missouri Labadie Energy Center Bottom Ash Pond Draft Groundwater Model Report.
10. Haley & Aldrich, Inc. 2018. Human Health and Ecological Assessment of the Labadie Energy Center
<https://www.ameren.com/company/environment-and-sustainability/managing-coal-combustion/water-quality>.
11. Kleinfelder 2016. Ground and Surface Water Assessment – Labadie Energy Center, June 17, 2016.
12. Lochmueller Group 2019. Extraction & Transportation Study: Rush Island Ash Pond Closure Assessment. Rush Island Site, Jefferson County, Missouri and Addendum, Meramec, Labadie and Sioux Ash Pond Closure Extraction & Transportation Assessment.
13. NAS. 2001. Dietary Reference Intakes for Vitamin A, Vitamin K, Arsenic, Boron, Chromium, Copper, Iodine, Iron, Manganese, Molybdenum, Nickel, Silicon, Vanadium, and Zinc. Institute of Medicine. National Academy of Sciences. 2001. National Academy Press. Available at:
<http://www.nap.edu/catalog/10026.html>.
14. USEPA. 1989. Risk Assessment Guidance for Superfund: Volume I. Human Health Evaluation Manual (Part A). Interim Final. Office of Emergency and Remedial Response. U.S. Environmental

Protection Agency, Washington, D.C. EPA 540/1-89/002. Available at:
<http://www.epa.gov/oswer/riskassessment/ragsa/>

15. USEPA. 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities – Unified Guidance.
16. USEPA. 2015. Frequent Questions about the 2015 Coal Ash Disposal Rule.
<https://www.epa.gov/coalash/frequent-questions-about-2015-coal-ash-disposal-rule>
17. USEPA. 2015a. Final Rule: Disposal of Coal Combustion Residuals (CCRs) for Electric Utilities. 80 FR 21301-21501. U.S. Environmental Protection Agency, Washington, D.C. Available at:
<https://www.govinfo.gov/content/pkg/FR-2015-04-17/pdf/2015-00257.pdf>.
18. USEPA. 2015b. Use of Monitored Natural Attenuation for Inorganic Contaminants in Groundwater at Superfund Sites.
19. USEPA. 2018a. USEPA Regional Screening Levels. November 2018, values for tapwater. U.S. Environmental Protection Agency. Available at: <https://www.epa.gov/risk/regional-screening-levels-rsls-generic-tables>

\\haleyaldrich.com\share\cle_common\Projects\132002 - Ameren Ash Pond Closure Assessment\006-Labadie\CMA Report\Final\2019-0520_Labadie Final CMA.docx

TABLES

TABLE I
GROUNDWATER ANALYTICAL RESULTS - APPENDIX IV CONSTITUENTS
CORRECTIVE MEASURES ASSESSMENT
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Monitoring Well ID	Date Sampled	Constituents													
		Antimony Total ug/L	Arsenic Total ug/L	Barium Total ug/L	Beryllium Total ug/L	Cadmium Total ug/L	Chromium Total ug/L	Cobalt Total ug/L	Fluoride Total mg/L	Lead Total ug/L	Lithium Total ug/L	Mercury Total ug/L	Molybdenum Total ug/L	Selenium Total ug/L	Thallium Total ug/L
		Site GWPS	6	42.6	2000	4	5	100	6	4	15	54.85	2	100	50
UMW-5D	3/23/2016	1 U	17.2	67.8	1 U	0.5 U	0.54 J	5 U	0.081 J	5 U	23.8	0.2 U	109	1 U	1 U
	5/5/2016	0.094 J	27.1	81.5	1 U	0.5 U	0.58 J	5 U	0.075 J	5.1	15.9	0.2 U	130	1 U	1 U
	7/13/2016	0.079 J	19.3	70.6	1 U	0.5 U	1 U	5 U	0.096 J	5 U	19	0.2 U	117	1 U	1 U
	9/9/2016	0.084 J	17.7	68.9	1 U	0.5 U	1 U	5 U	0.082 J	5 U	23.4	0.2 U	120	1 U	1 U
	11/14/2016	1 U	16.4	61.6	1 U	0.5 U	1 U	5 U	0.13 J	5 U	26.3	0.2 U	122	1 U	1 U
	1/17/2017	1 U	22.1	54.8	1 U	0.5 U	1 U	5 U	0.11 J	3.6 J	20.8	0.2 U	106	1 U	1 U
	3/2/2017	0.10 J	26.2	61.4	1 U	0.5 U	1 U	5 U	0.13 J	5 U	16.6	0.2 U	111	0.15 J	1 U
	6/1/2017	0.10 J	21	69.2	1 U	0.5 U	1 U	5 U	0.2 U	5 U	13.5	0.2 U	136	0.12 J	1 U
	4/9/2018	0.10 J	26	70.8	1 U	0.5 U	0.067 J	5 U	0.15 J	10 U	12.7	0.2 U	152	0.11 J	1 U
	5/22/2018		24.6	70.6					0.13 J		12.6		162		
11/8/2018		16.1	60					0.2 U		12.9		151			
UMW-6D	3/23/2016	0.11 J	1.8	129	1 U	0.5 U	0.54 J	5 U	0.12 J	5 U	10.1	0.2 U	668	1 U	1 U
	5/4/2016	1 U	5.7	139	1 U	0.5 U	0.80 J	5 U	0.14 J	3.2 J	7.8 J	0.2 U	634	0.20 J	1 U
	7/13/2016	1 U	9.6	123	1 U	0.5 U	1 U	5 U	0.14 J	5 U	6.5 J	0.2 U	674	1 U	1 U
	9/9/2016	1 U	16.6	127	1 U	0.5 U	0.56 J	5 U	0.12 J	5 U	6.6 J	0.2 U	596	0.28 J	1 U
	11/14/2016	1 U	12.9	129	1 U	0.5 U	1 U	5 U	0.15 J	3.6 J	7.0 J	0.2 U	554	0.33 J	1 U
	1/17/2017	1 U	15.2	141	1 U	0.052 J	1 U	5 U	0.11 J	5 U	5.9 J	0.2 U	504	0.22 J	1 U
	3/2/2017	1 U	14	150	1 U	0.5 U	1 U	5 U	0.14 J	5 U	7.4 J	0.2 U	496	0.26 J	1 U
	6/1/2017	1 U	12.8	145	1 U	0.5 U	1 U	5 U	0.11 J	5 U	5.8 J	0.2 U	548	0.21 J	0.092 J
	4/9/2018	1 U	9.4	152	1 U	0.034 J	0.079 J	5 U	0.17 J	10 U	6.9 J	0.2 U	564	0.26 J	1 U
	5/22/2018		8.7	137					0.15 J		5.0 J		534		
11/9/2018		15.4	114					0.2 U		5.2 J		591			
UMW-7D	3/23/2016	1 U	10.6	180	1 U	0.5 U	0.54 J	5 U	0.33	5 U	20.2	0.2 U	201	1 U	1 U
	5/4/2016	1 U	9.6	187	1 U	0.5 U	0.77 J	5 U	0.28	5 U	21	0.2 U	182	1 U	1 U
	7/11/2016	1 U	13.7	159	1 U	0.5 U	0.81 J	5 U	0.29	5 U	17.7	0.2 U	198	1 U	1 U
	9/12/2016	1 U	21.6	105	1 U	0.5 U	1 U	5 U	0.28	5 U	19.1	0.2 U	205	1 U	1 U
	11/14/2016	1 U	21.1	101	1 U	0.5 U	1 U	5 U	0.29	2.7 J	22.7	0.2 U	191	1 U	1 U
	1/18/2017	1 U	20.9	113	1 U	0.5 U	1 U	5 U	0.28	5 U	18.2	0.2 U	205	1 U	1 U
	3/2/2017	1 U	20.7	123	1 U	0.5 U	1 U	5 U	0.27	2.7 J	20.6	0.2 U	191	1 U	1 U
	6/1/2017	1 U	16.5	164	1 U	0.5 U	1 U	5 U	0.26	5 U	14.6	0.2 U	188	0.091 J	1 U
	4/9/2018	1 U	19.7	157	1 U	0.5 U	0.085 J	5 U	0.28	10 U	19.4	0.2 U	214	0.089 J	1 U
	5/22/2018		17.8	154					0.37		19.9		203		
11/7/2018		20.7	121					0.29		25		231			
UMW-8D	3/22/2016	1 U	27.9	454	1 U	0.5 U	0.48 J	5 U	0.14 J	5 U	34.6	0.2 U	14.8 J	1 U	1 U
	5/4/2016	1 U	28	458	1 U	0.5 U	0.62 J	0.79 J	0.15 J	5 U	34.8	0.2 U	9.5 J	1 U	1 U
	7/12/2016	1 U	31.2	448	1 U	0.5 U	1 U	5 U	0.16 J	5 U	32	0.2 U	13.6 J	1 U	1 U
	9/12/2016	1 U	31.8	497	1 U	0.5 U	1	5 U	0.15 J	5 U	31.2	0.2 U	14.5 J	1 U	1 U
	11/14/2016	1 U	32.5	481	1 U	0.5 U	1 U	5 U	0.20 J	3.9 J	31.7	0.2 U	11.7 J	1 U	1 U
	1/18/2017	1 U	32.8	492	1 U	0.5 U	1 U	5 U	0.19 J	5 U	30.7	0.2 U	14.5 J	1 U	1 U
	3/2/2017	1 U	35.4	482	1 U	0.5 U	1 U	5 U	0.17 J	4.4 J	32.4	0.2 U	12.2 J	1 U	1 U
	5/31/2017	1 U	27.6	465	1 U	0.5 U	1 U	5 U	0.15 J	5 U	26.4	0.2 U	11.5 J	1 U	1 U
	4/9/2018	1 U	27.9	452	1 U	0.5 U	0.064 J	5 U	0.23	10 U	30.9	0.2 U	11.0 J	0.087 J	1 U
	5/22/2018		29.5	449					0.22		31.8		10.7 J		
11/7/2018		24.3	446					0.23		31.4		15.5 J			
UMW-9D	3/22/2016	1 U	33.1	516	1 U	0.5 U	0.65 J	5 U	0.14 J	5 U	18.2	0.2 U	2.0 J	1 U	1 U
	5/4/2016	1 U	32.4	545	1 U	0.5 U	1.1	5 U	0.15 J	3.0 J	20.4	0.2 U	1.6 J	1 U	1 U
	7/12/2016	1 U	33.1	507	1 U	0.5 U	1 U	5 U	0.16 J	5 U	16.6	0.2 U	1.3 J	1 U	1 U
	9/9/2016	1 U	35.4	536	1 U	0.5 U	1 U	5 U	0.15 J	4.8 J	17.2	0.2 U	20 U	1 U	1 U
	11/14/2016	1 U	35.6	506	1 U	0.5 U	1 U	5 U	0.18 J	2.7 J	18.5	0.2 U	0.76 J	1 U	1 U
	1/18/2017	1 U	33.5	520	1 U	0.5 U	1 U	5 U	0.17 J	5 U	15.7	0.2 U	20 U	1 U	1 U
	3/2/2017	1 U	33.2	505	1 U	0.5 U	1 U	5 U	0.17 J	2.5 J	16.9	0.2 U	2.2 J	1 U	1 U
	5/31/2017	1 U	34.2	538	1 U	0.5 U	1 U	5 U	0.15 J	5 U	14	0.2 U	2.6 J	1 U	1 U
	4/9/2018	0.035 J	31.9	515	1 U	0.5 U	0.064 J	5 U	0.21	3.0 J	17.1	0.2 U	1.3 J	1 U	1 U
	5/22/2018		34	517					0.22		15.8		1.1 J		
11/7/2018		34.5	500					0.21		16.4		20 U			
AM-1D	11/9/2018	1 U	2.7	76.4	1 U	0.14 J	1 U	5 U	0.41	10 U	32.5	0.2 U	375	1 U	1 U
AM-1S	11/9/2018	1 U	4.5	539	1 U	0.5 U	1 U	5.6	0.27	10 U	37	0.2 U	3.6 J	1 U	1 U
TP-1D	11/8/2018	1 U	1 U	1420	1 U	0.5 U	0.26 J	5 U	0.2 U	10 U	26.4	0.2 U	20 U	1 U	1 U
TP-1M	11/8/2018	1 U	1 U	980	1 U	0.5 U	0.081 J	5 U	0.20 J	10 U	21.8	0.2 U	20 U	1 U	1 U
TP-1S	11/8/2018	1 U	12.8	355	1 U	0.5 U	0.10 J	5 U	0.2 U	10 U	14.3	0.2 U	4.5 J	1 U	1 U

TABLE I
GROUNDWATER ANALYTICAL RESULTS - APPENDIX IV CONSTITUENTS
CORRECTIVE MEASURES ASSESSMENT
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Monitoring Well ID	Date Sampled	Constituents													
		Antimony Total	Arsenic, Total	Barium Total	Beryllium Total	Cadmium Total	Chromium Total	Cobalt Total	Fluoride Total	Lead Total	Lithium Total	Mercury Total	Molybdenum Total	Selenium Total	Thallium Total
		ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	mg/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
	Site GWPS	6	42.6	2000	4	5	100	6	4	15	54.85	2	100	50	2
TP-2D	11/9/2018	1 U	5.9	112	1 U	0.057 J	1 U	5 U	0.43	3.2 J	42.7	0.2 U	125	1 U	1 U
TP-2M	11/9/2018	1 U	0.26 J	115	0.18 J	0.057 J	1 U	5 U	0.47	10 U	34.3	0.2 U	117	1 U	1 U
TP-2S	11/9/2018	1 U	11	315	1 U	0.080 J	1 U	5 U	0.31	10 U	39.7	0.2 U	43	1 U	1 U
TP-3D	11/8/2018	0.10 J	1.8	83.7	1 U	0.5 U	1 U	5 U	0.27	10 U	37.0 J	0.2 U	547	0.14 J	1 U
TP-3M	11/8/2018	1 U	1 U	238	1 U	0.5 U	1 U	5 U	0.22	10 U	26.9	0.2 U	355	1 U	1 U
TP-3S	11/8/2018	0.18 J	0.27 J	246	1 U	0.5 U	1 U	5 U	0.2 U	10 U	22.3	0.2 U	7.3 J	3.5	1 U
TP-4D	11/8/2018	0.097 J	5.2	418	1 U	0.5 U	1 U	5 U	0.2 U	3.6 J	26.1	0.2 U	1.8 J	0.091 J	1 U
TP-4M	11/8/2018	0.084 J	4.5	374	1 U	0.5 U	1 U	5 U	0.24	10 U	12.5	0.2 U	2.2 J	0.11 J	1 U
TP-4S	11/8/2018	0.12 J	24.2	302	1 U	0.5 U	1 U	5 U	0.23	10 U	18.2	0.2 U	20 U	0.19 J	1 U
TP-5D	11/8/2018	1 U	11.8	534	1 U	0.5 U	1 U	5 U	0.2 U	10 U	23.9	0.2 U	1.4 J	1 U	1 U
TP-5M	11/8/2018	1 U	0.72 J	888	1 U	0.5 U	1 U	5 U	0.2 U	3.4 J	26.5	0.2 U	0.98 J	1 U	1 U
TP-5S	11/8/2018	1 U	11.9	431	1 U	0.5 U	1 U	1.4 J	0.2 U	10 U	30.5	0.2 U	1.8 J	0.15 J	1 U

Notes:

102 Bold denotes concentration exceeding the GWPS

Blank cells - Constituent not included in this analysis.

mg/L - milligrams per liter.

ug/L - micrograms per liter.

GWPS - Groundwater Protection Standard.


Qualifiers:

J - Value is estimated.



U - Constituent was not detected, value is the reporting limit.

Site GWPS is either the MCL/Health Based GWPS or based on background levels (calculated as described in the Statistical Analysis Plan for Assessment Monitoring), whichever is higher. GWPS and background values calculated using baseline sampling results from monitoring wells BMW-1D and BMW-2D.

FIGURES




LEGEND

-  LCPA - BOTTOM ASH SURFACE IMPOUNDMENT
-  LABADIE ENERGY CENTER PROPERTY BOUNDARY

NOTES

1. ALL LOCATIONS AND BOUNDARIES ARE APPROXIMATE.
2. IMAGERY SOURCE: ESRI



**HALEY
ALDRICH**


CORRECTIVE MEASURES EVALUATION
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

SITE LOCATION MAP








MAY 2019

FIGURE 1-1

GIS FILE PATH: \\haleyaldrich.com\share\cde_common\Projects\132002 - Ameren Ash Pond Closure Assessment\006-Labadie\GIS\Maps\2019_05\132002_006_0002_SITE_FEATURES.mxd — USER: hwachholz — LAST SAVED: 5/9/2019 3:20:07 PM




LEGEND

-  LCPA BOTTOM ASH SURFACE IMPOUNDMENT MONITORING WELL
-  LABADIE CREEK
-  LABADIE ENERGY CENTER APPROXIMATE PROPERTY BOUNDARY
-  LCPA - BOTTOM ASH SURFACE IMPOUNDMENT
-  LCPB - FLY ASH SURFACE IMPOUNDMENT
-  LCL1 - UTILITY WASTE LANDFILL CELL 1
-  PROPOSED UTILITY WASTE LANDFILL FINAL FENCE PERIMETER

NOTES

1. ALL LOCATIONS AND BOUNDARIES ARE APPROXIMATE.
2. CCR - COAL COMBUSTION RESIDUALS.
3. AERIAL IMAGERY SOURCE: ESRI




CORRECTIVE MEASURES EVALUATION
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

SITE FEATURES

MAY 2019


FIGURE 1-2



LEGEND

- NATURE AND EXTENT MONITORING WELL
- LCPA BOTTOM ASH SURFACE IMPOUNDMENT MONITORING WELL
- LCL1 - UTILITY WASTE LANDFILL CELL 1
- LABADIE CREEK
- PROPOSED UTILITY WASTE LANDFILL FINAL FENCE PERIMETER
- LABADIE ENERGY CENTER APPROXIMATE PROPERTY BOUNDARY
- LCPA - BOTTOM ASH SURFACE IMPOUNDMENT
- LCPB - FLY ASH SURFACE IMPOUNDMENT
- MOLYBDENUM CONCENTRATION ABOVE THE GWPS (UMW-3D)
- MOLYBDENUM CONCENTRATION ABOVE THE GWPS (TP-2D)

- NOTES**
1. ALL LOCATIONS AND BOUNDARIES ARE APPROXIMATE.
 2. CCR - COAL COMBUSTION RESIDUALS.
 3. GWPS GROUNDWATER PROTECTION STANDARD
 4. AERIAL IMAGERY SOURCE: ESRI




HALEY ALDRICH CORRECTIVE MEASURES EVALUATION
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

MONITORING WELL LOCATIONS

MAY 2019

FIGURE 2-1




LEGEND

- Approximate Property Boundary
- LCPCB - Bottom Ash Surface
- LCPCB - Fly Ash Surface
- LCL1 - Utility Waste Landfill Cell 1
- NPDES Outfall Location

Surface Water Sampling Locations

- May 2018 Labadie Creek Sample
- May 2018 Missouri River Sample
- November 2014 Missouri River Sample
- October 2013 Labadie Creek Sample
- October 2013 Missouri River Sample
- Surface Water Flow Direction



- NOTES**
- ALL LOCATIONS AND BOUNDARIES ARE APPROXIMATE.
 - SAMPLE LOCATIONS BASED ON HANDHELD TRIMBLE GPS MEASUREMENTS. SAMPLE LOCATION REPRESENTS CENTERPOINT BETWEEN STARTING AND ENDING LOCATION.
 - NPDES - NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM.

REFERENCES

- ZAHNER AND ASSOCIATES, INC. 2016. LOT CONSOLIDATION PLAT OF "LABADIE ENERGY CENTER" - PREPARED FOR AMEREN MISSOURI. REVISED JUNE 15, 2016.

0 1,000 2,000 3,000 4,000 5,000 6,000 Feet

CLIENT
 AMEREN MISSOURI
 LABADIE ENERGY CENTER



PROJECT
 AMEREN HYDROGEOLOGICAL CONSULTING


TITLE
**SURFACE WATER SAMPLE LOCATIONS
 LABADIE ENERGY CENTER**


CONSULTANT		YYYY-MM-DD	2018-06-04
		PREPARED	JS
		DESIGN	JSI
		REVIEW	JSI
		APPROVED	MNH

PROJECT No. 130-1560 Rev. 0 **Figure 2-2**

Path: G:\Projects\130-1560 - Ameren Ash Ponds - MCB000 - FIGURES-DRAWINGS\PRODUCTION\Phase 0001 - Labadie\Aerial\Labadie May 2018 SW\LEC SW Sampling Locations.mxd

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM 11x17






LEGEND

- Labadie Energy Center Property Boundary
- LCPA - Bottom Ash Surface Impoundment

Groundwater Sampling Locations

- LCPA - Bottom Ash Surface Impoundment Monitoring Well
- Bedrock Aquifer Monitoring Well




NOTES

1. ALL LOCATIONS AND BOUNDARIES ARE APPROXIMATE.
2. GROUNDWATER MONITORING WELLS SURVEYED BY ZAHNER AND ASSOCIATES, INC.

REFERENCES

1. ZAHNER AND ASSOCIATES, INC. 2016. LOT CONSOLIDATION PLAT OF "LABADIE ENERGY CENTER" - PREPARED FOR AMEREN MISSOURI. REVISED JUNE 15, 2016.
2. COORDINATE SYSTEM: NAD 1983 STATEPLANE MISSOURI EAST FIPS 2,401 FEET.



CLIENT
 AMEREN MISSOURI
 LABADIE ENERGY CENTER



PROJECT
 GROUNDWATER MONITORING PROGRAM

TITLE
BEDROCK MONITORING WELL LOCATIONS

CONSULTANT	YYYY-MM-DD	2019-05-07
	PREPARED	JSI
	DESIGN	JSI
	REVIEW	EMS
	APPROVED	XXX

PROJECT No. 153-140601 PHASE 0001 **Figure 2-3**

Path: G:\Projects\153-1406 - Ameren GW Monitoring Program - MO\Phase 0001 - Labadie Energy\000 - FIGURE 2-DRAWINGS\PRODUCTION\CMA Presentation Documents\153-140601_Bedrock LCPA Wells_2019-05-07.mxd



IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 11in

FIGURE 4-1

REMEDIAL ALTERNATIVE ROADMAP


CORRECTIVE MEASURES ASSESSMENT

BOTTOM ASH SURFACE IMPOUNDMENT (LCPA)

LABADIE ENERGY CENTER - FRANKLIN COUNTY, MISSOURI

Alternative Number	Remedial Alternative Description	LCPA Closure Description	Groundwater Remedy Components		
			A. Groundwater Remedy Approach	B. Groundwater Treatment Method	C. Post-Closure Actions
1	Closure In Place (CIP) with Capping and Monitored Natural Attenuation (MNA)	CIP with Geomembrane and Soil Cap	<p>Natural Attenuation with Monitoring</p> <p>Mitigate off-site migration of groundwater with CCR constituents above GWPS through process of natural attenuation</p>	<p>No Active Treatment</p> <p>No active treatment technologies for groundwater to address CCR constituents</p>	<p>MNA</p> <p>Long-term groundwater monitoring to confirm reduction of CCR constituents</p>
3	CIP with Capping and In-Situ Groundwater Treatment	CIP with Geomembrane and Soil Cap	<p>Subsurface Treatment System</p> <p>Mitigate off-site migration of groundwater with CCR constituents above GWPS using in-situ amendments</p>	<p>In-Situ Treatment</p> <p>Subsurface treatment to reduce Appendix IV constituent concentrations in groundwater</p>	<p>In-Situ Treatment Long-Term</p> <p>Continue periodic in-situ treatment of groundwater to maintain reduction of CCR constituents in groundwater</p>
4	CIP with Capping and Hydraulic Containment through Groundwater Pumping and Ex-Situ Treatment	CIP with Geomembrane and Soil Cap	<p>Hydraulic Containment</p> <p>Mitigate off-site migration of groundwater with CCR constituents above GWPS using extraction wells</p>	<p>Ex-Situ Treatment</p> <p>Treatment system (ion exchange or reverse osmosis) to remove CCR constituents from groundwater</p>	<p>Pump & Treat Long-Term</p> <p>Operate groundwater treatment system long term to maintain reduction of CCR constituents in groundwater.</p>
5	Closure by Removal (CBR) with MNA	CBR	<p>Natural Attenuation with Monitoring</p> <p>Mitigate off-site migration of groundwater with CCR constituents above GWPS through process of natural attenuation</p>	<p>No Active Treatment</p> <p>No active treatment technologies for groundwater to address CCR constituents</p>	<p>MNA</p> <p>Long-term groundwater monitoring to confirm reduction of CCR constituents</p>

Figure 4-2
Modeled Molybdenum Concentrations After Capping and Closing the LCPA
Labadie Energy Center - Franklin County, Missouri



NOTES:

1. mg/L - Milligrams per liter.
2. GWPS - Groundwater Protection Standard.
3. Concentrations are representative of the intermediate zone of the alluvial aquifer at Alternative Source Demonstration Location L-ASD-5.

APPENDIX A

Surface Water Screening Tables

TABLES

1	HUMAN HEALTH SCREENING LEVELS
2	ECOLOGICAL SCREENING LEVELS - MISSOURI RIVER
3	ECOLOGICAL SCREENING LEVELS – LABADIE CREEK
4	SUMMARY OF SCREENING RESULTS
5a	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
5b	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
5c	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
5d	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
5e	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
5f	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
6a	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
6b	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
6c	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
6d	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS

Appendix A
Labadie Energy Center Surface Water Screening Tables – TOC

6e	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
6f	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER TO HUMAN HEALTH RECREATIONAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
7a	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
7b	COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
7c	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
7d	COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
7e	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS
7f	COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
8a	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS- TOTAL (UNFILTERED) SAMPLE RESULTS
8b	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
8c	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS- TOTAL (UNFILTERED) SAMPLE RESULTS
8d	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
9a	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVEL- TOTAL (UNFILTERED) SAMPLE RESULTS
9b	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVEL - DISSOLVED (FILTERED) SAMPLE RESULTS
9c	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVEL- TOTAL (UNFILTERED) SAMPLE RESULTS

Appendix A
Labadie Energy Center Surface Water Screening Tables – TOC

9d	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO HUMAN HEALTH RECREATIONAL SCREENING LEVEL - DISSOLVED (FILTERED) SAMPLE RESULTS
10a	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS- TOTAL (UNFILTERED) SAMPLE RESULTS
10b	COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
10c	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS- TOTAL (UNFILTERED) SAMPLE RESULTS
10d	COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
11	COMPARISON OF BLUFF AREA GROUNDWATER MONITORING RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS

TABLE 1
HUMAN HEALTH SCREENING LEVELS
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI

Constituent	CASRN	Drinking Water Screening Levels (mg/L)			Surface Water Screening Levels (mg/L)	
		MCLs (b)	SMCLs (b)	November 2018 USEPA Tapwater RSLs (c)	Drinking Water (d)	Recreational Use (a) (e)
Antimony	7440-36-0	0.006	NA	0.0078 (m)	0.006	0.64
Arsenic	7440-38-2	0.01	NA	0.000052	0.01	0.00014 (i)
Barium	7440-39-3	2	NA	3.8	2	NA
Beryllium	7440-41-7	0.004	NA	0.025	0.004	NA
Boron	7440-42-8	NA	NA	4	4	NA
Cadmium	7440-43-9	0.005	NA	0.0092	0.005	NA
Calcium	7440-70-2	NA	NA	NA	NA	NA
Chloride	7647-14-5	NA	250	NA	250	NA
Chromium	16065-83-1 (g)	0.1 (j)	NA	22 (n)	0.1	NA
Cobalt	7440-48-4	NA	NA	0.006	0.006	NA
Fluoride	16984-48-8	4	2	0.8	4	NA
Lead	7439-92-1	0.015 (k)	NA	0.015	0.015	NA
Lithium	7439-93-2	NA	NA	0.04	0.04	NA
Mercury	7487-94-7 (h)	0.002 (l)	NA	0.0057 (o)	0.002	NA
Molybdenum	7439-98-7	NA	NA	0.1	0.1	NA
Radium 226/228 (pCi/L)	RADIUM226228	5	NA	NA	5	NA
Selenium	7782-49-2	0.05	NA	0.1	0.05	4.2
Sulfate	7757-82-6	NA	250	NA	250	NA
Thallium	7440-28-0	0.002	NA	0.0002 (f)	0.002	0.00047
Total Dissolved Solids	TDS	NA	500	NA	500	NA
pH (std)	PHFLD	NA	6.5 - 8.5	NA	6.5 - 8.5	NA

Notes:

AWQC - Ambient Water Quality Criteria. NA - not available.

CASRN - Chemical Abstracts Service Registry Number.

GWPS - Groundwater Protection Standard. RSL - Risk-based Screening Levels (USEPA).

HI - Hazard Index (noncancer child). TR - Target Risk (carcinogenic).

MCL - Maximum Contaminant Level. USEPA - United States Environmental Protection Agency.

mg/L - milligram per liter.

(a) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<https://www.epa.gov/wqc/national-recommended-water-quality-criteria-human-health-criteria-table>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018.

<http://water.epa.gov/drink/contaminants/index.cfm>

(c) - USEPA Regional Screening Levels (November 2018). Values for tapwater.

http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm

(d) - Selected Drinking Water Screening Level uses the following hierarchy:

Federal USEPA MCL for Drinking Water.

Federal USEPA SMCL for Drinking Water.

Federal November 2018 USEPA Tapwater RSL.

(e) - The selected Human Health Recreational Use Screening Level is the Federal USEPA AWQC for Human Health Consumption of Organism Only.

(f) - RSL for Thallium (Soluble Salts) used for Thallium.

(g) - CAS number for Trivalent Chromium.

(h) - CAS number for Mercuric Chloride.

(i) - Value applies to inorganic form of arsenic only.

(j) - Value for Total Chromium.

(k) - Lead Treatment Technology Action Level is 0.015 mg/L.

(l) - Value for Inorganic Mercury.

(m) - RSL for Antimony (metallic) used for Antimony.

(n) - RSL for Chromium (III), Insoluble Salts used for Chromium.

(o) - RSL for Mercuric Chloride used for Mercury.

**TABLE 2
ECOLOGICAL SCREENING LEVELS - MISSOURI RIVER
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	CASRN	Federal Water Quality Criteria (mg/L)							
		Site-Specific USEPA Aquatic Life AWQC - 2018 Hardness Data Freshwater Acute (a)		Site-Specific USEPA Aquatic Life AWQC - 2018 Hardness Data Freshwater Chronic (a)		Site-Specific USEPA Aquatic Life AWQC - 2013 and 2014 Hardness Data Freshwater Acute (b)		Site-Specific USEPA Aquatic Life AWQC - 2013 and 2014 Hardness Data Freshwater Chronic (b)	
		Total	Dissolved	Total	Dissolved	Total	Dissolved	Total	Dissolved
Antimony	7440-36-0	NA	NA	NA	NA	NA	NA	NA	NA
Arsenic	7440-38-2	0.34	0.34	0.15	0.15	0.34	0.34	0.15	0.15
Barium	7440-39-3	NA	NA	NA	NA	NA	NA	NA	NA
Beryllium	7440-41-7	NA	NA	NA	NA	NA	NA	NA	NA
Boron	7440-42-8	NA	NA	NA	NA	NA	NA	NA	NA
Cadmium	7440-43-9	0.0058 (c)	0.0052 (d)	0.0020 (c)	0.0017 (d)	0.0053 (f)	0.0048 (g)	0.0018 (f)	0.0016 (g)
Calcium	7440-70-2	NA	NA	NA	NA	NA	NA	NA	NA
Chloride	16887-00-6	860	NA	230	NA	860	NA	230	NA
Chromium	7440-47-3	4.6 (e,c)	1.5 (e,d)	0.22 (e,c)	0.19 (e,d)	4.2 (e,f)	1.3 (e,g)	0.20 (e,f)	0.17 (e,g)
Cobalt	7440-48-4	NA	NA	NA	NA	NA	NA	NA	NA
Fluoride	16984-48-8	NA	NA	NA	NA	NA	NA	NA	NA
Lead	7439-92-1	0.35 (c)	0.22 (d)	0.014 (c)	0.0085 (d)	0.31 (f)	0.20 (g)	0.012 (f)	0.0077 (g)
Lithium	7439-93-2	NA	NA	NA	NA	NA	NA	NA	NA
Mercury	7439-97-6	0.0016	0.0014	0.00091	0.00077	0.0016	0.0014	0.00091	0.00077
Molybdenum	7439-98-7	NA	NA	NA	NA	NA	NA	NA	NA
Selenium	7782-49-2	NA	NA	3.1	NA	NA	NA	3.1	NA
Sulfate	14808-79-8	NA	NA	NA	NA	NA	NA	NA	NA
Thallium	7440-28-0	NA	NA	NA	NA	NA	NA	NA	NA
Total Dissolved Solids	TDS	NA	NA	NA	NA	NA	NA	NA	NA

Notes:

AWQC - USEPA Ambient Water Quality Criteria.

CASRN - Chemical Abstracts Service Registry Number.

CMC - Criterion Maximum Concentration.

(a) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness using hardness data collected in May 2018 - see note (c).

USEPA provides AWQC for both total and dissolved results.

(b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness using hardness data collected in November 2014 - see note (f).

USEPA provides AWQC for both total and dissolved results.

(c) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO₃ used.

(d) - Hardness dependent value for total metals adjusted for dissolved fraction. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO₃ used.

(e) - Value for trivalent chromium used.

(f) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO₃ used.

(g) - Hardness dependent value for total metals adjusted for dissolved fraction. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO₃ used.

**TABLE 3
ECOLOGICAL SCREENING LEVELS - LABADIE CREEK
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	CASRN	Federal Water Quality Criteria (mg/L)							
		Site-Specific USEPA Aquatic Life AWQC - 2018 Hardness Data Freshwater Acute (a)		Site-Specific USEPA Aquatic Life AWQC - 2018 Hardness Data Freshwater Chronic (a)		Site-Specific USEPA Aquatic Life AWQC - 2013 Hardness Data Freshwater Acute (b)		Site-Specific USEPA Aquatic Life AWQC - 2013 Hardness Data Freshwater Chronic (b)	
		Total	Dissolved	Total	Dissolved	Total	Dissolved	Total	Dissolved
Antimony	7440-36-0	NA	NA	NA	NA	NA	NA	NA	NA
Arsenic	7440-38-2	0.34	0.34	0.15	0.15	0.34	0.34	0.15	0.15
Barium	7440-39-3	NA	NA	NA	NA	NA	NA	NA	NA
Beryllium	7440-41-7	NA	NA	NA	NA	NA	NA	NA	NA
Boron	7440-42-8	NA	NA	NA	NA	NA	NA	NA	NA
Cadmium	7440-43-9	0.0043 (c)	0.0039 (d)	0.0015 (c)	0.0013 (d)	0.0050 (f)	0.0045 (g)	0.0017 (f)	0.0015 (g)
Calcium	7440-70-2	NA	NA	NA	NA	NA	NA	NA	NA
Chloride	16887-00-6	860	NA	230	NA	860	NA	230	NA
Chromium	7440-47-3	3.6 (e,c)	1.1 (e,d)	0.17 (e,c)	0.15 (e,d)	4.1 (e,f)	1.3 (e,g)	0.19 (e,f)	0.17 (e,g)
Cobalt	7440-48-4	NA	NA	NA	NA	NA	NA	NA	NA
Fluoride	16984-48-8	NA	NA	NA	NA	NA	NA	NA	NA
Lead	7439-92-1	0.24 (c)	0.16 (d)	0.0092 (c)	0.0062 (d)	0.29 (f)	0.19 (g)	0.011 (f)	0.0073 (g)
Lithium	7439-93-2	NA	NA	NA	NA	NA	NA	NA	NA
Mercury	7439-97-6	0.0016	0.0014	0.00091	0.00077	0.0016	0.0014	0.00091	0.00077
Molybdenum	7439-98-7	NA	NA	NA	NA	NA	NA	NA	NA
Selenium	7782-49-2	NA	NA	3.1	NA	NA	NA	3.1	NA
Sulfate	14808-79-8	NA	NA	NA	NA	NA	NA	NA	NA
Thallium	7440-28-0	NA	NA	NA	NA	NA	NA	NA	NA
Total Dissolved Solids	TDS	NA	NA	NA	NA	NA	NA	NA	NA

Notes:

AWQC - USEPA Ambient Water Quality Criteria.

CASRN - Chemical Abstracts Service Registry Number.

CMC - Criterion Maximum Concentration.

(a) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness using hardness data collected in May 2018 - see note (c).

USEPA provides AWQC for both total and dissolved results.

(b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness using hardness data collected in October 2013 - see note (f).

USEPA provides AWQC for both total and dissolved results.

(c) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Labadie Creek of 231 mg/L as CaCO₃ used.

(d) - Hardness dependent value for total metals adjusted for dissolved fraction. Site-specific total recoverable mean hardness value for the Labadie Creek of 231 mg/L as CaCO₃ used.

(e) - Value for trivalent chromium used.

(f) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Labadie Creek of 270 mg/L as CaCO₃ used.

(g) - Hardness dependent value for total metals adjusted for dissolved fraction. Site-specific total recoverable mean hardness value for the Labadie Creek of 270 mg/L as CaCO₃ used.

**TABLE 4
SUMMARY OF SCREENING RESULTS
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	Off-Site Bluff Area Wells - Drinking Water	Missouri River - Human Health Drinking Water										
		Dissolved					Total					
		Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream	Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream	
Antimony												
Arsenic												
Barium												
Beryllium												
Boron												
Cadmium												
Calcium												
Chloride												
Chromium												
Cobalt												
Fluoride												
Lead												
Lithium								4 : 5 80%			2 : 10 20%	
Mercury												
Molybdenum												
pH												
Selenium												
Sulfate												
Thallium												
TDS							7 : 10 70%	3 : 5 60%	8 : 10 80%	9 : 10 90%	9 : 10 90%	
Radium 226/228												

Notes:
Blank cells - no results above screening levels for the specified constituent / media.
Number of exceedences : total number of samples.

**TABLE 4
SUMMARY OF SCREENING RESULTS
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	Missouri River - Human Health Recreational									
	Dissolved					Total				
	Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream	Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream
Antimony										
Arsenic	15 : 15 100%	5 : 5 100%	15 : 15 100%	10 : 10 100%	10 : 10 100%	15 : 15 100%	5 : 5 100%	15 : 15 100%	10 : 10 100%	10 : 10 100%
Barium										
Beryllium										
Boron										
Cadmium										
Calcium										
Chloride										
Chromium										
Cobalt										
Fluoride										
Lead										
Lithium										
Mercury										
Molybdenum										
pH										
Selenium										
Sulfate										
Thallium										
TDS										
Radium 226/228										

Notes:
Blank cells - no results above screening levels for the specified constituent / media.
Number of exceedences : total number of samples.

**TABLE 4
SUMMARY OF SCREENING RESULTS
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	Missouri River - Ecological									
	Dissolved					Total				
	Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream	Upstream	Adjacent	Downstream	Further Downstream	Furthest Downstream
Antimony										
Arsenic										
Barium										
Beryllium										
Boron										
Cadmium										
Calcium										
Chloride										
Chromium										
Cobalt										
Fluoride										
Lead										
Lithium										
Mercury										
Molybdenum										
pH										
Selenium										
Sulfate										
Thallium										
TDS										
Radium 226/228										

Notes:
Blank cells - no results above screening levels for the specified constituent / media.
Number of exceedences : total number of samples.

**TABLE 4
SUMMARY OF SCREENING RESULTS
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Constituent	Labadie Creek - Human Health Drinking Water				Labadie Creek - Human Health Recreational				Labadie Creek - Ecological			
	Dissolved		Total		Dissolved		Total		Dissolved		Total	
	Upstream	Downstream	Upstream	Downstream	Upstream	Downstream	Upstream	Downstream	Upstream	Downstream	Upstream	Downstream
Antimony												
Arsenic					6 : 6 100%	6 : 6 100%	6 : 6 100%	6 : 6 100%				
Barium												
Beryllium												
Boron												
Cadmium												
Calcium												
Chloride												
Chromium												
Cobalt												
Fluoride												
Lead												
Lithium												
Mercury												
Molybdenum												
pH												
Selenium												
Sulfate												
Thallium												
TDS												
Radium 226/228												

Notes:
Blank cells - no results above screening levels for the specified constituent / media.
Number of exceedences : total number of samples.

TABLE 5a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006															
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.004	0.0041	0.0044	0.0044	0.0046	0.0042	0.0046	0.0046	0.0047	0.0045	0.0053	0.0041	0.0041	0.0045	0.0046
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.146	0.173	0.18	0.184	0.193	0.173	0.201	0.201	0.198	0.204	0.162	0.181	0.169	0.187	0.192
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004															
Boron	7440-42-8	mg/L	NA	NA	4	4	0.0787 J	0.0814 J	0.0824 J	0.0812 J	0.0836 J	0.085 J	0.0903 J	0.0885 J	0.0898 J	0.0916 J	0.0818 J	0.0829 J	0.0813 J	0.0849 J	0.0833 J
Cadmium	7440-43-9	mg/L	0.005	NA	0.0092	0.005						0.00059 J							0.00054 J		
Calcium (f)	7440-70-2	mg/L	NA	NA	NA	NA	74.1	75.1	76.8	76.2	79	72.8	77	77.2	78.6	77.8	75.4	76.7	75.9	79.6	78.9
Chloride	16887-00-6	mg/L	NA	NA	250	250	22.5	22.8	22.7	23.5	23.9	23.8	24	24.5	25.1	25.2	22.6	22.8	22.6	23.6	23.3
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1	0.0024 J	0.005	0.007	0.0064	0.0068	0.0052	0.0071	0.0076	0.0059	0.0075	0.0033 J	0.0067	0.0048 J	0.0061	0.0068
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006	0.002 J	0.0029 J	0.0034 J	0.0037 J	0.0039 J	0.0028 J	0.0038 J	0.0044 J	0.0035 J	0.0033 J	0.0028 J	0.0028 J	0.0028 J	0.0028 J	0.0032 J
Fluoride	16984-48-8	mg/L	4	2	0.8	4	0.36	0.37	0.36	0.38	0.37	0.39	0.42	0.4	0.41	0.37	0.36	0.36	0.36	0.37	0.38
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015	0.0052 J	0.0046 J	0.004 J	0.0046 J	0.0057 J	0.0051 J	0.006 J	0.006 J	0.0054 J	0.0034 J	0.0034 J	0.0057 J	0.0079 J	0.0079 J	0.0038 J
Lithium	7439-93-2	mg/L	NA	NA	0.04	0.04	0.0354	0.0353	0.0379	0.038	0.0396	0.0379	0.0408	0.0403	0.0414	0.0428	0.0357	0.0377	0.0366	0.0386	0.0398
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002															
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0022 J	0.0026 J	0.003 J	0.0025 J	0.003 J	0.0021 J	0.0024 J	0.002 J	0.002 J	0.0026 J	0.0026 J	0.0026 J	0.0027 J	0.0029 J	0.0028 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0074 J	0.007 J	0.0077 J	0.0076 J											
Sulfate	14808-79-8	mg/L	NA	250	NA	250	176	178	177	183	180	172	173	174	179	180	175	178	179	185	186
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002															
Total Hardness as CaCO3 (f)	471-34-1	mg/L	NA	NA	NA	NA	301	304	310	308	319	302	316	316	319	319	304	311	307	320	318
Total Dissolved Solids	TDS	mg/L	NA	500	NA	500	506	507	491	491	488	479	505	506	517	523	500	505	509	519	522

Notes:
 Blank cells - Non-detect value. mg/L - milligrams per liter.
 * - Constituent was not detected in any samples. NA - Not Available.
 CAS - Chemical Abstracts Service. RSL - Regional Screening Level.
 J - Estimated value. SMCL - Secondary Maximum Contaminant Level.
 MCL - Maximum Contaminant Level. USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River Further Downstream					Missouri River Furthest Downstream					
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS	
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006											
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0039	0.0041	0.0042	0.0045	0.0044	0.0034	0.0046	0.0043	0.0044	0.0045	0.0045
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.17	0.163	0.158	0.18	0.194	0.128	0.178	0.19	0.188	0.174	0.174
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004											
Boron	7440-42-8	mg/L	NA	NA	4	4	0.0825 J	0.0825 J	0.0818 J	0.0873 J	0.0854 J	0.0814 J	0.0879 J	0.0869 J	0.0875 J	0.0899 J	0.0899 J
Cadmium	7440-43-9	mg/L	0.005	NA	0.0092	0.005	0.0005 J										
Calcium (f)	7440-70-2	mg/L	NA	NA	NA	NA	76.6	76	78.5	75.7	79.8	72.5	78.6	80.2	78.9	82.6	82.6
Chloride	16887-00-6	mg/L	NA	250	NA	250	22.8	22.4	22.7	23	22.9	22.5	23	23	23.5	23.8	23.8
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1	0.0051	0.0042 J	0.0023 J	0.0054	0.0066	0.0016 J	0.0047 J	0.0073	0.0064	0.0048 J	0.0048 J
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006	0.0024 J	0.0027 J	0.0024 J	0.0029 J	0.0037 J	0.0013 J	0.0036 J	0.0036 J	0.0033 J	0.0024 J	0.0024 J
Fluoride	16984-48-8	mg/L	4	2	0.8	4	0.36	0.36	0.36	0.37	0.37	0.36	0.37	0.37	0.37	0.39	0.39
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015	0.0034 J	0.0034 J	0.0043 J	0.0051 J	0.005 J	0.003 J	0.003 J	0.0048 J	0.0046 J	0.0057 J	0.0057 J
Lithium	7439-93-2	mg/L	NA	NA	0.04	0.04	0.0368	0.0349	0.036	0.0412	0.0415	0.0342	0.039	0.0396	0.0379	0.04	0.04
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002											
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0028 J	0.0023 J	0.0023 J	0.0021 J	0.0028 J	0.0024 J	0.0029 J	0.0028 J	0.0029 J	0.0025 J	0.0025 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0088 J					0.0102 J	0.0065 J	0.0089 J	0.0063 J	0.0063 J	0.0063 J
Sulfate	14808-79-8	mg/L	NA	250	NA	250	175	178	178	181	179	176	180	181	187	187	187
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002											
Total Hardness as CaCO3 (f)	471-34-1	mg/L	NA	NA	NA	NA	310	307	315	308	323	296	317	325	319	331	331
Total Dissolved Solids	TDS	mg/L	NA	500	NA	500	492	519	486	517	508	481	512	513	525	519	519

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 MCL - Maximum Contaminant Level.

mg/L - milligrams per liter.
 NA - Not Available.
 RSL - Regional Screening Level.
 SMCL - Secondary Maximum Contaminant Level.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
(a) AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006															
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0031	0.003	0.003	0.003	0.0029	0.0029	0.0029	0.0032	0.003	0.0029	0.003	0.003	0.0029	0.0032	0.003
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.111	0.108	0.11	0.111	0.111	0.109	0.106	0.108	0.103	0.111	0.107	0.109	0.103	0.113	0.109
Beryllium	7440-41-7	mg/L	0.004	NA	0.025	0.004						0.00017 J									
Boron	7440-42-8	mg/L	NA	NA	4	4	0.081 J	0.0806 J	0.0785 J	0.0846 J	0.0837 J	0.0817 J	0.0798 J	0.0777 J	0.0765 J	0.0805 J	0.079 J	0.0859 J	0.078 J	0.0842 J	0.0836 J
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005															
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	71.7	71.5	71.1	72.2	73	70.5	69.3	70.4	67.4	71.5	68.5	72	68.1	72.4	71
Chromium*	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1															
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006							0.00099 J								
Lead*	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015															
Lithium	7439-93-2	mg/L	NA	NA	0.04	0.04	0.0328	0.0334	0.0361	0.0357	0.036	0.038	0.0348	0.0371	0.0355	0.0362	0.0331	0.0335	0.0314	0.0359	0.0351
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002															
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0026 J	0.0029 J	0.0029 J	0.0031 J	0.0026 J	0.0028 J	0.0025 J	0.0024 J	0.0029 J	0.003 J	0.0028 J	0.0027 J	0.003 J	0.0026 J	
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0069 J	0.007 J	0.0103 J												
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002															

Notes:
 Blank cells - Non-detect value. mg/L - milligrams per liter.
 * - Constituent was not detected in any samples. NA - Not Available.
 CAS - Chemical Abstracts Service. RSL - Regional Screening Level.
 J - Estimated value. SMCL - Secondary Maximum Contaminant Level.
 MCL - Maximum Contaminant Level. USEPA - United States Environmental Protection Agency.

 Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS
(a) AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River Further Downstream					Missouri River Furthest Downstream						
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS		
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006												
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0027	0.0028	0.0028	0.003	0.003	0.0028	0.003	0.0028	0.0028	0.0028	0.003	0.003
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.107	0.112	0.112	0.109	0.11	0.114	0.107	0.105	0.112	0.114		
Beryllium	7440-41-7	mg/L	0.004	NA	0.025	0.004												
Boron	7440-42-8	mg/L	NA	NA	4	4	0.0793 J	0.0838 J	0.0812 J	0.0777 J	0.0828 J	0.0825 J	0.082 J	0.0798 J	0.0849 J	0.0869 J		
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005												
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	68.8	72.4	71.4	71	69.4	73.2	68.6	67.6	72.7	73.5		
Chromium*	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1												
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006												
Lead*	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015												
Lithium	7439-93-2	mg/L	NA	NA	0.04	0.04	0.035	0.0385	0.0354	0.0366	0.0328	0.0368	0.0344	0.0341	0.0363	0.0378		
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002												
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0028 J	0.0029 J	0.0026 J	0.0021 J	0.0026 J	0.0027 J	0.0028 J	0.0031 J	0.003 J	0.0031 J		
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05												
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002												

Notes:
Blank cells - Non-detect value. mg/L - milligrams per liter.
* - Constituent was not detected in any samples. NA - Not Available.
CAS - Chemical Abstracts Service. RSL - Regional Screening Level.
J - Estimated value. SMCL - Secondary Maximum Contaminant Level.
MCL - Maximum Contaminant Level. USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018.
<http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater.
http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
Federal USEPA MCL for Drinking Water.
Federal USEPA SMCL for Drinking Water.
Federal November 2018 USEPA Tapwater RSL.

TABLE 5c
 COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO
 HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
 AMEREN MISSOURI LABADIE ENERGY CENTER
 FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River River Upstream					Missouri River River Downstream					Missouri River River Further Downstream					Missouri River River Furthest Downstream				
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4AS Total	LBD-R-5AS Total	LBD-R-6AS Total	LBD-R-6AS Total	LBD-R-6AM Total	LBD-R-1AS Total	LBD-R-2AS Total	LBD-R-2AM Total	LBD-R-3AS Total	LBD-R-3AM Total	LBD-R-10S Total	LBD-R-11S Total	LBD-R-11M Total	LBD-R-12S Total	LBD-R-12M Total	LBD-R-7S Total	LBD-R-8S Total	LBD-R-8M Total	LBD-R-9S Total	LBD-R-9M Total
			Antimony*	7440-36-0	mg/L		0.006	NA	0.0078	0.006																
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0033	0.0032	0.0035	0.003	0.0031	0.0038	0.0032	0.0034	0.0034	0.0028	0.0037	0.0033	0.0032	0.0035	0.0035	0.0046	0.0034	0.0034	0.0035	0.0037
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.124	0.131	0.128	0.132	0.118	0.134	0.124	0.129	0.13	0.131	0.135	0.132	0.13	0.129	0.127	0.17	0.13	0.13	0.135	0.135
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004																				
Boron	7440-42-8	mg/L	NA	NA	4	4	0.111	0.112	0.109	0.111	0.109	0.115	0.111	0.113	0.11	0.11	0.111	0.11	0.111	0.11	0.111	0.115	0.111	0.11	0.111	0.109
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005																				
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	69.9	71.7	70.7	70	66.2	70.7	69.2	70.8	70.2	71.4	70.5	69.5	69.5	69.4	70.2	71.6	70.1	69.6	70.8	70.2
Chloride	16887-00-6	mg/L	NA	250	NA	250	19.5	20.2	20.1	20.9	18.6	20.5	20.4	19.9	18.6	20.8	18.8	20.4	20.5	20.9	18.7	16.6	18.5	18.4	17.7	19.4
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1	0.0015 J	0.0025 J	0.0016 J	0.0019 J	0.0023 J	0.0024 J	0.0019 J	0.0016 J	0.0019 J	0.0023 J	0.0025 J	0.0024 J	0.0018 J	0.002 J	0.0018 J	0.0056 J	0.0017 J	0.0018 J	0.003 J	0.0019 J
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006																				
Fluoride	16984-48-8	mg/L	4	2	0.8	4	0.52	0.55	0.52	0.55	0.52	0.54	0.55	0.52	0.5 J	0.57	0.0012 J	0.001 J	0.5	0.53	0.54	0.5 J	0.37 J	0.001 J	0.0011 J	0.31 J
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015	0.00056 J	0.00076 J	0.00072 J	0.0011	0.0011	0.001	0.00062 J	0.00068 J	0.00088 J	0.00098 J	0.0013	0.0012	0.001	0.00088 J	0.00077 J	0.0033	0.0011	0.0011	0.0013	0.0015
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002																				
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0033 J	0.0031 J	0.0028 J	0.0036 J	0.0029 J	0.0035 J	0.0035 J	0.0031 J	0.0031 J	0.0029 J	0.0036 J	0.0033 J	0.0031 J	0.0034 J	0.0032 J	0.0062 J	0.0038 J	0.003 J	0.003 J	0.0032 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0015 J	0.0017 J	0.0018 J	0.0018 J	0.0017 J	0.0015 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J	0.0018 J	0.0017 J	0.0017 J	0.0017 J	0.0019 J	0.0019 J	0.0019 J	0.0017 J	0.0017 J	
Sulfate	14808-79-8	mg/L	NA	250	NA	250	209	210	203	212	210	209	210	213	208	205	215	210	210	213	211	208	210	224	206	211
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002																				
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	284,000	291,000	287,000	285,000	268,000	287,000	281,000	287,000	285,000	289,000	286,000	282,000	283,000	283,000	285,000	291,000	285,000	283,000	287,000	284,000
Total Dissolved Solids	TDS	mg/L	NA	500	NA	500	539	553	548	550	544	532	541	531	540	541	550	543	546	516	555	524	538	551	547	551

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 CAS - Chemical Abstracts Service.
 J - Value is estimated.
 MCL - Maximum Contaminant Level.
 mg/L - milligrams per liter.
 NA - Not Available.
 RSL - Regional Screening Level.
 SMCL - Secondary Maximum Contaminant Level.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5d
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO
HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River River Upstream					Missouri River River Downstream					Missouri River River Further Downstream					Missouri River River Furthest Downstream				
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4AS Filtered	LBD-R-5AS Filtered	LBD-R-5AM Filtered	LBD-R-6AS Filtered	LBD-R-6AM Filtered	LBD-R-1AS Filtered	LBD-R-2AS Filtered	LBD-R-2AM Filtered	LBD-R-3AS Filtered	LBD-R-3AM Filtered	LBD-R-10S Filtered	LBD-R-11S Filtered	LBD-R-11M Filtered	LBD-R-12S Filtered	LBD-R-12M Filtered	LBD-R-7S Filtered	LBD-R-8S Filtered	LBD-R-8M Filtered	LBD-R-9S Filtered	LBD-R-9M Filtered
			Antimony*	7440-36-0	mg/L		0.006	NA	0.0078	0.006																
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0024	0.0027	0.0023	0.0026	0.0026	0.0028	0.0024	0.0022	0.0026	0.0026	0.0026	0.0027	0.0025	0.0026	0.0023	0.0027	0.0028	0.0026	0.0025	0.0027
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.111	0.108	0.11	0.11	0.0999	0.111	0.113	0.11	0.109	0.109	0.112	0.111	0.111	0.11	0.109	0.113	0.111	0.111	0.109	0.111
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004																				
Boron	7440-42-8	mg/L	NA	NA	4	4	0.109	0.107	0.108	0.108	0.103	0.113	0.113	0.111	0.108	0.11	0.11	0.109	0.11	0.109	0.11	0.11	0.108	0.108	0.105	0.108
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005																				
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	70.2	67.8	68.7	67.8	62.5	70.7	69.8	69.4	68.6	69.4	68.6	68.4	68.5	69.4	69.2	69	67.8	68.7	68.7	69.1
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1																				
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006																				
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015																				
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002																				
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0036 J	0.0038 J	0.0037 J	0.0041 J	0.0027 J	0.0031 J	0.0035 J	0.0036 J	0.0034 J	0.0037 J	0.0037 J	0.004 J	0.0048 J	0.004 J	0.0034 J	0.0059 J	0.0038 J	0.004 J	0.0035 J	0.0036 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0016 J	0.0017 J	0.0017 J	0.0018 J	0.0016 J	0.0015 J	0.0017 J	0.0016 J	0.0015 J	0.0016 J	0.0015 J	0.0016 J	0.0017 J	0.0015 J	0.0017 J	0.0016 J	0.0017 J	0.0015 J	0.0017 J	
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002																				

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 CAS - Chemical Abstracts Service.
 J - Value is estimated.
 MCL - Maximum Contaminant Level.
 mg/L - milligrams per liter.
 NA - Not Available.
 RSL - Regional Screening Level.
 SMCL - Secondary Maximum Contaminant Level.
 USEPA - United States Environmental Protection Agency.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018.
<http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater.
http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5e
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River River Upstream					Missouri River River Downstream						
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4S Total	LBD-R-5S Total	LBD-R-5M Total	LBD-R-6S Total	LBD-R-6M Total	LBD-R-1S Total	LBD-R-2S Total	LBD-R-2M Total	LBD-R-3S Total	LBD-R-3M Total		
			Antimony*	7440-36-0	mg/L		0.006	NA	0.0078	0.006								
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.005	0.005	0.0048	0.0047	0.0047	0.0044	0.0045	0.0047	0.0048	0.0048	0.0049	
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.113	0.119	0.12	0.123	0.119	0.113	0.122	0.123	0.123	0.124		
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004												
Boron	7440-42-8	mg/L	NA	NA	4	4	0.111	0.114	0.114	0.115	0.113	0.12	0.121	0.123	0.118	0.119		
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005												
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	62.3	63.5	63.4	65.1	64.5	63.8	64.7	63.6	64.2	65.5		
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1	0.0022 J	0.0026 J	0.0029 J	0.0031 J	0.0023 J	0.0023 J	0.0027 J	0.0031 J	0.0029 J	0.0032 J		
Cobalt*	7440-48-4	mg/L	NA	NA	0.006	0.006												
Fluoride	16984-48-8	mg/L	4	2	0.8	4	0.41 J	0.48 J	0.45 J	0.51 J	0.44 J	0.5 J	0.47 J	0.48 J	0.47 J	0.43 J		
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015	0.0015	0.0018	0.0018	0.0019	0.0019	0.0015	0.0018	0.0018	0.0019	0.0019		
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002												
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.004 J	0.0044 J	0.0042 J	0.0043 J	0.0041 J	0.0044 J	0.0044 J	0.0044 J	0.0044 J	0.0041 J		
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0016 J	0.0018 J	0.0016 J	0.0017 J	0.0018 J	0.0017 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J		
Sulfate	14808-79-8	mg/L	NA	250	NA	250	194	194	193	194	197	174	187	193	189	192		
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002												
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	249	254	253	260	257	255	258	254	256	261		

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 -- - Constituent not included in this analysis.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 MCL - Maximum Contaminant Level.
 mg/L - milligrams per liter.
 NA - Not Available.
 RSL - Regional Screening Level.
 SMCL - Secondary Maximum Contaminant Level.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in October 2013.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 5f
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Missouri River River Upstream					Missouri River River Downstream					
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-R-4S Filtered	LBD-R-5S Filtered	LBD-R-5M Filtered	LBD-R-6S Filtered	LBD-R-6M Filtered	LBD-R-1S Filtered	LBD-R-2S Filtered	LBD-R-2M Filtered	LBD-R-3S Filtered	LBD-R-3M Filtered	
			Antimony*	7440-36-0	mg/L		0.006	NA	0.0078	0.006							
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0035	0.0035	0.0038	0.0037	0.0034	0.004	0.0037	0.0036	0.0033	0.0035	0.0035
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.0928	0.0906	0.0917	0.0907	0.0886	0.0936	0.0912	0.0914	0.0915	0.0938	0.0938
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004											
Boron	7440-42-8	mg/L	NA	NA	4	4	0.12	0.115	0.118	0.115	0.113	0.123	0.122	0.123	0.116	0.119	0.119
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005											
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	--	--	--	--	--	--	--	--	--	--	--
Chromium*	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1											
Cobalt*	7440-48-4	mg/L	NA	NA	0.006	0.006											
Fluoride	16984-48-8	mg/L	4	2	0.8	4	--	--	--	--	--	--	--	--	--	--	--
Lead*	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015											
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002											
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0035 J	0.0035 J	0.0041 J	0.0038 J	0.0036 J	0.0042 J	0.0039 J	0.0042 J	0.0036 J	0.0037 J	0.0037 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05	0.0016 J	0.0015 J	0.0015 J	0.0016 J	0.0014 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J
Sulfate	14808-79-8	mg/L	NA	250	NA	250	--	--	--	--	--	--	--	--	--	--	--
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002											
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	--	--	--	--	--	--	--	--	--	--	--

Notes:
Blank cells - Non-detect value. mg/L - milligrams per liter.
* Constituent was not detected in any samples. NA - Not Available.
-- - Constituent not included in this analysis. RSL - Regional Screening Level.
CAS - Chemical Abstracts Service. SMCL - Secondary Maximum Contaminant Level.
J - Estimated value. USEPA - United States Environmental Protection Agency.
MCL - Maximum Contaminant Level.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in October 2013.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (f) - Screening levels from the presented sources are not available for this constituent.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
Federal USEPA MCL for Drinking Water.
Federal USEPA SMCL for Drinking Water.
Federal November 2018 USEPA Tapwater RSL.

TABLE 6a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			AWQC (b)	LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	0.64															
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.004	0.0041	0.0044	0.0044	0.0046	0.0042	0.0046	0.0046	0.0047	0.0045	0.0053	0.0041	0.0041	0.0045	0.0046
Barium	7440-39-3	mg/L	NA	0.146	0.173	0.18	0.184	0.193	0.173	0.201	0.201	0.198	0.204	0.162	0.181	0.169	0.187	0.192
Beryllium*	7440-41-7	mg/L	NA															
Boron	7440-42-8	mg/L	NA	0.0787 J	0.0814 J	0.0824 J	0.0812 J	0.0836 J	0.085 J	0.0903 J	0.0885 J	0.0898 J	0.0916 J	0.0818 J	0.0829 J	0.0813 J	0.0849 J	0.0833 J
Cadmium	7440-43-9	mg/L	NA						0.00059 J							0.00054 J		
Calcium	7440-70-2	mg/L	NA	74.1	75.1	76.8	76.2	79	72.8	77	77.2	78.6	77.8	75.4	76.7	75.9	79.6	78.9
Chloride	16887-00-6	mg/L	NA	22.5	22.8	22.7	23.5	23.9	23.8	24	24.5	25.1	25.2	22.6	22.8	22.6	23.6	23.3
Chromium	7440-47-3	mg/L	NA	0.0024 J	0.005	0.007	0.0064	0.0068	0.0052	0.0071	0.0076	0.0059	0.0075	0.0033 J	0.0067	0.0048 J	0.0061	0.0068
Cobalt	7440-48-4	mg/L	NA	0.002 J	0.0029 J	0.0034 J	0.0037 J	0.0039 J	0.0028 J	0.0038 J	0.0044 J	0.0035 J	0.0033 J	0.0028 J	0.0028 J	0.0028 J	0.0028 J	0.0032 J
Fluoride	16984-48-8	mg/L	NA	0.36	0.37	0.36	0.38	0.37	0.39	0.42	0.4	0.41	0.41	0.37	0.36	0.36	0.37	0.38
Lead	7439-92-1	mg/L	NA	0.0052 J	0.0046 J	0.004 J	0.0046 J	0.0057 J	0.0051 J	0.006 J	0.006 J	0.0054 J	0.0034 J	0.0034 J	0.0057 J	0.0079 J	0.0038 J	0.0038 J
Lithium	7439-93-2	mg/L	NA	0.0354	0.0353	0.0379	0.038	0.0396	0.0379	0.0408	0.0403	0.0414	0.0428	0.0357	0.0377	0.0366	0.0386	0.0398
Mercury*	7439-97-6	mg/L	NA															
Molybdenum	7439-98-7	mg/L	NA	0.0022 J	0.0026 J	0.003 J	0.0025 J	0.003 J	0.0021 J	0.0024 J	0.002 J	0.002 J	0.0026 J	0.0026 J	0.0026 J	0.0027 J	0.0029 J	0.0028 J
Selenium	7782-49-2	mg/L	4.2	0.0074 J	0.007 J	0.0077 J	0.0076 J							0.009 J				
Sulfate	14808-79-8	mg/L	NA	176	178	177	183	180	172	173	174	179	180	175	178	179	185	186
Thallium*	7440-28-0	mg/L	0.00047															
Total Hardness as CaCO3	471-34-1	mg/L	NA	301	304	310	308	319	302	316	316	319	319	304	311	307	320	318
Total Dissolved Solids	TDS	mg/L	NA	506	507	491	491	488	479	505	506	517	523	500	505	509	519	522

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples.
 AWQC - Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > AWQC.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 USEPA AWQC Human Health for the Consumption of Organism Only
 apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 6a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Missouri River Further Downstream					Missouri River Furthest Downstream					
			AWQC (b)	LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS	
Antimony*	7440-36-0	mg/L	0.64											
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0039	0.0041	0.0042	0.0045	0.0044	0.0034	0.0046	0.0043	0.0044	0.0045	
Barium	7440-39-3	mg/L	NA	0.17	0.163	0.158	0.18	0.194	0.128	0.178	0.19	0.188	0.174	
Beryllium*	7440-41-7	mg/L	NA											
Boron	7440-42-8	mg/L	NA	0.0825 J	0.0825 J	0.0818 J	0.0873 J	0.0854 J	0.0814 J	0.0879 J	0.0869 J	0.0875 J	0.0899 J	
Cadmium	7440-43-9	mg/L	NA	0.0005 J										
Calcium	7440-70-2	mg/L	NA	76.6	76	78.5	75.7	79.8	72.5	78.6	80.2	78.9	82.6	
Chloride	16887-00-6	mg/L	NA	22.8	22.4	22.7	23	22.9	22.5	23	23	23.5	23.8	
Chromium	7440-47-3	mg/L	NA	0.0051	0.0042 J	0.0023 J	0.0054	0.0066	0.0016 J	0.0047 J	0.0073	0.0064	0.0048 J	
Cobalt	7440-48-4	mg/L	NA	0.0024 J	0.0027 J	0.0024 J	0.0029 J	0.0037 J	0.0013 J	0.0036 J	0.0036 J	0.0033 J	0.0024 J	
Fluoride	16984-48-8	mg/L	NA	0.36	0.36	0.36	0.37	0.37	0.36	0.37	0.37	0.37	0.39	
Lead	7439-92-1	mg/L	NA	0.0034 J	0.0034 J	0.0043 J	0.0051 J	0.005 J	0.003 J	0.0048 J	0.0046 J	0.0046 J	0.0057 J	
Lithium	7439-93-2	mg/L	NA	0.0368	0.0349	0.036	0.0412	0.0415	0.0342	0.039	0.0396	0.0379	0.04	
Mercury*	7439-97-6	mg/L	NA											
Molybdenum	7439-98-7	mg/L	NA	0.0028 J	0.0023 J	0.0023 J	0.0021 J	0.0028 J	0.0024 J	0.0029 J	0.0028 J	0.0029 J	0.0025 J	
Selenium	7782-49-2	mg/L	4.2	0.0088 J						0.0102 J	0.0065 J	0.0089 J	0.0063 J	
Sulfate	14808-79-8	mg/L	NA	175	178	178	181	179	176	180	181	187	187	
Thallium*	7440-28-0	mg/L	0.00047											
Total Hardness as CaCO3	471-34-1	mg/L	NA	310	307	315	308	323	296	317	325	319	331	
Total Dissolved Solids	TDS	mg/L	NA	492	519	486	517	508	481	512	513	525	519	

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples.
 AWQC - Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > AWQC.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 USEPA AWQC Human Health for the Consumption of Organism Only
 apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 6b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS -
DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			AWQC (b)	LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	0.64															
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0031	0.003	0.003	0.003	0.0029	0.0029	0.0029	0.0032	0.003	0.0029	0.003	0.003	0.0029	0.0032	0.003
Barium	7440-39-3	mg/L	NA	0.111	0.108	0.11	0.111	0.111	0.109	0.106	0.108	0.103	0.111	0.107	0.109	0.103	0.113	0.109
Beryllium	7440-41-7	mg/L	NA						0.00017 J									
Boron	7440-42-8	mg/L	NA	0.081 J	0.0806 J	0.0785 J	0.0846 J	0.0837 J	0.0817 J	0.0798 J	0.0777 J	0.0765 J	0.0805 J	0.079 J	0.0859 J	0.078 J	0.0842 J	0.0836 J
Cadmium*	7440-43-9	mg/L	NA															
Calcium	7440-70-2	mg/L	NA	71.7	71.5	71.1	72.2	73	70.5	69.3	70.4	67.4	71.5	68.5	72	68.1	72.4	71
Chromium*	7440-47-3	mg/L	NA															
Cobalt	7440-48-4	mg/L	NA							0.00099 J								
Lead*	7439-92-1	mg/L	NA															
Lithium	7439-93-2	mg/L	NA	0.0328	0.0334	0.0361	0.0357	0.036	0.038	0.0348	0.0371	0.0355	0.0362	0.0331	0.0335	0.0314	0.0359	0.0351
Mercury*	7439-97-6	mg/L	NA															
Molybdenum	7439-98-7	mg/L	NA	0.0026 J	0.0029 J	0.0029 J	0.0031 J	0.0026 J	0.0028 J	0.0028 J	0.0025 J	0.0024 J	0.0029 J	0.003 J	0.0028 J	0.0027 J	0.003 J	0.0026 J
Selenium	7782-49-2	mg/L	4.2	0.0069 J	0.007 J	0.0103 J												
Thallium*	7440-28-0	mg/L	0.00047															

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples.
 AWQC - Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

Detected Concentration > AWQC.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 USEPA AWQC Human Health for the Consumption of Organism Only
 apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 6b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS -
DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Missouri River Further Downstream					Missouri River Furthest Downstream					
			AWQC (b)	LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS	
Antimony*	7440-36-0	mg/L	0.64											
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0027	0.0028	0.0028	0.003	0.003	0.0028	0.003	0.0028	0.0028	0.003	
Barium	7440-39-3	mg/L	NA	0.107	0.112	0.112	0.109	0.11	0.114	0.107	0.105	0.112	0.114	
Beryllium	7440-41-7	mg/L	NA											
Boron	7440-42-8	mg/L	NA	0.0793 J	0.0838 J	0.0812 J	0.0777 J	0.0828 J	0.0825 J	0.082 J	0.0798 J	0.0849 J	0.0869 J	
Cadmium*	7440-43-9	mg/L	NA											
Calcium	7440-70-2	mg/L	NA	68.8	72.4	71.4	71	69.4	73.2	68.6	67.6	72.7	73.5	
Chromium*	7440-47-3	mg/L	NA											
Cobalt	7440-48-4	mg/L	NA											
Lead*	7439-92-1	mg/L	NA											
Lithium	7439-93-2	mg/L	NA	0.035	0.0385	0.0354	0.0366	0.0328	0.0368	0.0344	0.0341	0.0363	0.0378	
Mercury*	7439-97-6	mg/L	NA											
Molybdenum	7439-98-7	mg/L	NA	0.0028 J	0.0029 J	0.0026 J	0.0021 J	0.0026 J	0.0027 J	0.0028 J	0.0031 J	0.003 J	0.0031 J	
Selenium	7782-49-2	mg/L	4.2			0.0065 J				0.0074 J				
Thallium*	7440-28-0	mg/L	0.00047											

Notes:

Blank cells - Non-detect value.

* - Constituent was not detected in any samples.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only

apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 6c
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH AWQC SCREENING LEVELS -

TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Upstream					Missouri River River Downstream				
				LBD-R-4AS Total	LBD-R-5AS Total	LBD-R-5AM Total	LBD-R-6AS Total	LBD-R-6AM Total	LBD-R-1AS Total	LBD-R-2AS Total	LBD-R-2AM Total	LBD-R-3AS Total	LBD-R-3AM Total
				Antimony*	7440-36-0	mg/L	0.64						
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0033	0.0032	0.0035	0.003	0.0031	0.0038	0.0032	0.0034	0.0034	0.0028
Barium	7440-39-3	mg/L	NA	0.124	0.131	0.128	0.132	0.118	0.134	0.124	0.129	0.13	0.131
Beryllium*	7440-41-7	mg/L	NA										
Boron	7440-42-8	mg/L	NA	0.111	0.112	0.109	0.111	0.109	0.115	0.111	0.113	0.11	0.11
Cadmium*	7440-43-9	mg/L	NA										
Calcium	7440-70-2	mg/L	NA	69.9	71.7	70.7	70	66.2	70.7	69.2	70.8	70.2	71.4
Chloride	16887-00-6	mg/L	NA	19.5	20.2	20.1	20.9	18.6	20.5	20.4	19.9	18.6	20.8
Chromium	7440-47-3	mg/L	NA	0.0015 J	0.0025 J	0.0016 J	0.0019 J	0.0023 J	0.0024 J	0.0019 J	0.0016 J	0.0019 J	0.0023 J
Cobalt	7440-48-4	mg/L	NA										
Fluoride	16984-48-8	mg/L	NA	0.52	0.55	0.52	0.55	0.52	0.54	0.55	0.52	0.5 J	0.57
Lead	7439-92-1	mg/L	NA	0.00056 J	0.00076 J	0.00072 J	0.0011	0.0011	0.001	0.00062 J	0.00068 J	0.00088 J	0.00098 J
Mercury*	7439-97-6	mg/L	NA										
Molybdenum	7439-98-7	mg/L	NA	0.0033 J	0.0031 J	0.0028 J	0.0036 J	0.0029 J	0.0035 J	0.0035 J	0.0031 J	0.0031 J	0.0029 J
Selenium	7782-49-2	mg/L	NA	0.0015 J	0.0017 J	0.0018 J	0.0018 J	0.0017 J	0.0015 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J
Sulfate	14808-79-8	mg/L	NA	209	210	203	212	210	209	210	213	208	205
Thallium*	7440-28-0	mg/L	0.00047										
Total Hardness as CaCO3	471-34-1	mg/L	NA	284,000	291,000	287,000	285,000	268,000	287,000	281,000	287,000	285,000	289,000
Total Dissolved Solids	TDS	mg/L	NA	539	553	548	550	544	532	541	531	540	541

Notes:

- Blank cells - Non-detect value.
- * Constituent was not detected in any samples.
- AWQC - Ambient Water Quality Criteria.
- CAS - Chemical Abstracts Service.
- J - Value is estimated.
- mg/L - milligrams per liter.
- NA - Not Available.
- USEPA - United States Environmental Protection Agency.
- Detected Concentration > AWQC.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria.
USEPA Office of Water and Office of Science.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 6c
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH AWQC SCREENING LEVELS -

TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Further Downstream					Missouri River River Furthest Downstream					
				LBD-R-10S Total	LBD-R-11S Total	LBD-R-11M Total	LBD-R-12S Total	LBD-R-12M Total	LBD-R-7S Total	LBD-R-8S Total	LBD-R-8M Total	LBD-R-9S Total	LBD-R-9M Total	
				Antimony*	7440-36-0	mg/L	0.64							
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0037	0.0033	0.0032	0.0035	0.0035	0.0046	0.0034	0.0034	0.0035	0.0037	
Barium	7440-39-3	mg/L	NA	0.135	0.132	0.13	0.129	0.127	0.17	0.13	0.13	0.135	0.135	
Beryllium*	7440-41-7	mg/L	NA											
Boron	7440-42-8	mg/L	NA	0.111	0.11	0.111	0.11	0.111	0.115	0.111	0.11	0.111	0.109	
Cadmium*	7440-43-9	mg/L	NA											
Calcium	7440-70-2	mg/L	NA	70.5	69.5	69.5	69.4	70.2	71.6	70.1	69.6	70.8	70.2	
Chloride	16887-00-6	mg/L	NA	18.8	20.4	20.5	20.9	18.7	16.6	18.5	18.4	17.7	19.4	
Chromium	7440-47-3	mg/L	NA	0.0025 J	0.0024 J	0.0018 J	0.002 J	0.0018 J	0.0056 J	0.0017 J	0.0018 J	0.003 J	0.0019 J	
Cobalt	7440-48-4	mg/L	NA	0.0012 J	0.001 J				0.0022 J		0.001 J	0.0011 J		
Fluoride	16984-48-8	mg/L	NA		0.5	0.53	0.54	0.5 J		0.37 J			0.31 J	
Lead	7439-92-1	mg/L	NA	0.0013	0.0012	0.001	0.00088 J	0.00077 J	0.0033	0.0011	0.0011	0.0013	0.0015	
Mercury*	7439-97-6	mg/L	NA											
Molybdenum	7439-98-7	mg/L	NA	0.0036 J	0.0033 J	0.0031 J	0.0034 J	0.0032 J	0.0062 J	0.0038 J	0.003 J	0.003 J	0.0032 J	
Selenium	7782-49-2	mg/L	4.2	0.0018 J	0.0017 J	0.0017 J	0.0017 J	0.0017 J	0.0019 J	0.0019 J	0.0019 J	0.0017 J	0.0017 J	
Sulfate	14808-79-8	mg/L	NA	215	210	210	213	211	208	210	224	206	211	
Thallium*	7440-28-0	mg/L	0.00047											
Total Hardness as CaCO3	471-34-1	mg/L	NA	286,000	282,000	283,000	283,000	285,000	291,000	285,000	283,000	287,000	284,000	
Total Dissolved Solids	TDS	mg/L	NA	550	543	546	516	555	524	538	551	547	551	

Notes:

- Blank cells - Non-detect value.
- * Constituent was not detected in any samples.
- AWQC - Ambient Water Quality Criteria.
- CAS - Chemical Abstracts Service.
- J - Value is estimated.
- mg/L - milligrams per liter.
- NA - Not Available.
- USEPA - United States Environmental Protection Agency.
- Detected Concentration > AWQC.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria.
USEPA Office of Water and Office of Science.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 6d

COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH AWQC SCREENING LEVELS -

DISSOLVED (FILTERED) SAMPLE RESULTS (a)
 AMEREN MISSOURI LABADIE ENERGY CENTER
 FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Upstream					Missouri River River Downstream				
				LBD-R-4AS Filtered	LBD-R-5AS Filtered	LBD-R-5AM Filtered	LBD-R-6AS Filtered	LBD-R-6AM Filtered	LBD-R-1AS Filtered	LBD-R-2AS Filtered	LBD-R-2AM Filtered	LBD-R-3AS Filtered	LBD-R-3AM Filtered
				Antimony*	7440-36-0	mg/L	0.64						
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0024	0.0027	0.0023	0.0026	0.0026	0.0028	0.0024	0.0022	0.0026	0.0026
Barium	7440-39-3	mg/L	NA	0.111	0.108	0.11	0.11	0.0999	0.111	0.113	0.11	0.109	0.109
Beryllium*	7440-41-7	mg/L	NA										
Boron	7440-42-8	mg/L	NA	0.109	0.107	0.108	0.108	0.103	0.113	0.113	0.111	0.108	0.11
Cadmium*	7440-43-9	mg/L	NA										
Calcium	7440-70-2	mg/L	NA	70.2	67.8	68.7	67.8	62.5	70.7	69.8	69.4	68.6	69.4
Chromium*	7440-47-3	mg/L	NA										
Cobalt*	7440-48-4	mg/L	NA										
Lead*	7439-92-1	mg/L	NA										
Mercury*	7439-97-6	mg/L	NA										
Molybdenum	7439-98-7	mg/L	NA	0.0036 J	0.0038 J	0.0037 J	0.0041 J	0.0027 J	0.0031 J	0.0035 J	0.0036 J	0.0034 J	0.0037 J
Selenium	7782-49-2	mg/L	4.2	0.0016 J	0.0017 J	0.0017 J	0.0018 J	0.0016 J	0.0015 J	0.0017 J	0.0016 J	0.0015 J	0.0016 J
Thallium*	7440-28-0	mg/L	0.00047										

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Value is estimated.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

Detected Concentration > AWQC.

(a) - Surface water samples collected in November 2014.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 6d
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS TO HUMAN HEALTH AWQC SCREENING LEVELS -

DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Further Downstream					Missouri River River Furthest Downstream				
				LBD-R-10S Filtered	LBD-R-11S Filtered	LBD-R-11M Filtered	LBD-R-12S Filtered	LBD-R-12M Filtered	LBD-R-7S Filtered	LBD-R-8S Filtered	LBD-R-8M Filtered	LBD-R-9S Filtered	LBD-R-9M Filtered
				Antimony*	7440-36-0	mg/L	0.64						
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0026	0.0027	0.0025	0.0026	0.0023	0.0027	0.0028	0.0026	0.0025	0.0027
Barium	7440-39-3	mg/L	NA	0.112	0.111	0.111	0.11	0.109	0.113	0.111	0.111	0.109	0.111
Beryllium*	7440-41-7	mg/L	NA										
Boron	7440-42-8	mg/L	NA	0.11	0.109	0.11	0.109	0.11	0.11	0.108	0.108	0.105	0.108
Cadmium*	7440-43-9	mg/L	NA										
Calcium	7440-70-2	mg/L	NA	68.6	68.4	68.5	69.4	69.2	69	67.8	68.7	68.7	69.1
Chromium*	7440-47-3	mg/L	NA										
Cobalt*	7440-48-4	mg/L	NA										
Lead*	7439-92-1	mg/L	NA										
Mercury*	7439-97-6	mg/L	NA										
Molybdenum	7439-98-7	mg/L	NA	0.0037 J	0.004 J	0.0048 J	0.004 J	0.0034 J	0.0059 J	0.0038 J	0.004 J	0.0035 J	0.0036 J
Selenium	7782-49-2	mg/L	4.2	0.0015 J	0.0016 J	0.0017 J	0.0015 J	0.0017 J	0.0016 J	0.0017 J	0.0015 J	0.0019 J	0.0017 J
Thallium*	7440-28-0	mg/L	0.00047										

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Value is estimated.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

Detected Concentration > AWQC.

(a) - Surface water samples collected in November 2014.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 6e
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO AWQC SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Upstream					Missouri River River Downstream					
				LBD-R-4S Total	LBD-R-5S Total	LBD-R-5M Total	LBD-R-6S Total	LBD-R-6M Total	LBD-R-1S Total	LBD-R-2S Total	LBD-R-2M Total	LBD-R-3S Total	LBD-R-3M Total	
				Antimony*	7440-36-0	mg/L	0.64							
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.005	0.005	0.0048	0.0047	0.0047	0.0044	0.0045	0.0047	0.0048	0.0049	
Barium	7440-39-3	mg/L	NA	0.113	0.119	0.12	0.123	0.119	0.113	0.122	0.123	0.123	0.124	
Beryllium*	7440-41-7	mg/L	NA											
Boron	7440-42-8	mg/L	NA	0.111	0.114	0.114	0.115	0.113	0.12	0.121	0.123	0.118	0.119	
Cadmium*	7440-43-9	mg/L	NA											
Calcium	7440-70-2	mg/L	NA	62.3	63.5	63.4	65.1	64.5	63.8	64.7	63.6	64.2	65.5	
Chromium	7440-47-3	mg/L	NA	0.0022 J	0.0026 J	0.0029 J	0.0031 J	0.0023 J	0.0023 J	0.0027 J	0.0031 J	0.0029 J	0.0032 J	
Cobalt*	7440-48-4	mg/L	NA											
Fluoride	16984-48-8	mg/L	NA	0.41 J	0.48 J	0.45 J	0.51 J	0.44 J	0.5 J	0.47 J	0.48 J	0.47 J	0.43 J	
Lead	7439-92-1	mg/L	NA	0.0015	0.0018	0.0018	0.0019	0.0019	0.0015	0.0018	0.0018	0.0019	0.0019	
Mercury*	7439-97-6	mg/L	NA											
Molybdenum	7439-98-7	mg/L	NA	0.004 J	0.0044 J	0.0042 J	0.0043 J	0.0041 J	0.0044 J	0.0044 J	0.0044 J	0.0044 J	0.0041 J	
Selenium	7782-49-2	mg/L	4.2	0.0016 J	0.0018 J	0.0016 J	0.0017 J	0.0018 J	0.0017 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J	
Sulfate	14808-79-8	mg/L	NA	194	194	193	194	197	174	187	193	189	192	
Thallium*	7440-28-0	mg/L	0.00047											
Total Hardness as CaCO3	471-34-1	mg/L	NA	249	254	253	260	257	255	258	254	256	261	

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in October 2013.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 6f
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO AWQC SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Missouri River River Upstream					Missouri River River Downstream					
				LBD-R-4S Filtered	LBD-R-5S Filtered	LBD-R-5M Filtered	LBD-R-6S Filtered	LBD-R-6M Filtered	LBD-R-1S Filtered	LBD-R-2S Filtered	LBD-R-2M Filtered	LBD-R-3S Filtered	LBD-R-3M Filtered	
				Antimony*	7440-36-0	mg/L	0.64							
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0035	0.0035	0.0038	0.0037	0.0034	0.004	0.0037	0.0036	0.0033	0.0035	
Barium	7440-39-3	mg/L	NA	0.0928	0.0906	0.0917	0.0907	0.0886	0.0936	0.0912	0.0914	0.0915	0.0938	
Beryllium*	7440-41-7	mg/L	NA											
Boron	7440-42-8	mg/L	NA	0.12	0.115	0.118	0.115	0.113	0.123	0.122	0.123	0.116	0.119	
Cadmium*	7440-43-9	mg/L	NA											
Calcium	7440-70-2	mg/L	NA	--	--	--	--	--	--	--	--	--	--	
Chromium*	7440-47-3	mg/L	NA											
Cobalt*	7440-48-4	mg/L	NA											
Fluoride	16984-48-8	mg/L	NA	--	--	--	--	--	--	--	--	--	--	
Lead*	7439-92-1	mg/L	NA											
Mercury*	7439-97-6	mg/L	NA											
Molybdenum	7439-98-7	mg/L	NA	0.0035 J	0.0035 J	0.0041 J	0.0038 J	0.0036 J	0.0042 J	0.0039 J	0.0042 J	0.0036 J	0.0037 J	
Selenium	7782-49-2	mg/L	4.2	0.0016 J	0.0015 J	0.0015 J	0.0016 J	0.0014 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J	
Sulfate	14808-79-8	mg/L	NA	--	--	--	--	--	--	--	--	--	--	
Thallium*	7440-28-0	mg/L	0.00047											
Total Hardness as CaCO3	471-34-1	mg/L	NA	--	--	--	--	--	--	--	--	--	--	

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in October 2013.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 7a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	NA	NA															
Arsenic	7440-38-2	mg/L	0.34	0.15	0.004	0.0041	0.0044	0.0044	0.0046	0.0042	0.0046	0.0046	0.0047	0.0045	0.0053	0.0041	0.0041	0.0045	0.0046
Barium	7440-39-3	mg/L	NA	NA	0.146	0.173	0.18	0.184	0.193	0.173	0.201	0.201	0.198	0.204	0.162	0.181	0.169	0.187	0.192
Beryllium*	7440-41-7	mg/L	NA	NA															
Boron	7440-42-8	mg/L	NA	NA	0.0787 J	0.0814 J	0.0824 J	0.0812 J	0.0836 J	0.085 J	0.0903 J	0.0885 J	0.0898 J	0.0916 J	0.0818 J	0.0829 J	0.0813 J	0.0849 J	0.0833 J
Cadmium*	7440-43-9	mg/L	0.0058 (d)	0.0020 (d)						0.00059 J						0.00054 J			
Calcium	7440-70-2	mg/L	NA	NA	74.1	75.1	76.8	76.2	79	72.8	77	77.2	78.6	77.8	75.4	76.7	75.9	79.6	78.9
Chloride	16887-00-6	mg/L	860	230	22.5	22.8	22.7	23.5	23.9	23.8	24	24.5	25.1	25.2	22.6	22.8	22.6	23.6	23.3
Chromium	7440-47-3	mg/L	4.59 (c,d)	0.219 (c,d)	0.0024 J	0.005	0.007	0.0064	0.0068	0.0052	0.0071	0.0076	0.0059	0.0075	0.0033 J	0.0067	0.0048 J	0.0061	0.0068
Cobalt	7440-48-4	mg/L	NA	NA	0.002 J	0.0029 J	0.0034 J	0.0037 J	0.0039 J	0.0028 J	0.0038 J	0.0044 J	0.0035 J	0.0033 J	0.0028 J	0.0028 J	0.0028 J	0.0028 J	0.0032 J
Fluoride	16984-48-8	mg/L	NA	NA	0.36	0.37	0.36	0.38	0.37	0.39	0.42	0.4	0.41	0.41	0.37	0.36	0.36	0.37	0.38
Lead	7439-92-1	mg/L	0.35 (d)	0.014 (d)	0.0052 J	0.0046 J	0.004 J	0.0046 J	0.0057 J	0.0051 J	0.006 J	0.006 J	0.0054 J	0.0034 J	0.0034 J	0.0057 J	0.0079 J	0.0038 J	0.0038 J
Lithium	7439-93-2	mg/L	NA	NA	0.0354	0.0353	0.0379	0.038	0.0396	0.0379	0.0408	0.0403	0.0414	0.0428	0.0357	0.0377	0.0366	0.0386	0.0398
Mercury*	7439-97-6	mg/L	0.0016	0.001															
Molybdenum	7439-98-7	mg/L	NA	NA	0.0022 J	0.0026 J	0.003 J	0.0025 J	0.003 J	0.0021 J	0.0024 J	0.002 J	0.002 J	0.0026 J	0.0026 J	0.0026 J	0.0027 J	0.0029 J	0.0028 J
Selenium	7782-49-2	mg/L	NA	3.1	0.0074 J	0.007 J	0.0077 J	0.0076 J							0.009 J				
Sulfate	14808-79-8	mg/L	NA	NA	176	178	177	183	180	172	173	174	179	180	175	178	179	185	186
Thallium*	7440-28-0	mg/L	NA	NA															
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	301	304	310	308	319	302	316	316	319	319	304	311	307	320	318
Total Dissolved Solids	TDS	mg/L	NA	NA	506	507	491	491	488	479	505	506	517	523	500	505	509	519	522

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - USEPA Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness - see note (d).

USEPA provides AWQC for both total and dissolved results.

(c) - Value for trivalent chromium used.

(d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO3 used.

TABLE 7a
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River Further Downstream					Missouri River Furthest Downstream				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0039	0.0041	0.0042	0.0045	0.0044	0.0034	0.0046	0.0043	0.0044	0.0045
Barium	7440-39-3	mg/L	NA	NA	0.17	0.163	0.158	0.18	0.194	0.128	0.178	0.19	0.188	0.174
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.0825 J	0.0825 J	0.0818 J	0.0873 J	0.0854 J	0.0814 J	0.0879 J	0.0869 J	0.0875 J	0.0899 J
Cadmium*	7440-43-9	mg/L	0.0058 (d)	0.0020 (d)	0.0005 J									
Calcium	7440-70-2	mg/L	NA	NA	76.6	76	78.5	75.7	79.8	72.5	78.6	80.2	78.9	82.6
Chloride	16887-00-6	mg/L	860	230	22.8	22.4	22.7	23	22.9	22.5	23	23	23.5	23.8
Chromium	7440-47-3	mg/L	4.59 (c,d)	0.219 (c,d)	0.0051	0.0042 J	0.0023 J	0.0054	0.0066	0.0016 J	0.0047 J	0.0073	0.0064	0.0048 J
Cobalt	7440-48-4	mg/L	NA	NA	0.0024 J	0.0027 J	0.0024 J	0.0029 J	0.0037 J	0.0013 J	0.0036 J	0.0036 J	0.0033 J	0.0024 J
Fluoride	16984-48-8	mg/L	NA	NA	0.36	0.36	0.36	0.37	0.37	0.36	0.37	0.37	0.37	0.39
Lead	7439-92-1	mg/L	0.35 (d)	0.014 (d)	0.0034 J	0.0034 J	0.0043 J	0.0051 J	0.005 J	0.003 J	0.0048 J	0.0048 J	0.0046 J	0.0057 J
Lithium	7439-93-2	mg/L	NA	NA	0.0368	0.0349	0.036	0.0412	0.0415	0.0342	0.039	0.0396	0.0379	0.04
Mercury*	7439-97-6	mg/L	0.0016	0.001										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0028 J	0.0023 J	0.0023 J	0.0021 J	0.0028 J	0.0024 J	0.0029 J	0.0028 J	0.0029 J	0.0025 J
Selenium	7782-49-2	mg/L	NA	3.1	0.0088 J					0.0102 J	0.0065 J	0.0089 J	0.0063 J	
Sulfate	14808-79-8	mg/L	NA	NA	175	178	178	181	179	176	180	181	187	187
Thallium*	7440-28-0	mg/L	NA	NA										
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	310	307	315	308	323	296	317	325	319	331
Total Dissolved Solids	TDS	mg/L	NA	NA	492	519	486	517	508	481	512	513	525	519

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 AWQC - USEPA Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO3 used.

TABLE 7b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River Upstream					Missouri River Adjacent					Missouri River Downstream				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-R-4BS	LBD-R-5BM	LBD-R-5BS	LBD-R-6BM	LBD-R-6BS	LBD-R-13BS	LBD-R-14BM	LBD-R-14BS	LBD-R-15BM	LBD-R-15BS	LBD-R-1BS	LBD-R-2BM	LBD-R-2BS	LBD-R-3BM	LBD-R-3BS
Antimony*	7440-36-0	mg/L	NA	NA															
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0031	0.003	0.003	0.003	0.0029	0.0029	0.0029	0.0032	0.003	0.0029	0.003	0.003	0.0029	0.0032	0.003
Barium	7440-39-3	mg/L	NA	NA	0.111	0.108	0.11	0.111	0.111	0.109	0.106	0.108	0.103	0.111	0.107	0.109	0.103	0.113	0.109
Beryllium	7440-41-7	mg/L	NA	NA						0.00017 J									
Boron	7440-42-8	mg/L	NA	NA	0.081 J	0.0806 J	0.0785 J	0.0846 J	0.0837 J	0.0817 J	0.0798 J	0.0777 J	0.0765 J	0.0805 J	0.079 J	0.0859 J	0.078 J	0.0842 J	0.0836 J
Cadmium*	7440-43-9	mg/L	0.0052 (d)	0.0017 (d)															
Calcium	7440-70-2	mg/L	NA	NA	71.7	71.5	71.1	72.2	73	70.5	69.3	70.4	67.4	71.5	68.5	72	68.1	72.4	71
Chromium*	7440-47-3	mg/L	1.45 (c,d)	0.19 (c,d)															
Cobalt	7440-48-4	mg/L	NA	NA								0.00099 J							
Lead*	7439-92-1	mg/L	0.218 (d)	0.0085 (d)															
Lithium	7439-93-2	mg/L	NA	NA	0.0328	0.0334	0.0361	0.0357	0.036	0.038	0.0348	0.0371	0.0355	0.0362	0.0331	0.0335	0.0314	0.0359	0.0351
Mercury*	7439-97-6	mg/L	0.0014	0.00077															
Molybdenum	7439-98-7	mg/L	NA	NA	0.0026 J	0.0029 J	0.0029 J	0.0031 J	0.0026 J	0.0028 J	0.0028 J	0.0025 J	0.0024 J	0.0029 J	0.003 J	0.0028 J	0.0027 J	0.003 J	0.0026 J
Selenium	7782-49-2	mg/L	NA	NA	0.0069 J	0.007 J	0.0103 J												
Thallium*	7440-28-0	mg/L	NA	NA															

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 AWQC - USEPA Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Estimated value.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

 Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO3 used.

TABLE 7b
COMPARISON OF MAY 2018 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River Further Downstream					Missouri River Furthest Downstream				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-R-10BS	LBD-R-11BM	LBD-R-11BS	LBD-R-12BM	LBD-R-12BS	LBD-R-7BS	LBD-R-8BM	LBD-R-8BS	LBD-R-9BM	LBD-R-9BS
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0027	0.0028	0.0028	0.003	0.003	0.0028	0.003	0.0028	0.0028	0.003
Barium	7440-39-3	mg/L	NA	NA	0.107	0.112	0.112	0.109	0.11	0.114	0.107	0.105	0.112	0.114
Beryllium	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.0793 J	0.0838 J	0.0812 J	0.0777 J	0.0828 J	0.0825 J	0.082 J	0.0798 J	0.0849 J	0.0869 J
Cadmium*	7440-43-9	mg/L	0.0052 (d)	0.0017 (d)										
Calcium	7440-70-2	mg/L	NA	NA	68.8	72.4	71.4	71	69.4	73.2	68.6	67.6	72.7	73.5
Chromium*	7440-47-3	mg/L	1.45 (c,d)	0.19 (c,d)										
Cobalt	7440-48-4	mg/L	NA	NA										
Lead*	7439-92-1	mg/L	0.218 (d)	0.0085 (d)										
Lithium	7439-93-2	mg/L	NA	NA	0.035	0.0385	0.0354	0.0366	0.0328	0.0368	0.0344	0.0341	0.0363	0.0378
Mercury*	7439-97-6	mg/L	0.0014	0.00077										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0028 J	0.0029 J	0.0026 J	0.0021 J	0.0026 J	0.0027 J	0.0028 J	0.0031 J	0.003 J	0.0031 J
Selenium	7782-49-2	mg/L	NA	NA			0.0065 J				0.0074 J			
Thallium*	7440-28-0	mg/L	NA	NA										

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - USEPA Ambient Water Quality Criteria.



CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness - see note (d).

USEPA provides AWQC for both total and dissolved results.

(c) - Value for trivalent chromium used.

(d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 313 mg/L as CaCO₃ used.

TABLE 7c
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River					Missouri River				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	River Upstream					River Downstream				
					LBD-R-4AS Total	LBD-R-5AS Total	LBD-R-5AM Total	LBD-R-6AS Total	LBD-R-6AM Total	LBD-R-1AS Total	LBD-R-2AS Total	LBD-R-2AM Total	LBD-R-3AS Total	LBD-R-3AM Total
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0033	0.0032	0.0035	0.003	0.0031	0.0038	0.0032	0.0034	0.0034	0.0028
Barium	7440-39-3	mg/L	NA	NA	0.124	0.131	0.128	0.132	0.118	0.134	0.124	0.129	0.13	0.131
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.111	0.112	0.109	0.111	0.109	0.115	0.111	0.113	0.11	0.11
Cadmium*	7440-43-9	mg/L	0.0053 (d)	0.0018 (d)										
Calcium	7440-70-2	mg/L	NA	NA	69.9	71.7	70.7	70	66.2	70.7	69.2	70.8	70.2	71.4
Chloride	16987-00-6	mg/L	860	230	19.5	20.2	20.1	20.9	18.6	20.5	20.4	19.9	18.6	20.8
Chromium	7440-47-3	mg/L	4.2 (c,d)	0.20 (c,d)	0.0015 J	0.0025 J	0.0016 J	0.0019 J	0.0023 J	0.0024 J	0.0019 J	0.0016 J	0.0019 J	0.0023 J
Cobalt	7440-48-4	mg/L	NA	NA										
Fluoride	16984-48-8	mg/L	NA	NA	0.52	0.55	0.52	0.55	0.52	0.54	0.55	0.52	0.5 J	0.57
Lead	7439-92-1	mg/L	0.31 (d)	0.012 (d)	0.00056 J	0.00076 J	0.00072 J	0.0011	0.0011	0.001	0.00062 J	0.00068 J	0.00088 J	0.00098 J
Mercury*	7439-97-6	mg/L	0.0016	0.00091										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0033 J	0.0031 J	0.0028 J	0.0036 J	0.0029 J	0.0035 J	0.0035 J	0.0031 J	0.0031 J	0.0029 J
Selenium	7782-49-2	mg/L	NA	3.1	0.0015 J	0.0017 J	0.0018 J	0.0018 J	0.0017 J	0.0015 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J
Sulfate	14808-79-8	mg/L	NA	NA	209	210	203	212	210	209	210	213	208	205
Thallium*	7440-28-0	mg/L	NA	NA										
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	284,000	291,000	287,000	285,000	268,000	287,000	281,000	287,000	285,000	289,000
Total Dissolved Solids	TDS	mg/L	NA	NA	539	553	548	550	544	532	541	531	540	541

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - USEPA Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Value is estimated.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

Detected Concentration- USEPA Aquatic Life AWQC Chronic.
 Detected Concentration- USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 7c
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River					Missouri River				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	River Further Downstream					River Furthest Downstream				
					LBD-R-10S Total	LBD-R-11S Total	LBD-R-11M Total	LBD-R-12S Total	LBD-R-12M Total	LBD-R-7S Total	LBD-R-8S Total	LBD-R-8M Total	LBD-R-9S Total	LBD-R-9M Total
Antimony*	7440-36-0	mg/L	NA	NA	0.0037	0.0033	0.0032	0.0035	0.0035	0.0046	0.0034	0.0034	0.0035	0.0037
Arsenic	7440-38-2	mg/L	0.34	0.15	0.135	0.132	0.13	0.129	0.127	0.17	0.13	0.13	0.135	0.135
Barium	7440-39-3	mg/L	NA	NA										
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.111	0.11	0.111	0.11	0.111	0.115	0.111	0.11	0.111	0.109
Cadmium*	7440-43-9	mg/L	0.0053 (d)	0.0018 (d)										
Calcium	7440-70-2	mg/L	NA	NA	70.5	69.5	69.5	69.4	70.2	71.6	70.1	69.6	70.8	70.2
Chloride	16887-00-6	mg/L	860	230	18.8	20.4	20.5	20.9	18.7	16.6	18.5	18.4	17.7	19.4
Chromium	7440-47-3	mg/L	4.2 (c,d)	0.20 (c,d)	0.0025 J	0.0024 J	0.0018 J	0.002 J	0.0018 J	0.0056 J	0.0017 J	0.0018 J	0.003 J	0.0019 J
Cobalt	7440-48-4	mg/L	NA	NA	0.0012 J	0.001 J				0.0022 J		0.001 J	0.0011 J	
Fluoride	16984-48-8	mg/L	NA	NA		0.5	0.53	0.54	0.5 J		0.37 J			0.31 J
Lead	7439-92-1	mg/L	0.31 (d)	0.012 (d)	0.0013	0.0012	0.001	0.00088 J	0.00077 J	0.0033	0.0011	0.0011	0.0013	0.0015
Mercury*	7439-97-6	mg/L	0.0016	0.00091										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0036 J	0.0033 J	0.0031 J	0.0034 J	0.0032 J	0.0062 J	0.0038 J	0.003 J	0.003 J	0.0032 J
Selenium	7782-49-2	mg/L	NA	3.1	0.0018 J	0.0017 J	0.0017 J	0.0017 J	0.0017 J	0.0019 J	0.0019 J	0.0019 J	0.0017 J	0.0017 J
Sulfate	14808-79-8	mg/L	NA	NA	215	210	210	213	211	208	210	224	206	211
Thallium*	7440-28-0	mg/L	NA	NA										
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	286,000	282,000	283,000	283,000	285,000	291,000	285,000	283,000	287,000	284,000
Total Dissolved Solids	TDS	mg/L	NA	NA	550	543	546	516	555	524	538	551	547	551

Notes:

- Blank cells - Non-detect value.
- * Constituent was not detected in any samples.
- AWQC - USEPA Ambient Water Quality Criteria.
- CAS - Chemical Abstracts Service.
- J - Value is estimated.
- mg/L - milligrams per liter.
- NA - Not Available.
- USEPA - United States Environmental Protection Agency.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology. <http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
Total values provided. Values adjusted for site-specific hardness - see note (d). USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 7d
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River					Missouri River				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	River Upstream					River Downstream				
					LBD-R-4AS Filtered	LBD-R-5AS Filtered	LBD-R-5AM Filtered	LBD-R-6AS Filtered	LBD-R-6AM Filtered	LBD-R-1AS Filtered	LBD-R-2AS Filtered	LBD-R-2AM Filtered	LBD-R-3AS Filtered	LBD-R-3AM Filtered
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0024	0.0027	0.0023	0.0026	0.0026	0.0028	0.0024	0.0022	0.0026	0.0026
Barium	7440-39-3	mg/L	NA	NA	0.111	0.108	0.11	0.11	0.0999	0.111	0.113	0.11	0.109	0.109
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.109	0.107	0.108	0.108	0.103	0.113	0.113	0.111	0.108	0.11
Cadmium*	7440-43-9	mg/L	0.0048 (d)	0.0016 (d)										
Calcium	7440-70-2	mg/L	NA	NA	70.2	67.8	68.7	67.8	62.5	70.7	69.8	69.4	68.6	69.4
Chromium*	7440-47-3	mg/L	1.3 (c,d)	0.17 (c,d)										
Cobalt*	7440-48-4	mg/L	NA	NA										
Lead*	7439-92-1	mg/L	0.20 (d)	0.0077 (d)										
Mercury*	7439-97-6	mg/L	0.0014	0.00077										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0036 J	0.0038 J	0.0037 J	0.0041 J	0.0027 J	0.0031 J	0.0035 J	0.0036 J	0.0034 J	0.0037 J
Selenium	7782-49-2	mg/L	NA	NA	0.0016 J	0.0017 J	0.0017 J	0.0018 J	0.0016 J	0.0015 J	0.0017 J	0.0016 J	0.0015 J	0.0016 J
Thallium*	7440-28-0	mg/L	NA	NA										

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 AWQC - USEPA Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Value is estimated.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

 Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 7d
COMPARISON OF NOVEMBER 2014 MISSOURI RIVER SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River					Missouri River				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	River Further Downstream					River Furthest Downstream				
					LBD-R-10S Filtered	LBD-R-11S Filtered	LBD-R-11M Filtered	LBD-R-12S Filtered	LBD-R-12M Filtered	LBD-R-7S Filtered	LBD-R-8S Filtered	LBD-R-8M Filtered	LBD-R-9S Filtered	LBD-R-9M Filtered
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0026	0.0027	0.0025	0.0026	0.0023	0.0027	0.0028	0.0026	0.0025	0.0027
Barium	7440-39-3	mg/L	NA	NA	0.112	0.111	0.111	0.11	0.109	0.113	0.111	0.111	0.109	0.111
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.11	0.109	0.11	0.109	0.11	0.11	0.108	0.108	0.105	0.108
Cadmium*	7440-43-9	mg/L	0.0048 (d)	0.0016 (d)										
Calcium	7440-70-2	mg/L	NA	NA	68.6	68.4	68.5	69.4	69.2	69	67.8	68.7	68.7	69.1
Chromium*	7440-47-3	mg/L	1.3 (c,d)	0.17 (c,d)										
Cobalt*	7440-48-4	mg/L	NA	NA										
Lead*	7439-92-1	mg/L	0.20 (d)	0.0077 (d)										
Mercury*	7439-97-6	mg/L	0.0014	0.00077										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0037 J	0.004 J	0.0048 J	0.004 J	0.0034 J	0.0059 J	0.0038 J	0.004 J	0.0035 J	0.0036 J
Selenium	7782-49-2	mg/L	NA	NA	0.0015 J	0.0016 J	0.0017 J	0.0015 J	0.0017 J	0.0016 J	0.0017 J	0.0015 J	0.0019 J	0.0017 J
Thallium*	7440-28-0	mg/L	NA	NA										

Notes:
 Blank cells - Non-detect value.
 * Constituent was not detected in any samples.
 AWQC - USEPA Ambient Water Quality Criteria.
 CAS - Chemical Abstracts Service.
 J - Value is estimated.
 mg/L - milligrams per liter.
 NA - Not Available.
 USEPA - United States Environmental Protection Agency.

Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in November 2014.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 7e
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Missouri River					Missouri River				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	River Upstream					River Downstream				
					LBD-R-4S Total	LBD-R-5S Total	LBD-R-5M Total	LBD-R-6S Total	LBD-R-6M Total	LBD-R-1S Total	LBD-R-2S Total	LBD-R-2M Total	LBD-R-3S Total	LBD-R-3M Total
Antimony*	7440-36-0	mg/L	NA	NA										
Arsenic	7440-38-2	mg/L	0.34	0.15	0.005	0.005	0.0048	0.0047	0.0047	0.0044	0.0045	0.0047	0.0048	0.0049
Barium	7440-39-3	mg/L	NA	NA	0.113	0.119	0.12	0.123	0.119	0.113	0.122	0.123	0.123	0.124
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.111	0.114	0.114	0.115	0.113	0.12	0.121	0.123	0.118	0.119
Cadmium*	7440-43-9	mg/L	0.0053 (d)	0.0018 (d)										
Calcium	7440-70-2	mg/L	NA	NA	62.3	63.5	63.4	65.1	64.5	63.8	64.7	63.6	64.2	65.5
Chromium	7440-47-3	mg/L	4.2 (c,d)	0.20 (c,d)	0.0022 J	0.0026 J	0.0029 J	0.0031 J	0.0023 J	0.0023 J	0.0027 J	0.0031 J	0.0029 J	0.0032 J
Cobalt*	7440-48-4	mg/L	NA	NA										
Fluoride	16984-48-8	mg/L	NA	NA	0.41 J	0.48 J	0.45 J	0.51 J	0.44 J	0.5 J	0.47 J	0.48 J	0.47 J	0.43 J
Lead	7439-92-1	mg/L	0.31 (d)	0.012 (d)	0.0015	0.0018	0.0018	0.0019	0.0019	0.0015	0.0018	0.0018	0.0019	0.0019
Mercury*	7439-97-6	mg/L	0.0016	0.00091										
Molybdenum	7439-98-7	mg/L	NA	NA	0.004 J	0.0044 J	0.0042 J	0.0043 J	0.0041 J	0.0044 J	0.0044 J	0.0044 J	0.0044 J	0.0041 J
Selenium	7782-49-2	mg/L	NA	3.1	0.0016 J	0.0018 J	0.0016 J	0.0017 J	0.0018 J	0.0017 J	0.0016 J	0.0017 J	0.0017 J	0.0017 J
Sulfate	14808-79-8	mg/L	NA	NA	194	194	193	194	197	174	187	193	189	192
Thallium*	7440-28-0	mg/L	NA	NA										
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	249	254	253	260	257	255	258	254	256	261

Notes:

Blank cells - Non-detect value. J - Estimated value.
 * Constituent was not detected in any samples. mg/L - milligrams per liter.
 -- - Constituent not included in this analysis. NA - Not Available.
 AWQC - USEPA Ambient Water Quality Criteria. USEPA - United States Environmental Protection Agency.
 CAS - Chemical Abstracts Service.

Detected Concentration > USEPA Aquatic Life AWQC Chronic.
 Detected Concentration > USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in October 2013.
- (b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology. <http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 7f
COMPARISON OF OCTOBER 2013 MISSOURI RIVER SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality		Missouri River River Upstream					Missouri River River Downstream				
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-R-4S Filtered	LBD-R-5S Filtered	LBD-R-5M Filtered	LBD-R-6S Filtered	LBD-R-6M Filtered	LBD-R-1S Filtered	LBD-R-2S Filtered	LBD-R-2M Filtered	LBD-R-3S Filtered	LBD-R-3M Filtered
			Antimony*	7440-36-0	mg/L	NA	NA							
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0035	0.0035	0.0038	0.0037	0.0034	0.004	0.0037	0.0036	0.0033	0.0035
Barium	7440-39-3	mg/L	NA	NA	0.0928	0.0906	0.0917	0.0907	0.0886	0.0936	0.0912	0.0914	0.0915	0.0938
Beryllium*	7440-41-7	mg/L	NA	NA										
Boron	7440-42-8	mg/L	NA	NA	0.12	0.115	0.118	0.115	0.113	0.123	0.122	0.123	0.116	0.119
Cadmium*	7440-43-9	mg/L	0.0048 (d)	0.0016 (d)										
Calcium	7440-70-2	mg/L	NA	NA	--	--	--	--	--	--	--	--	--	--
Chromium*	7440-47-3	mg/L	1.3 (c,d)	0.17 (c,d)										
Cobalt*	7440-48-4	mg/L	NA	NA										
Fluoride	16984-48-8	mg/L	NA	NA	--	--	--	--	--	--	--	--	--	--
Lead*	7439-92-1	mg/L	0.20 (d)	0.0077 (d)										
Mercury*	7439-97-6	mg/L	0.0014	0.00077										
Molybdenum	7439-98-7	mg/L	NA	NA	0.0035 J	0.0035 J	0.0041 J	0.0038 J	0.0036 J	0.0042 J	0.0039 J	0.0042 J	0.0036 J	0.0037 J
Selenium	7782-49-2	mg/L	NA	NA	0.0016 J	0.0015 J	0.0015 J	0.0016 J	0.0014 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J	0.0016 J
Sulfate	14808-79-8	mg/L	NA	NA	--	--	--	--	--	--	--	--	--	--
Thallium*	7440-28-0	mg/L	NA	NA										
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	--	--	--	--	--	--	--	--	--	--

Notes:
 Blank cells - Non-detect value. J - Estimated value.
 * Constituent was not detected in any samples. mg/L - milligrams per liter.
 -- Constituent not included in this analysis. NA - Not Available.
 AWQC - USEPA Ambient Water Quality Criteria. USEPA - United States Environmental Protection Agency.
 CAS - Chemical Abstracts Service.

Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in October 2013.
- (b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for the Missouri River of 284.5 mg/L as CaCO3 used.

TABLE 8a
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Labadie Creek Upstream			Labadie Creek Downstream		
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-C-4BS 5/17/2018	LBD-C-5BS 5/17/2018	LBD-C-6BS 5/17/2018	LBD-C-1BS 5/17/2018	LBD-C-2BS 5/17/2018	LBD-C-3BS 5/17/2018
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006						
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0036	0.0036	0.0032	0.0044	0.0045	0.0045
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.136	0.136	0.132	0.168	0.17	0.171
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004						
Boron	7440-42-8	mg/L	NA	NA	4	4	0.0736 J	0.0731 J	0.0711 J	0.0955 J	0.0997 J	0.099 J
Cadmium	7440-43-9	mg/L	0.005	NA	0.0092	0.005					0.00089 J	
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	48.3	47.8	46.7	53.7	54.3	54.7
Chloride	16887-00-6	mg/L	NA	250	NA	250	28.8	28.6	28.6	29.9	30.1	30
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1				0.0013 J	0.0013 J	0.0013 J
Cobalt	7440-48-4	mg/L	NA	NA	0.006	0.006		0.00089 J	0.0011 J	0.0016 J	0.0013 J	0.0016 J
Fluoride	16984-48-8	mg/L	4	2	0.8	4	0.24	0.24	0.23	0.27	0.26	0.26
Lead*	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015						
Lithium*	7439-93-2	mg/L	NA	NA	0.04	0.04						
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002						
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.002 J	0.0019 J	0.0019 J	0.0034 J	0.0036 J	0.0036 J
Selenium*	7782-49-2	mg/L	0.05	NA	0.1	0.05						
Sulfate	14808-79-8	mg/L	NA	250	NA	250	19	19.1	19.1	26.4	25.4	24.8
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002						
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	225	222	218	237	240	242
Total Dissolved Solids	TDS	mg/L	NA	500	NA	500	309	304	304	350	342	334

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples. NA - Not Available.
 CAS - Chemical Abstracts Service. RSL - Regional Screening Level.
 J - Estimated value. SMCL - Secondary Maximum Contaminant Level.
 MCL - Maximum Contaminant Level. U - Constituent was not detected.
 mg/L - milligrams per liter. USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

TABLE 8b
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Labadie Creek Upstream			Labadie Creek Downstream		
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-C-4BS	LBD-C-5BS	LBD-C-6BS	LBD-C-1BS	LBD-C-2BS	LBD-C-3BS
							5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006						
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.003	0.003	0.0016	0.0033	0.0036	0.0037
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.13	0.121	0.09	0.155	0.156	0.156
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004						
Boron	7440-42-8	mg/L	NA	NA	4	4	0.0723 J	0.0797	0.0478 J	0.0995 J	0.098 J	0.097 J
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005						
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	51	51	61.7	57.8	57.4	57.6
Chromium*	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1						
Cobalt*	7440-48-4	mg/L	NA	NA	0.006	0.006				0.00098 J		
Lead*	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015						
Lithium*	7439-93-2	mg/L	NA	NA	0.04	0.04						
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002						
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0024 J			0.004 J	0.0039 J	0.0041 J
Selenium*	7782-49-2	mg/L	0.05	NA	0.1	0.05						
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002						

Notes:
 Blank cells - Non-detect value.
 * - Constituent was not detected in any samples. NA - Not Available.
 CAS - Chemical Abstracts Service. RSL - Regional Screening Level.
 J - Estimated value. SMCL - Secondary Maximum Contaminant Level.
 MCL - Maximum Contaminant Level. U - Constituent was not detected.
 mg/L - milligrams per liter. USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

- (a) - Surface water samples collected in May 2018.
- (b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018. <http://water.epa.gov/drink/contaminants/index.cfm>
- (c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm
- (d) - RSL for Mercuric Chloride used for Mercury.
- (e) - The drinking water standard or MCL for chromium is based on total chromium.
- (f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.
- (g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.
- (h) - Selected Drinking Water Screening Level uses the following hierarchy:
 Federal USEPA MCL for Drinking Water.
 Federal USEPA SMCL for Drinking Water.
 Federal November 2018 USEPA Tapwater RSL.

**TABLE 8c
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI**

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Labadie Creek							
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		Creek Upstream			Creek Downstream				
							LBD-C-4 Total	LBD-C-5 Total	LBD-C-6 Total	LBD-C-1 Total	LBD-C-2 Total	LBD-C-3 Total		
Antimony*	7440-36-0	mg/L	0.006	NA	0.0078	0.006								
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0056	0.0055	0.0061	0.0065	0.0061	0.0066		
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.124	0.122	0.125	0.161	0.164	0.172		
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004								
Boron	7440-42-8	mg/L	NA	NA	4	4	0.166	0.164	0.167	0.0978	0.0959	0.0999		
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005								
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	65.6	64.4	65.7	56.1	55.4	57.7		
Chromium	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1				0.0026 J	0.0027 J	0.0031 J		
Cobalt*	7440-48-4	mg/L	NA	NA	0.006	0.006								
Fluoride*	16984-48-8	mg/L	4	2	0.8	4								
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015	0.00014 J	0.00013 J	0.0002 J	0.0017	0.0018	0.0021		
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002								
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0029 J	0.0024 J	0.0024 J	0.0092 J	0.0055 J	0.0046 J		
Selenium*	7782-49-2	mg/L	0.05	NA	0.1	0.05								
Sulfate	14808-79-8	mg/L	NA	250	NA	250	17.8 J	17.6 J	16.6 J	19.4 J	16.3 J	15.3 J		
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002								
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	291	286	291	249	246	256		

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- Constituent not included in this analysis.

CAS - Chemical Abstracts Service.

MCL - Maximum Contaminant Level.

mg/L - milligrams per liter.

J - Estimated value.

NA - Not Available.

RSL - Regional Screening Level.

SMCL - Secondary Maximum Contaminant Level.

USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

(a) - Surface water samples collected in October 2013.

(b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018.

<http://water.epa.gov/drink/contaminants/index.cfm>

(c) - USEPA Regional Screening Levels (November 2018). Values for tapwater.

http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm

(d) - RSL for Mercuric Chloride used for Mercury.

(e) - The drinking water standard or MCL for chromium is based on total chromium.

(f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium

that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.

(g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.

(h) - Selected Drinking Water Screening Level uses the following hierarchy:

Federal USEPA MCL for Drinking Water.

Federal USEPA SMCL for Drinking Water.

Federal November 2018 USEPA Tapwater RSL.

**TABLE 8d
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI**

Constituent	CAS	Units	Federal Water Quality Screening Levels			Selected Drinking Water Screening Level (h)	Labadie Creek Creek Upstream			Labadie Creek Creek Downstream		
			USEPA MCLs (b)	USEPA SMCLs (b)	USEPA Tapwater RSLs (c)		LBD-C-4 Filtered	LBD-C-5 Filtered	LBD-C-6 Filtered	LBD-C-1 Filtered	LBD-C-2 Filtered	LBD-C-3 Filtered
			Antimony*	7440-36-0	mg/L		0.006	NA	0.0078	0.006		
Arsenic	7440-38-2	mg/L	0.01	NA	0.000052	0.01	0.0056	0.0051	0.0051	0.0039	0.0039	0.0043
Barium	7440-39-3	mg/L	2	NA	3.8	2	0.116	0.118	0.12	0.141	0.145	0.146
Beryllium*	7440-41-7	mg/L	0.004	NA	0.025	0.004						
Boron	7440-42-8	mg/L	NA	NA	4	4	0.165	0.169	0.17	0.108	0.1	0.0994
Cadmium*	7440-43-9	mg/L	0.005	NA	0.0092	0.005						
Calcium	7440-70-2	mg/L	NA	NA	NA	NA	--	--	--	--	--	--
Chromium*	7440-47-3	mg/L	0.1 (e)	NA	22 (f)	0.1						
Cobalt*	7440-48-4	mg/L	NA	NA	0.006	0.006						
Fluoride	16984-48-8	mg/L	4	2	0.8	4	--	--	--	--	--	--
Lead	7439-92-1	mg/L	0.015 (g)	NA	0.015	0.015				0.0001 J		
Mercury*	7439-97-6	mg/L	0.002	NA	0.0057 (d)	0.002						
Molybdenum	7439-98-7	mg/L	NA	NA	0.1	0.1	0.0018 J	0.0022 J	0.002 J	0.0036 J	0.0031 J	0.003 J
Selenium	7782-49-2	mg/L	0.05	NA	0.1	0.05						
Sulfate	14808-79-8	mg/L	NA	250	NA	250	--	--	--	--	--	--
Thallium*	7440-28-0	mg/L	0.002	NA	0.0002	0.002						
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	NA	NA	--	--	--	--	--	--

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

CAS - Chemical Abstracts Service.

MCL - Maximum Contaminant Level.

mg/L - milligrams per liter.

J - Estimated value.

NA - Not Available.

RSL - Regional Screening Level.

SMCL - Secondary Maximum Contaminant Level.

USEPA - United States Environmental Protection Agency.

Detected Concentration > Selected Drinking Water Screening Level.

(a) - Surface water samples collected in October 2013.

(b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories. Spring 2018.

<http://water.epa.gov/drink/contaminants/index.cfm>

(c) - USEPA Regional Screening Levels (November 2018). Values for tapwater.

http://www.epa.gov/reg3hwmd/risk/human/rb-concentration_table/Generic_Tables/index.htm

(d) - RSL for Mercuric Chloride used for Mercury.

(e) - The drinking water standard or MCL for chromium is based on total chromium.

(f) - Value for trivalent chromium used. USEPA provides a screening level for hexavalent chromium

that is not a drinking water standard, the basis of which has been questioned by USEPA's Science Advisory Board.

(g) - The Action Level presented is recommended in the USEPA Drinking Water Standards.

(h) - Selected Drinking Water Screening Level uses the following hierarchy:

Federal USEPA MCL for Drinking Water.

Federal USEPA SMCL for Drinking Water.

Federal November 2018 USEPA Tapwater RSL.

TABLE 9a
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Labadie Creek Upstream			Labadie Creek Downstream			
			AWQC (b)	LBD-C-4BS	LBD-C-5BS	LBD-C-6BS	LBD-C-1BS	LBD-C-2BS	LBD-C-3BS	
				5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018	
Antimony*	7440-36-0	mg/L	0.64							
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0036	0.0036	0.0032	0.0044	0.0045	0.0045	
Barium	7440-39-3	mg/L	NA	0.136	0.136	0.132	0.168	0.17	0.171	
Beryllium*	7440-41-7	mg/L	NA							
Boron	7440-42-8	mg/L	NA	0.0736 J	0.0731 J	0.0711 J	0.0955 J	0.0997 J	0.099 J	
Cadmium	7440-43-9	mg/L	NA					0.00089 J		
Calcium	7440-70-2	mg/L	NA	48.3	47.8	46.7	53.7	54.3	54.7	
Chloride	16887-00-6	mg/L	NA	28.8	28.6	28.6	29.9	30.1	30	
Chromium	7440-47-3	mg/L	NA				0.0013 J	0.0013 J	0.0013 J	
Cobalt	7440-48-4	mg/L	NA		0.00089 J	0.0011 J	0.0016 J	0.0013 J	0.0016 J	
Fluoride	16984-48-8	mg/L	NA	0.24	0.24	0.23	0.27	0.26	0.26	
Lead*	7439-92-1	mg/L	NA							
Lithium*	7439-93-2	mg/L	NA							
Mercury*	7439-97-6	mg/L	NA							
Molybdenum	7439-98-7	mg/L	NA	0.002 J	0.0019 J	0.0019 J	0.0034 J	0.0036 J	0.0036 J	
Selenium*	7782-49-2	mg/L	4.2							
Sulfate	14808-79-8	mg/L	NA	19	19.1	19.1	26.4	25.4	24.8	
Thallium*	7440-28-0	mg/L	0.00047							
Total Hardness as CaCO3	471-34-1	mg/L	NA	225	222	218	237	240	242	
Total Dissolved Solids	TDS	mg/L	NA	309	304	304	350	342	334	

Notes:

- Blank cells - Non-detect value.
- * - Constituent was not detected in any samples.
- AWQC - Ambient Water Quality Criteria.
- CAS - Chemical Abstracts Service.
- J - Estimated value.
- mg/L - milligrams per liter.
- NA - Not Available.
- U - Constituent was not detected.
- USEPA - United States Environmental Protection Agency.
- Detected Concentration > AWQC.
- (a) - Surface water samples collected in May 2018.
- (b) - USEPA National Recommended Water Quality Criteria.
 USEPA Office of Water and Office of Science and Technology.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 USEPA AWQC Human Health for the Consumption of Organism Only
 apply to total concentrations.
- (c) - Value applies to inorganic form of arsenic only.

TABLE 9b
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO HUMAN HEALTH AWQC SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA	Labadie Creek Upstream			Labadie Creek Downstream		
			AWQC (b)	LBD-C-4BS	LBD-C-5BS	LBD-C-6BS	LBD-C-1BS	LBD-C-2BS	LBD-C-3BS
				5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018	5/17/2018
Antimony*	7440-36-0	mg/L	0.64						
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.003	0.003	0.0016	0.0033	0.0036	0.0037
Barium	7440-39-3	mg/L	NA	0.13	0.121	0.09	0.155	0.156	0.156
Beryllium*	7440-41-7	mg/L	NA						
Boron	7440-42-8	mg/L	NA	0.0723 J	0.0797	0.0478 J	0.0995 J	0.098 J	0.097 J
Cadmium*	7440-43-9	mg/L	NA						
Calcium	7440-70-2	mg/L	NA	51	51	61.7	57.8	57.4	57.6
Chromium*	7440-47-3	mg/L	NA						
Cobalt*	7440-48-4	mg/L	NA				0.00098 J		
Lead*	7439-92-1	mg/L	NA						
Lithium*	7439-93-2	mg/L	NA						
Mercury*	7439-97-6	mg/L	NA						
Molybdenum	7439-98-7	mg/L	NA	0.0024 J			0.004 J	0.0039 J	0.0041 J
Selenium*	7782-49-2	mg/L	4.2						
Thallium*	7440-28-0	mg/L	0.00047						

Notes:

Blank cells - Non-detect value.

* - Constituent was not detected in any samples.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.


J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

U - Constituent was not detected.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 9c
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO AWQC SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Labadie Creek					
				Creek Upstream			Creek Downstream		
				LBD-C-4 Total	LBD-C-5 Total	LBD-C-6 Total	LBD-C-1 Total	LBD-C-2 Total	LBD-C-3 Total
Antimony*	7440-36-0	mg/L	0.64						
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0056	0.0055	0.0061	0.0065	0.0061	0.0066
Barium	7440-39-3	mg/L	NA	0.124	0.122	0.125	0.161	0.164	0.172
Beryllium*	7440-41-7	mg/L	NA						
Boron	7440-42-8	mg/L	NA	0.166	0.164	0.167	0.0978	0.0959	0.0999
Cadmium*	7440-43-9	mg/L	NA						
Calcium	7440-70-2	mg/L	NA	65.6	64.4	65.7	56.1	55.4	57.7
Chromium	7440-47-3	mg/L	NA				0.0026 J	0.0027 J	0.0031 J
Cobalt*	7440-48-4	mg/L	NA						
Fluoride*	16984-48-8	mg/L	NA						
Lead	7439-92-1	mg/L	NA	0.00014 J	0.00013 J	0.0002 J	0.0017	0.0018	0.0021
Mercury*	7439-97-6	mg/L	NA						
Molybdenum	7439-98-7	mg/L	NA	0.0029 J	0.0024 J	0.0024 J	0.0092 J	0.0055 J	0.0046 J
Selenium*	7782-49-2	mg/L	4.2						
Sulfate	14808-79-8	mg/L	NA	17.8 J	17.6 J	16.6 J	19.4 J	16.3 J	15.3 J
Thallium*	7440-28-0	mg/L	0.00047						
Total Hardness as CaCO3	471-34-1	mg/L	NA	291	286	291	249	246	256

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in October 2013.

(b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology. Accessed November 2014.
<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 9d
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO AWQC SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	USEPA AWQC (b)	Labadie Creek Creek Upstream			Labadie Creek Creek Downstream		
				LBD-C-4 Filtered	LBD-C-5 Filtered	LBD-C-6 Filtered	LBD-C-1 Filtered	LBD-C-2 Filtered	LBD-C-3 Filtered
				Antimony*	7440-36-0	mg/L	0.64		
Arsenic	7440-38-2	mg/L	0.00014 (c)	0.0056	0.0051	0.0051	0.0039	0.0039	0.0043
Barium	7440-39-3	mg/L	NA	0.116	0.118	0.12	0.141	0.145	0.146
Beryllium*	7440-41-7	mg/L	NA						
Boron	7440-42-8	mg/L	NA	0.165	0.169	0.17	0.108	0.1	0.0994
Cadmium*	7440-43-9	mg/L	NA						
Calcium (f)	7440-70-2	mg/L	NA	--	--	--	--	--	--
Chromium*	7440-47-3	mg/L	NA						
Cobalt*	7440-48-4	mg/L	NA						
Fluoride	16984-48-8	mg/L	NA	--	--	--	--	--	--
Lead	7439-92-1	mg/L	NA				0.0001 J		
Mercury*	7439-97-6	mg/L	NA						
Molybdenum	7439-98-7	mg/L	NA	0.0018 J	0.0022 J	0.002 J	0.0036 J	0.0031 J	0.003 J
Selenium	7782-49-2	mg/L	4.2						
Sulfate	14808-79-8	mg/L	NA	--	--	--	--	--	--
Thallium*	7440-28-0	mg/L	0.00047						
Total Hardness as CaCO3 (f)	471-34-1	mg/L	NA	--	--	--	--	--	--

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

AWQC - Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration > AWQC.

(a) - Surface water samples collected in October 2013.

(b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology. Accessed November 2014.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

USEPA AWQC Human Health for the Consumption of Organism Only apply to total concentrations.

(c) - Value applies to inorganic form of arsenic only.

TABLE 10a
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Labadie Creek Upstream			Labadie Creek Downstream		
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	LBD-C-4BS 5/17/2018	LBD-C-5BS 5/17/2018	LBD-C-6BS 5/17/2018	LBD-C-1BS 5/17/2018	LBD-C-2BS 5/17/2018	LBD-C-3BS 5/17/2018
Antimony*	7440-36-0	mg/L	NA	NA						
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0036	0.0036	0.0032	0.0044	0.0045	0.0045
Barium	7440-39-3	mg/L	NA	NA	0.136	0.136	0.132	0.168	0.17	0.171
Beryllium*	7440-41-7	mg/L	NA	NA						
Boron	7440-42-8	mg/L	NA	NA	0.0736 J	0.0731 J	0.0711 J	0.0955 J	0.0997 J	0.099 J
Cadmium	7440-43-9	mg/L	0.0043 (d)	0.0015 (d)					0.00089 J	
Calcium	7440-70-2	mg/L	NA	NA	48.3	47.8	46.7	53.7	54.3	54.7
Chloride	16887-00-6	mg/L	860	230	28.8	28.6	28.6	29.9	30.1	30
Chromium	7440-47-3	mg/L	3.6 (c,d)	0.17 (c,d)				0.0013 J	0.0013 J	0.0013 J
Cobalt	7440-48-4	mg/L	NA	NA		0.00089 J	0.0011 J	0.0016 J	0.0013 J	0.0016 J
Fluoride	16984-48-8	mg/L	NA	NA	0.24	0.24	0.23	0.27	0.26	0.26
Lead*	7439-92-1	mg/L	0.24 (d)	0.0092 (d)						
Lithium*	7439-93-2	mg/L	NA	NA						
Mercury*	7439-97-6	mg/L	0.0016	0.00091						
Molybdenum	7439-98-7	mg/L	NA	NA	0.002 J	0.0019 J	0.0019 J	0.0034 J	0.0036 J	0.0036 J
Selenium*	7782-49-2	mg/L	NA	3.1						
Sulfate	14808-79-8	mg/L	NA	NA	19	19.1	19.1	26.4	25.4	24.8
Thallium*	7440-28-0	mg/L	NA	NA						
Total Hardness as CaCO3	471-34-1	mg/L	NA	NA	225	222	218	237	240	242
Total Dissolved Solids	TDS	mg/L	NA	NA	309	304	304	350	342	334

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

mg/L - milligrams per liter.

AWQC - USEPA Ambient Water Quality Criteria.

NA - Not Analyzed/Not Available.

CAS - Chemical Abstracts Service.

U - Constituent was not detected.

J - Estimated value.

USEPA - United States Environmental Protection Agency.

Detected Concentration> USEPA Aquatic Life AWQC Chronic.

Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness - see note (d).

USEPA provides AWQC for both total and dissolved results.

(c) - Value for trivalent chromium used.

(d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for Labadie Creek of 231 mg/L as CaCO3 used.

TABLE 10b
COMPARISON OF MAY 2018 LABADIE CREEK SURFACE WATER RESULTS
TO ECOLOGICAL SCREENING LEVELS - DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Labadie Creek Upstream			Labadie Creek Downstream		
			USEPA Aquatic Life AWQC Freshwater Acute (c)	USEPA Aquatic Life AWQC Freshwater Chronic (c)	LBD-C-4BS 5/17/2018	LBD-C-5BS 5/17/2018	LBD-C-6BS 5/17/2018	LBD-C-1BS 5/17/2018	LBD-C-2BS 5/17/2018	LBD-C-3BS 5/17/2018
Antimony*	7440-36-0	mg/L	NA	NA						
Arsenic	7440-38-2	mg/L	0.34	0.15	0.003	0.003	0.0016	0.0033	0.0036	0.0037
Barium	7440-39-3	mg/L	NA	NA	0.13	0.121	0.09	0.155	0.156	0.156
Beryllium*	7440-41-7	mg/L	NA	NA						
Boron	7440-42-8	mg/L	NA	NA	0.0723 J	0.0797	0.0478 J	0.0995 J	0.098 J	0.097 J
Cadmium*	7440-43-9	mg/L	0.0039 (d)	0.0013 (d)						
Calcium	7440-70-2	mg/L	NA	NA	51	51	61.7	57.8	57.4	57.6
Chromium*	7440-47-3	mg/L	1.1 (c,d)	0.15 (c,d)						
Cobalt*	7440-48-4	mg/L	NA	NA				0.00098 J		
Lead*	7439-92-1	mg/L	0.16 (d)	0.0062 (d)						
Lithium*	7439-93-2	mg/L	NA	NA						
Mercury*	7439-97-6	mg/L	0.0014	0.00077						
Molybdenum	7439-98-7	mg/L	NA	NA	0.0024 J			0.004 J	0.0039 J	0.0041 J
Selenium*	7782-49-2	mg/L	NA	NA						
Thallium*	7440-28-0	mg/L	NA	NA						

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

AWQC - USEPA Ambient Water Quality Criteria.

CAS - Chemical Abstracts Service.

J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

U - Constituent was not detected.

USEPA - United States Environmental Protection Agency.

Detected Concentration > USEPA Aquatic Life AWQC Chronic.
 Detected Concentration > USEPA Aquatic Life AWQC Acute and Chronic.

(a) - Surface water samples collected in May 2018.

(b) - USEPA National Recommended Water Quality Criteria.

USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness - see note (d).

USEPA provides AWQC for both total and dissolved results.

(c) - Value for trivalent chromium used.

(d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for Labadie Creek of 231 mg/L as CaCO3 used.

TABLE 10c
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS - TOTAL (UNFILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Labadie Creek						
			USEPA Aquatic Life AWQC Freshwater	USEPA Aquatic Life AWQC Freshwater	Creek Upstream			Creek Downstream			
					LBD-C-4 Total	LBD-C-5 Total	LBD-C-6 Total	LBD-C-1 Total	LBD-C-2 Total	LBD-C-3 Total	
Antimony*	7440-36-0	mg/L	NA	NA							
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0056	0.0055	0.0061	0.0065	0.0061	0.0066	
Barium	7440-39-3	mg/L	NA	NA	0.124	0.122	0.125	0.161	0.164	0.172	
Beryllium*	7440-41-7	mg/L	NA	NA							
Boron	7440-42-8	mg/L	NA	NA	0.166	0.164	0.167	0.0978	0.0959	0.0999	
Cadmium*	7440-43-9	mg/L	0.0050 (g)	0.0017 (g)							
Calcium (h)	7440-70-2	mg/L	NA	NA	65.6	64.4	65.7	56.1	55.4	57.7	
Chromium	7440-47-3	mg/L	4.1 (e,q)	0.19 (e,q)				0.0026 J	0.0027 J	0.0031 J	
Cobalt*	7440-48-4	mg/L	NA	NA							
Fluoride*	16984-48-8	mg/L	NA	NA							
Lead	7439-92-1	mg/L	0.29 (g)	0.011 (g)	0.00014 J	0.00013 J	0.0002 J	0.0017	0.0018	0.0021	
Mercury*	7439-97-6	mg/L	0.0016	0.00091							
Molybdenum	7439-98-7	mg/L	NA	NA	0.0029 J	0.0024 J	0.0024 J	0.0092 J	0.0055 J	0.0046 J	
Selenium*	7782-49-2	mg/L	NA	3.1							
Sulfate	14808-79-8	mg/L	NA	NA	17.8 J	17.6 J	16.6 J	19.4 J	16.3 J	15.3 J	
Thallium*	7440-28-0	mg/L	NA	NA							
Total Hardness as CaCO3 (h)	471-34-1	mg/L	NA	NA	291	286	291	249	246	256	

Notes:
 Blank cells - Non-detect value. J - Estimated value.
 * Constituent was not detected in any samples. mg/L - milligrams per liter.
 -- - Constituent not included in this analysis. NA - Not Available.
 AWQC - USEPA Ambient Water Quality Criteria. USEPA - United States Environmental Protection Agency.
 CAS - Chemical Abstracts Service.

 Detected Concentration> USEPA Aquatic Life AWQC Chronic.
 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

- (a) - Surface water samples collected in October 2013.
- (b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology. <http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>
 Total values provided. Values adjusted for site-specific hardness - see note (d).
 USEPA provides AWQC for both total and dissolved results.
- (c) - Value for trivalent chromium used.
- (d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for Labadie Creek of 270 mg/L as CaCO3 used.

TABLE 10d
COMPARISON OF OCTOBER 2013 LABADIE CREEK SURFACE WATER RESULTS TO ECOLOGICAL SCREENING LEVELS
- DISSOLVED (FILTERED) SAMPLE RESULTS (a)
AMEREN MISSOURI LABADIE ENERGY CENTER
FRANKLIN COUNTY, MISSOURI

Constituent	CAS	Units	Federal Water Quality Criteria		Labadie Creek			Labadie Creek		
			USEPA Aquatic Life AWQC Freshwater Acute (b)	USEPA Aquatic Life AWQC Freshwater Chronic (b)	Creek Upstream			Creek Downstream		
					LBD-C-4 Filtered	LBD-C-5 Filtered	LBD-C-6 Filtered	LBD-C-1 Filtered	LBD-C-2 Filtered	LBD-C-3 Filtered
Antimony*	7440-36-0	mg/L	NA	NA						
Arsenic	7440-38-2	mg/L	0.34	0.15	0.0056	0.0051	0.0051	0.0039	0.0039	0.0043
Barium	7440-39-3	mg/L	NA	NA	0.116	0.118	0.12	0.141	0.145	0.146
Beryllium*	7440-41-7	mg/L	NA	NA						
Boron	7440-42-8	mg/L	NA	NA	0.165	0.169	0.17	0.108	0.1	0.0994
Cadmium*	7440-43-9	mg/L	0.0045 (d)	0.0015 (d)						
Calcium	7440-70-2	mg/L	NA	NA	--	--	--	--	--	--
Chromium*	7440-47-3	mg/L	1.3 (c,d)	0.17 (c,d)						
Cobalt*	7440-48-4	mg/L	NA	NA						
Fluoride	16984-48-8	mg/L	NA	NA	--	--	--	--	--	--
Lead	7439-92-1	mg/L	0.19 (d)	0.0073 (d)				0.0001 J		
Mercury*	7439-97-6	mg/L	0.0014	0.00077						
Molybdenum	7439-98-7	mg/L	NA	NA	0.0018 J	0.0022 J	0.002 J	0.0036 J	0.0031 J	0.003 J
Selenium	7782-49-2	mg/L	NA	NA						
Sulfate	14808-79-8	mg/L	NA	NA	--	--	--	--	--	--
Thallium*	7440-28-0	mg/L	NA	NA						
Total Hardness as CaCO3	HARDNESS	mg/L	NA	NA	--	--	--	--	--	--

Notes:

Blank cells - Non-detect value.

* Constituent was not detected in any samples.

-- - Constituent not included in this analysis.

AWQC - USEPA Ambient Water Quality Criteria.


CAS - Chemical Abstracts Service.


J - Estimated value.

mg/L - milligrams per liter.

NA - Not Available.

USEPA - United States Environmental Protection Agency.

 Detected Concentration> USEPA Aquatic Life AWQC Chronic.

 Detected Concentration> USEPA Aquatic Life AWQC Acute and Chronic.

(a) - Surface water samples collected in October 2013.

(b) - USEPA National Recommended Water Quality Criteria. USEPA Office of Water and Office of Science and Technology.

<http://water.epa.gov/scitech/swguidance/standards/criteria/current/index.cfm>

Total values provided. Values adjusted for site-specific hardness - see note (d).

USEPA provides AWQC for both total and dissolved results.

(c) - Value for trivalent chromium used.

(d) - Hardness dependent value for total metals. Site-specific total recoverable mean hardness value for Labadie Creek of 270 mg/L as CaCO3 used.

**TABLE 11
COMPARISON OF BLUFF AREA GROUNDWATER MONITORING RESULTS TO HUMAN HEALTH DRINKING WATER SCREENING LEVELS (a)
LABADIE ENERGY CENTER, FRANKLIN COUNTY, MO
AMEREN MISSOURI**

Monitoring Well ID (e)	Date	Boron mg/L	Calcium mg/L	Chloride mg/L	Fluoride mg/L	Sulfate mg/L	Antimony mg/L	Arsenic mg/L	Barium mg/L	Beryllium mg/L	Cadmium mg/L	Chromium mg/L	Cobalt mg/L	Lead mg/L	Mercury mg/L	Molybdenum mg/L	Selenium mg/L	Thallium mg/L
MCL (b)		NA	NA	NA	4	NA	0.006	0.01	2	0.004	0.005	0.1	NA	0.015	0.002	NA	0.05	0.002
SMCL (b)		NA	NA	250	2	250	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
RSL (c)		4	NA	NA	0.8	NA	0.0078	0.000052	3.8	0.025	0.0092	22	0.006	0.015	0.0057	0.1	0.1	0.0002
Selected Drinking Water Screening Level (d)		4	NA	250	4	250	0.006	0.01	2	0.004	0.005	0.1	0.006	0.015	0.002	0.1	0.05	0.002
TGP-A	Apr-12			5.8	0.2	13			0.21			0.0029	--	0.0031		--		
	Mar-14	0.0094	70.9	--		15.3		0.00087	0.211			0.0034		0.00062		0.002	0.00064	
	Sep-14	0.009	69.4	--		15.1		0.0011	0.216			0.0036		0.00055	0.000063		0.00062	
DUP-1 (f)	Apr-12			5.7	0.18	14			0.22			0.0034	--	0.0037		--		
	Mar-14		71.2	--		15.4		0.00085	0.214			0.0048		0.0005			0.00062	
TGP-B	Apr-12			29	0.25	25	0.0026		0.1			0.0025	--	0.0036		--		
	Mar-14	0.0164	77.6	--		22.5		0.0021	0.106			0.0029		0.00015		0.0024		
	Sep-14	0.0168	73.8	--	0.34	23.2		0.00089	0.105			0.0027				0.0021		
DUP-1 (g)	Sep-14	0.0159	72.4	--		23.7		0.00095	0.102			0.0029			0.000097			
TGP-C	Apr-12			43	0.16	34			0.15			0.0013	--	0.0044		--		
	Mar-14	0.0088	79.1	--		27.8		0.00082	0.177					0.0011			0.00087	
	Sep-14	0.0531	73.9	--		28.8		0.00088	0.202			0.0022		0.0013			0.0012	
TGP-D	Mar-14	0.0144	72.0	--		14.1			0.147			0.0017		0.00015		0.002	0.0012	
	Sep-14	0.0114	66.4	--		15.9			0.151					0.00027			0.0013	
TGP-E	Mar-14	0.0465	79.5	--		21.8		0.0016	0.122					0.00016		0.0022		
	Sep-14	0.0399	77.2	--	0.34	23.1			0.127			0.0016						
TGP-F	Sep-14	0.113	76.2	--	0.3	25.2		0.0061	0.111			0.0029		0.0036		0.002	0.00072	
TGP-G	Sep-14	0.0063	93.6	--	0.32	27.7		0.00088	0.114			0.0029				0.0032		

Notes:

-- Constituent not sampled.

Blank data cells indicate a non-detect value.

HI - Hazard Index.

MCL - Maximum Contaminant Level.

mg/L - Milligrams per liter.

NA - Not available.

RSL - Regional Screening Level.

SMCL - Secondary Maximum Contaminant Level. Value used if no MCL available.

USEPA - United States Environmental Protection Agency.

(a) - Numerical values were obtained from the Ameren Missouri Labadie Energy Center Utility Waste Landfill, Solid Waste Disposal Area, Franklin County, Missouri,

Solid Waste Disposal Area, Franklin County, Laboratory Analytical Results for Groundwater Monitoring Samples Collected on April 12-13, 2012, March 12th and 25th, 2014, and

September 3rd through October 6th 2014 from Temporary Groundwater Piezometers Installed Near Labadie Plant.

(b) - USEPA 2018 Edition of the Drinking Water Standards and Health Advisories.

<https://www.epa.gov/dwstandardsregulations/2018-drinking-water-standards-and-advisory-tables>

(c) - USEPA Regional Screening Levels (November 2018). Values for tapwater. HI = 1.

<https://www.epa.gov/risk/regional-screening-levels-rsls-generic-tables>

(d) - Selected Drinking Water Screening Level uses the following hierarchy:

Federal USEPA MCL for Drinking Water.

Federal USEPA SMCL for Drinking Water.

Federal November 2018 USEPA Tapwater RSL.

(e) - Piezometers are screened in bedrock.

(f) - Duplicate sample from TGP-A.

(g) - Duplicate sample from TGP-B.

 Detected Concentration > Selected Drinking Water Screening Level.

APPENDIX B

What You Need to Know About Molybdenum

WHAT YOU NEED TO KNOW ABOUT MOLYBDENUM

Molybdenum is the one constituent that is present in at least one groundwater sample at each of the four Ameren energy centers in Missouri above the screening level used by the U.S. Environmental Protection Agency (USEPA) under the Coal Combustion Residuals (CCR) Rule. The purpose of this fact sheet is to provide information on molybdenum so that data can be considered in context. There is no public exposure to groundwater at the Ameren energy centers and concentration levels of molybdenum in adjacent surface waters are all well below health-based regulatory standards.

SOURCES OF INFORMATION ON MOLYBDENUM

Molybdenum had been evaluated by regulatory and health agencies in the U.S. As discussed below, molybdenum is an essential nutrient for humans, and the Institute of Medicine of the U.S. National Academy of Sciences (NAS) has provided recommended daily allowances and tolerable upper limits to be used as guidelines for vitamins and supplements and other exposures (NAS, 2001).

The Agency for Toxic Substances and Disease Registry (ATSDR) is a federal public health agency within the U.S. Department of Health and Human Services. The ATSDR Toxicological Profile for Molybdenum (ATSDR, 2017) provides a comprehensive summary and interpretation of available toxicological and epidemiological information on molybdenum and provides information on the naturally occurring levels in our environment and in our diet.

The U.S. Environmental Protection Agency (USEPA) published an oral toxicity value for molybdenum in 1992 (USEPA, 1992); this value serves as the basis for the tapwater screening level for molybdenum of 0.1 milligrams per liter (mg/L) or 100 micrograms per liter (ug/L) that was included in the Phase 1 Part update to the CCR Rule (USEPA, 2018a).

MOLYBDENUM IS NATURALLY OCCURRING AND AN ESSENTIAL NUTRIENT FOR PLANTS AND HUMANS

Molybdenum is a naturally occurring trace element that can be found extensively in nature. Biologically, molybdenum plays an important role as a micronutrient in plants and animals, including humans.

Molybdenum in Our Natural Environment

Molybdenum naturally accumulates in poorly drained soils and soils with high organic content (for example, peat bogs and wetlands). It is also present at high concentrations in “black shales,” which are shale deposits with high organic content. The U.S. Geological Survey (USGS, 2013) reports that the average concentration in U.S. soils is approximately 1 milligram per kilogram of soil (mg/kg). USGS (2011) estimates the median concentration of molybdenum in groundwater is 0.001 milligrams per liter (mg/L), with most concentrations below 0.008 mg/L.

Molybdenum in Our Diet

Molybdenum is considered an essential nutrient or trace element for living beings. It is required in several mammalian enzyme systems and is present in most adult multi-vitamins. A deficiency syndrome has only been seen in people with a genetic defect that prevents the synthesis of a specific enzyme for which molybdenum is a cofactor. The deficiency leads to severe neurological damage and early death.

Because it is present in soils, it is also present in our diet. Food derived from above ground plants, such as legumes, leafy vegetables, and cauliflower generally has a relatively higher concentration of molybdenum in comparison to food from tubers or animals. Beans, cereal grains, leafy vegetables, legumes, liver, and milk are reported as the richest sources of molybdenum in the average diet (ATSDR, 2017). The amount of molybdenum in plants varies according to the amount in the soil. The National Academy of Sciences (NAS) has estimated that the average dietary intakes of molybdenum by adult men and women are 0.109 and 0.076 milligrams per day (mg/day), respectively. A study of the dietary intake of adult residents in Denver, Colorado reported a mean molybdenum ingestion rate of 180 µg/day (range 120–240 µg/day) (ATSDR, 2017).

Molybdenum for Health

How Much Do You Need - Daily Allowance:

The Institute of Medicine of the NAS sets dietary intake values for essential nutrients. The recommended dietary allowance (RDA) for a nutrient is “the average daily dietary nutrient intake level sufficient to meet the nutrient requirement of nearly all (97 to 98 percent) health individuals” (NAS, 2001). The RDA for molybdenum for adults set by the NAS in 2001 is 0.045 milligram per day (mg/day) and is based on the amount of molybdenum needed to achieve a steady healthy balance in the body for the majority of the population.

How Much is Too Much - Upper Limits:

In addition to the RDA, the NAS also defines a Tolerable Upper Intake Level (UL) for essential nutrients. The UL is “the highest average daily nutrient intake level that is likely to pose no risk of adverse health effects to almost all individuals in the general population.” Thus, the RDA is a level that is considered to be sufficient for the health of the general population, while intake can be as high as the UL and pose no adverse health effects.

The UL for molybdenum set by the NAS is 2 mg/day. This level is based on an evaluation of the potential toxicity of molybdenum at high levels of intake. The most sensitive effect in the literature is associated with reproductive outcomes in rats, and the study was used to develop an oral toxicity value for humans of 0.03 milligrams of molybdenum ingested per day per kilogram of body weight (mg/kg-day). This value is used with an average adult body weight of 68-70 kg (154 lbs) to set the UL¹.

¹ The oral toxicity value identifies a level of intake in terms of milligrams of constituent per kilogram of body weight per day (mg/kg-day) that is considered to be safe for daily exposure for a lifetime. The oral toxicity value is used to calculate a safe drinking water level as follows: if the oral toxicity value is 0.03 mg/kg-day, and a 70 kg adult that consumes 2 liters of water per day, then the safe drinking water level = (0.03 mg/kg-day) x (70 kg) ÷ (2 liters water/day) = 1.05 milligrams per liter (mg/L).

USEPA'S ORAL TOXICITY VALUE FOR MOLYBDENUM

USEPA developed a lower oral toxicity value for molybdenum of 0.005 mg/kg-day (USEPA, 1992) based on a 1962 study of a small population (52 exposure subjects) in Armenia that had a high level of molybdenum in their diet. This population had high levels of uric acid and experienced gout. The findings from the Armenian study have not been replicated, and other regulatory bodies such as the NAS and ATSDR have rejected the study due to its many deficiencies. [It is likely that the observance of gout in the Armenian population had some other cause.]

The NAS concluded that there were “serious methodological difficulties with the [Armenian] study” and noted that no other studies in humans or animals have replicated this effect. The NAS toxicity value is 0.03 mg/kg-day, six-fold higher than the USEPA value. Based on the NAS toxicity value and USEPA assumptions (for body weight and drinking water intake) results in a calculated safe drinking water level of 0.6 mg/L or 600 ug/L.

ATSDR noted the study of the Armenian population was not considered suitable for derivation of a chronic-duration oral toxicity value for molybdenum due to deficiencies in the control group size and composition, and a lack of controlling for confounders, such as diet and alcohol, that could affect the results. ATSDR developed an oral toxicity value of 0.008 mg/kg-day, using the same study reproductive outcomes in rats as the NAS, but applying different assumptions, most notably a 3-fold higher uncertainty factor. Based on the ATSDR toxicity value and USEPA assumptions (for body weight and drinking water intake) results in a calculated safe drinking water level of 0.16 mg/L or 160 ug/L.

MOLYBDENUM UNDER THE CCR RULE

When the CCR Rule was published in 2015, groundwater standards were provided only for those Appendix IV constituents that have primary drinking water standards published by the USEPA under the Safe Drinking Water Act – values known as MCLs or maximum contaminant levels. Molybdenum does not have an MCL². In a subsequent 2018 CCR rule-making, USEPA designated a health-based groundwater protection standard for molybdenum of 0.1 mg/L or 100 ug/L. That is the value used to evaluate groundwater at the Ameren facilities. This level is very conservative and could be much higher and still protective of human health, as described above. [Note that in its March 3, 2019 report the Environmental Integrity Project used a screening level for molybdenum of 0.04 mg/L (or 40 ug/L), which is not the level USEPA has required in the CCR Rule.]

However, based on the USEPA toxicity value, the drinking water levels USEPA has developed for molybdenum are:

² USEPA is in the process of gathering information on the occurrence of molybdenum in public drinking water systems. The decision to develop an MCL (which is a multi-year process) is based on occurrence in public drinking water systems, the severity of adverse health effects, whether the constituent is present in public drinking water systems at levels of public health concern, and whether regulation would provide a meaningful opportunity for health risk reduction. No decision has yet been made as to whether molybdenum will be a candidate for the development of a drinking standard. Note that when USEPA included molybdenum for public water supply testing, it cited USEPA 1992, ATSDR 2017, and NAS 2001 as toxicity references. No mention was made of the differences in toxicity studies used or the values developed.

- 0.1 mg/L – The USEPA tapwater value in its Regional Screening Level (RSL) table and the value identified by USEPA for the CCR Rule (USEPA, 2018b). This is the value USEPA uses in the CCR Rule (USEPA, 2018a).
- 0.2 mg/L – The USEPA Office of Water value for the Drinking Water Equivalent Level (DWEL), which is a *lifetime exposure* concentration protective of adverse, non-cancer health effects, that assumes all of the exposure to a constituent is from drinking water (USEPA, 2018c).
- 0.04 mg/L – The USEPA Office of Water value for the Health Advisory Level (HA), which is based on the DWEL, but using a default assumption that only 20% of intake can come from water (USEPA, 2018c).

Therefore, drinking water concentrations of molybdenum up to 0.2 mg/L to are expected to be **without** adverse health effects. Based on the NAS review, daily exposure to drinking water concentrations of molybdenum up to 0.6 mg/L would be **without** adverse health effects.

WHAT THIS MEANS FOR THE AMEREN ENERGY CENTERS

This information from the NAS has been used to evaluate the levels of molybdenum in groundwater at the Ameren Energy Centers and in nearby surface waters. A total of 930 groundwater and surface water samples were collected from the four energy centers. The concentration levels in approximately 866 samples were below the screening level based on the National Academy of Science Tolerable Upper Intake Level (UL), while 241 are above the GWPS established by USEPA in the CCR Rule.

	Labadie	Meramec	Rush Island	Sioux
Groundwater				
Number of Samples	208	88	77	244
Molybdenum greater than CCR GWPS of 0.1 mg/L (a)	81	35	38	77
Molybdenum greater than NAS standard of 0.6 mg/L (b)	3	1	11	49
Surface Water				
Number of Samples	67	74	50	80
Molybdenum greater than 0.1 mg/L (a)	0	0	0	0

Notes:

mg/L - milligrams per liter.

(a) - Drinking water-based groundwater protection standard specified in the Coal Combustion Residuals Rule.

(b) - Alternative health-protective drinking water screening level based on the National Academy of Sciences review of molybdenum.

The groundwater results were collected from monitoring wells placed as close as practical to the ash basins’ boundaries and provide near-source groundwater monitoring results. The groundwater downgradient of each of the Ameren ash basins is not used as a source of drinking water. Deep bedrock groundwater used as drinking water in the vicinity of Labadie and in the vicinity of Rush Island was sampled and demonstrated no impacts from CCR.

Surface water adjacent to each of the energy centers was sampled and all results for molybdenum in surface water are well below the USEPA drinking water screening level of 0.1 mg/L.

Thus, although there are some results for molybdenum in groundwater that are above the USEPA drinking water screening level, the groundwater at these facilities is not used as a source of drinking water, and molybdenum is not present in any of the adjacent water bodies above the drinking water screening level. These results confirm that molybdenum does not pose a risk to human health or the environment at any of the Ameren facilities.

REFERENCES

ATSDR. 2017. Toxicological Profile for Molybdenum. Agency for Toxic Substances and Disease Registry, U.S. Department of Health and Human Services. Available at: <https://www.atsdr.cdc.gov/ToxProfiles/tp.asp?id=1482&tid=289>

NAS. 2001. Dietary Reference Intakes for Vitamin A, Vitamin K, Arsenic, Boron, Chromium, Copper, Iodine, Iron, Manganese, Molybdenum, Nickel, Silicon, Vanadium, and Zinc. Institute of Medicine. National Academy of Sciences. 2001. National Academy Press. Available at: <http://www.nap.edu/catalog/10026.html>

USEPA. 1992. Chemical Assessment Summary for Molybdenum. Integrated Risk Information System (IRIS). National Center for Environmental Assessment. U.S. Environmental Protection Agency. Available at: https://cfpub.epa.gov/ncea/iris2/chemicalLanding.cfm?&substance_nmbr=425

USEPA. 2018a. Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals from Electric Utilities; Amendments to the National Minimum Criteria (Phase One, Part One). Available at: <https://www.federalregister.gov/documents/2018/07/30/2018-16262/hazardous-and-solid-waste-management-system-disposal-of-coal-combustion-residuals-from-electric>

USEPA. 2018b. USEPA Regional Screening Levels. U.S. Environmental Protection Agency. Available at: <https://www.epa.gov/risk/regional-screening-levels-rsls>

USEPA. 2018c. 2018 Edition of the Drinking Water Standards and Health Advisories. March 2018. EPA 822-F-18-001. Office of Water. U.S. Environmental Protection Agency Washington, DC. Available at: <https://www.epa.gov/sites/production/files/2018-03/documents/dwtable2018.pdf>

USGS. 2011. Trace Elements National Synthesis Project: Trace Elements and Radon in Groundwater Across the United States, 1992-2003. U.S. Department of the Interior. U.S. Geological Survey (USGS). Scientific Investigations Report 2011-5059. Available at: <https://water.usgs.gov/nawqa/trace/pubs/sir2011-5059/index.html>

USGS. 2013. Geochemical and mineralogical data for soils of the conterminous United States: U.S. Geological Survey Data Series 801, 19 p. Available at: <http://pubs.usgs.gov/ds/801/>

APPENDIX C

Extraction and Transportation Study

ADDENDUM

Meramec, Labadie and Sioux Ash Pond Closure: Extraction and Transportation Assessment

Lochmueller Group applied the methodology from the Extraction and Transportation Study for the Rush Island Energy Center to develop high-level estimates of the costs and timeframes associated with hypothetical CCR excavation processes at the Labadie, Sioux and Meramec Energy Centers. Specifically, the formula used to estimate daily productivity (i.e. number of trucks hauling excavated material offsite) was adapted for use at Labadie, Sioux and Meramec along with site-specific considerations.

Estimates from the Rush Island Study assumed a maximum of 192 truck loads per day over an 8-hour work day (24 per hour), with 155 to 193 days of annual operation. Once loaded, trucks would make multiple roundtrips to the closest available commercial landfill. Such estimates assume that the excavation, staging, and loading process is capable of accommodating a steady stream of trucks loading **every 2.5 minutes** and that such material can be quickly unloaded at the receiving commercial landfill without significant delay. While such productivity rates are undoubtedly optimistic, the resulting estimates nevertheless are useful in capturing the enormity of such projects and are sufficient at a planning-level.

It is important to note that the existing onsite utility waste landfills (UWLs) at Labadie and Sioux were designed and permitted to manage production needs of the energy centers through each facility's retirement date. To facilitate permanent storage, excavated CCR material would need to be transported offsite to a commercial landfill or Ameren Missouri would need to permit and construct new onsite landfills. Given the absence of an existing utility waste landfill at Meramec, onsite disposal options were considered for the Labadie and Sioux locations only.

Each facility presents unique challenges that are likely to impact cost estimates and closure times beyond the scope of this assessment. For example, the regulatory process for construction of an onsite landfill would require multiple levels of approval, including environmental permits, zoning or land use authorization, and potentially a certificate of issuance from the Missouri Public Service Commission. Opposition to such projects may further delay the regulatory approval process such that it would be years *before* construction could commence.¹

¹ Efforts to permit and construct the Labadie UWL commenced in 2008 with the completion of Preliminary Site Investigation (PSI). The landfill was placed in service in 2016 after years of opposition from environmental groups and litigation. *See* *Petition for Writ of Certiorari [to invalidate county landfill ordinance] Franklin County Circ. Ct., 11/23/11, Case # 11AB-C286; Appeal to Franklin County Board of Adjustment, #14-00002, Filed 1/8/14 (of Land Use Administrator 10/10/13 and 12/10/13 Decisions), Denied by BZA 6/24/14; Appealed to Circ. Ct. by Writ of Certiorari, Cause # 14AB-CC00155, 7/24/14; Intervention and Motion to Dismiss in PSC Case EA 2012-0281, Ameren Application to PSC for CCN to operate landfill (PSC overruled Motion to Dismiss on 4/17/13); Administrative Hearing Commission Petition for Review [of MDNR Solid Waste Disposal Construction Permit], Filed 1-30-15, #15-0136, dismissed by AHC 3/5/15. *See also* *Campbell v. County Commission of Franklin County, 453 S.W.3d 762 (Mo. banc 2015).**

May 13, 2019

Page 2

Based on experience, it would be virtually impossible to sustain productivity at the planning level rate over extended, multi-year timeframe due to a variety of unpredictable factors. Excavation activities could be limited or precluded for several days following weather events. Other potential disruptions could include:

- loading equipment failure
- site restrictions that limit the number of excavation equipment
- traffic congestion on travel route
- truck breakdown
- staffing
- weather conditions
- commercial landfill available capacity in Illinois and Missouri
- landfill unloading equipment failure

In addition, site specific conditions can impact productivity. For example, an elementary school is located along Fine Road between the Meramec Energy Center and Telegraph Road. To accommodate local safety concerns, the hauling company would likely limit trips during the beginning and end of the school day, thereby limiting effective hauling hours to 5-6 per day during the school year.

Route 94 east of the Sioux Energy Center travels beneath multiple narrow, low-clearance railroad overpasses in the West Alton area. An entirely new roadway by-passing West Alton would avoid the railroad entirely, but would require regulatory approvals, land acquisition, and potentially eminent domain. Assumptions were adjusted to account for these impacts, but it is not possible to foresee every challenge and quantify every impact likely to surface.

Scenarios:

The following summarizes the assessment of five scenarios for CCR removal for the Meramec, Labadie and the Sioux Energy Centers. The assessment utilized the same methodology, assumptions, and unit costing information as for Rush Island. The volume of ash, hauling distances, and the anticipated infrastructure upgrades were adjusted for each site.

For each scenario, the total volume of excavated ash, total cost of removal, and closure duration are summarized. The reported volume of ash incorporates a swell factor. The closure duration is measured from the time the decision is made to close the ponds (i.e. removal from service) until such time that the CCR material is fully removed. It was assumed that 5 years of preparation time would be needed in advance of starting an offsite removal operation, whereas an onsite removal operation would require 10 years of preparation time to account for the regulatory process to secure approvals for construction of new onsite landfills.

The five scenarios are as follows:

1. Labadie Bottom Ash and Fly Ash Pond CCR Removal to an Offsite Landfill
2. Labadie Bottom Ash and Fly Ash Pond CCR Removal to an Onsite Landfill

3. Sioux Bottom Ash and Fly Ash Pond CCR Removal to an Offsite Landfill
4. Sioux Bottom Ash and Fly Ash Pond CCR Removal to an Onsite Landfill
5. Meramec Bottom Ash and Fly Ash Pond CCR Removal to an Offsite Landfill

Scenario 1: Offsite CCR Removal for Labadie

This scenario assumes offsite removal for the Labadie ash pond sites and includes the following:

- Pre-CCR removal preparation (5 years, included on a prorated basis in the Closure Duration for each pond);
- Stabilization, loading, and pond restoration;
- Seasonal impacts from wet and winter weather conditions impeding productivity;
- Hauling to an offsite landfill in Missouri;
- Landfill placement; and
- Loading and transportation infrastructure.

Labadie Energy Center	Estimated Ash Volume (CY) ²	Estimated Total Removal Cost	Closure Duration (Years)
	17,325,126	\$2,440 M – \$2,930 M	35 plus years

Scenario 2: Onsite CCR Removal for Labadie

This scenario assumes onsite disposal the Labadie ash pond sites and includes the following:

- Pre-CCR removal preparation (10 years, included on a prorated basis in the Closure Duration for each pond);
- Stabilization, loading, and pond restoration;
- Hauling to an onsite landfill located near the existing ponds;
- Seasonal impacts from wet and winter weather conditions impeding productivity;
- Landfill placement; and
- Loading infrastructure.

Labadie Energy Center	Estimated Ash Volume (CY)	Estimated Total Removal Cost	Closure Duration (Years)
	17,325,126	\$1,270 M - \$1,520 M	40 plus years

²Estimated volumes do not include any dry amendment materials.

Scenario 3: Offsite CCR Removal for Sioux

This scenario assumes offsite removal for the Sioux ash pond sites and includes the following:

- Pre-CCR removal preparation (5 years, included on a prorated basis in the Closure Duration for each pond);
- Stabilization, loading, and pond restoration;
- Hauling to an offsite landfill in Illinois³;
- Seasonal impacts from wet and winter weather conditions impeding productivity;
- Landfill placement; and
- Loading and transportation infrastructure.

Sioux Energy Center	Estimated Ash Volume (CY)	Estimated Total Removal Cost	Closure Duration (Years)
	6,079,808	\$890 M - \$1,060 M	15 plus years

Scenario 4: Onsite CCR Removal for Sioux

This scenario assumes onsite disposal the Sioux ash pond sites and includes the following:

- Pre-CCR removal preparation (10 years, included on a prorated basis in the Closure Duration for each pond);
- Stabilization, loading, and pond restoration;
- Hauling to an onsite landfill located near the existing ponds;
- Seasonal impacts from wet and winter weather conditions impeding productivity;
- Landfill placement; and
- Loading infrastructure.

Sioux Energy Center	Estimated Ash Volume (CY)	Estimated Total Removal Cost	Closure Duration (Years)
	6,079,808	\$470 M - \$570 M	20 plus years

Scenario 5: Onsite CCR Removal for Meramec

This scenario assumes offsite removal for the Meramec ash pond sites and includes the following:

- Pre-CCR removal preparation (5 years, included on a prorated basis in the Closure Duration for each pond);

³ Lochmueller did not review local siting requirements but many Illinois counties contain such restrictions.

May 13, 2019

Page 5

- Stabilization, loading, and pond restoration;
- Hauling to an offsite landfill in Illinois;
- Seasonal impacts from wet and winter weather conditions impeding productivity;
- Site specific constraints with transportation access and associated limitations;
- Landfill placement; and
- Loading and transportation infrastructure.

Meramec Energy Center	Estimated Ash Volume (CY)	Estimated Total Removal Cost	Closure Duration (Years)
	5,194,923	\$740 M - \$890 M	20 plus years

APRIL 29, 2019

EXTRACTION & TRANSPORTATION STUDY: Rush Island Ash Pond Closure Assessment

**Rush Island Site
Jefferson County, Missouri**

Prepared for:

AMEREN
1901 Chouteau Avenue
St. Louis, Missouri 63103
314.621.3222

Prepared by:

Lochmueller Group
411 N. 10th Street
Suite 200
St. Louis, MO 63101
314.621.3395



Table of Contents

Introduction	2
Extraction & Stabilization.....	3
Description of Method.....	3
Dry Extraction:	3
Partially Wet Extraction:	3
Fully Submerged Extraction:	3
Site Restoration:.....	4
Extraction and Stabilization Impacts.....	5
Safety	5
Accidents.....	5
Exposure.....	5
Environment.....	5
Floodplain	5
River Embankment.....	5
Emissions.....	5
Fugitive Ash Particulate	5
Capital Projects	5
Onsite Access Roads.....	5
Geotube Staging Areas.....	6
Water Treatment Facilities	6
Loading Areas.....	6
Restoration of Former Ash Ponds.....	6
Transportation & Disposal	7
Modal Options (Truck, Rail, Barge)	7
Truck Hauling	7
Landfill Options	8
Transportation Route.....	9
Transportation Impacts.....	10
Traffic Flow.....	10
Safety & Environment.....	11
Pavement	11
Conclusion.....	12

Introduction

Lochmueller Group completed the following planning-level assessment of the costs and logistics associated with extracting, stabilizing, and transporting coal combustion residuals (CCR) from the existing ash pond system at the Rush Island Power Generation Center to existing offsite, commercially available landfill facilities. The Rush Island site is located along the Mississippi River in Jefferson County, Missouri approximately nine (9) miles southeast of Festus, Missouri. The purpose of this assessment is to describe the methods, determine the impacts, and quantify the order-of-magnitude costs associated with removing and transporting all CCR from its current disposal location at the Rush Island site to a private landfill for permanent storage.

Extraction & Stabilization

Description of Method

Extraction and stabilization of the CCR material from the CCR unit at Rush Island Energy Center is complicated due to its depth and location. In addition, the CCR unit contains both Class C and F fly ash that complicates excavation methods. CCR material from the unit would need to be excavated at depths of up to 100 feet, dewatered, dried and conditioned, before being and loaded into trucks and transported offsite.

Removal of the CCR material would require multiple phases including dry extraction, partially wet extraction and fully submerged extraction. The various phases are described below:

Dry Extraction:

This phase includes the handling and removal of the existing CCR material from the current surface elevation down to the groundwater elevation (approximately 18' below the ground surface (BGS) elevation) (Geotechnical Investigation and Report, prepared by CEC and dated December 20, 2011). Generally, it is assumed that this material can be direct loaded and transported without additional drying or conditioning procedures (moisture content between approximately 25% and 35%). The work associated with this phase includes the extraction, on-site transportation to Staging/Loading Areas, storage, and loading onto transportation for off-site removal. Standard earth-moving equipment and procedures would be utilized including dozers, loaders, and excavators. In general, dozers would be used to excavate and move the CCR material into piles and loaders would be used to load the CCR material into the waiting trucks for transport off-site. Excavators would be used in a support role to dig in areas where dozers are not efficient. Sub-areas of the pond area would need to be established to facilitate extraction operations. The general size of these sub-areas, laterally and vertically, will be determined based on on-site conditions as the operation progresses and the CCR material is removed.

Partially Wet Extraction:

This phase includes the handling and removal of the existing CCR material from the groundwater elevation to a point in which hydraulic excavation is feasible (18' below ground surface to 28' below ground surface). This material is assumed to be in acceptable condition for loading and transportation with no additional drying and conditioning after the dewatering procedure described below is completed.

Dewatering of this material would involve excavation of channels to promote material drying prior to excavation and transportation. Water would be diverted from excavated depressions utilizing pumps and piping systems to transport the water away from the material excavation area. After sufficient dewatering and drying time, the CCR materials would be removed using the same means as described for dry excavation.

Fully Submerged Extraction:

CCR materials located further down in the pond (28' below ground surface to 100' below ground surface) may be saturated and would require drying and conditioning prior to off-site transport. Such materials would need to be extracted via hydraulic dredging methods. The complexities and potential costs associated with such dredging efforts are significantly higher per unit volume than the "Dry Extraction" and "Partially Wet Extraction" phases. In fact, successful pond closures at the depths

required for the Rush Island site could were not discovered. Removal operations for CCR ponds with depths up to 50 feet were found.

This method employs equipment that removes the CCR material directly from the bottom of the CCR unit and pumps the “slurry” through a piping system to “geotubes” located in nearby drying areas. Geotubes are a geotextile filtration “bag” manufactured by sewing together multiple sheets of geotextiles using polyester or polypropylene. As the dredged water enters the geotubes, the geotextile captures the CCR materials as the water drains. Chemical addition during the pumping and piping operation using coagulants and flocculants will be necessary to aid in the dewatering process. The specific makeup of CCR materials are site specific. Therefore, selection of the most effective and efficient coagulants and flocculants will require bench testing. Maintenance of the dredging equipment, piping system, drying areas, settling ponds, and temporary roads will be necessary to facilitate the operation.

Significantly large drying areas will be required to accommodate the multi-week week drying procedure. After dewatering is complete, the geotubes are opened and the CCR material is loaded onto transportation for off-site removal. The transportation of material for off-site removal was the assumed limiting factor for the overall CCR disposal process flow based on the analysis performed in this study. However, extended, unforeseen weather conditions can contribute to additional lost working time due to icy conditions, mechanical system freeze-ups, or flooding.

Site Restoration:

This phase includes the final restoration of the site. This would include removal of all temporary access roads and residual ash in project area. Backfilling would likely need to occur for at least some volume of the remaining pond in conjunction with excavation activities to minimize infiltration from the Mississippi River. The closest source of backfill material would be sand dredged from the Mississippi River. Stabilization of the site with vegetative practices would be required for erosion control. The river banks and the remaining embankment along the river would require additional analysis and appropriate stabilization, but may include a combination of vegetation, large rocks or manufactured concrete products.

Extraction and Stabilization Impacts

Safety

Accidents

Workforce safety during the operation is a significant risk factor. With several unit processes operating with heavy machinery, proper safety planning is important. Accidents can be minimized during operations, but the planning and implementation of a safety plan will have significant costs associated with the effort.

Exposure

There is not only immediate physical injury risks, but there is also exposure risk to the people working on the site. Proper safety equipment will be necessary to limit exposure to potentially harmful substances in the CCR material removal process such as flocculants and coagulant used for the dewatering process.

Environment

Floodplain

The project area is currently shown within the 100 year floodplain for both the current and pending FIRM maps. The potential for the area to experience flooding during excavation activities creates additional risk to the extraction and stabilization operations.

River Embankment

The existing ash ponds are adjacent to the Mississippi River. There is a strip of land that separates these surface water bodies and serves as an embankment that separates the pond from the river. Proper excavation techniques and monitoring will need to be employed to ensure the land between the two surface water bodies remains stable during excavation and dredging activities. After dredging activities are complete, the embankment will require analysis to confirm stability. Removal of the embankment and/or significant re-stabilization may be necessary for the restoration of the site.

Emissions

The heavy equipment used during the extraction and stabilization phase of the project includes dozers, loaders, excavators, hydraulic dredges, and onsite hauling trucks. These types of equipment typically utilize diesel fuel and would generate emissions during operations. These emissions are in addition to the emissions discussed in the transportation impacts section of this assessment.

Fugitive Ash Particulate

As the CCR material is being extracted and stabilized, fugitive ash particulate will be created and would need to be managed through an ash management plan.

Capital Projects

Onsite Access Roads

The onsite access road utilized for the offsite hauling trucks is discussed in the transportation section of this assessment. The construction of temporary on-site hauling roads will be required throughout the extraction and stabilization process. These haul roads will need to be modified frequently in order to provide efficient transportation of the CCR to the stabilization and loading areas and to maintain dust control.

Geotube Staging Areas

Geotube staging areas will need to be constructed within the project area that are relatively flat to allow for proper dewatering of the CCR. These staging areas will be temporary and will need to be moved throughout the closure process as CCR is removed during different phases of the operation. Filtrate from the geotubes would be directed back to the settling ponds for treatment.

Water Treatment Facilities

The existing ponds could be utilized throughout the CCR removal process for settling any remaining solids from the filtrate from the drying process. There may be a need for the construction of new settling ponds toward the end of the process to fully remove CCR from the existing ponds. The filtrate will likely contain suspended solids and some form of treatment or settling may need to be evaluated depending on the final characteristics of the filtrate.

Loading Areas

Once the CCR is stabilized, the material may require some additional layout and loading area to ensure the material is dry enough for offsite hauling and ultimate placement in a landfill. The loading areas will need to be constructed as appropriate for the CCR removal areas that are active. The loading areas will require the construction of scales for measuring the weight of trucks and truck washing facilities to wash down tires of residual ash material.

Restoration of Former Ash Ponds

The post-CCR-removal condition of the ponds will be dependent on the final planned use of the area. Some options may include backfilling, removing embankment, creating or restoring habitat, etc. Achieving the desired future use may include utilizing the soil material that would remain between the pond and the river to backfill some of the remaining pond area. Sand backfill material could also be dredged from the Mississippi river for additional backfill material. Overall stabilization of the site would be required and would include vegetative, natural rock, and manufactured products to meet regulatory requirements.

Transportation & Disposal

This section addresses the transportation of CCR material from the site and its permanent disposal at a private landfill.

Modal Options (Truck, Rail, Barge)

The Rush Island site is located along the Mississippi River. Additionally, a BNSF rail line runs adjacent to the site. Therefore, the ability to haul CCR by barge and rail from Rush Island may be possible. However, significant infrastructure improvements would be required at the Rush Island site to provide ash loading capabilities for these modes.

The preferred landfill locations are all located within 80 miles of Rush Island. None of the sites have direct water access. Therefore, any CCR transported by barge from Rush Island would need to be transferred from barge to truck to reach the landfill destinations. The inefficiency of this transfer would render barge transportation considerably more costly than truck hauling. Moreover, most of the landfill sites are located further inland (east or west) from Rush Island such that north-south travel along the Mississippi River would not be beneficial.

With regards to rail, none of the preferred landfill sites have direct rail access. Several sites are located adjacent to rail corridors but spurs would need to be constructed to facilitate direct landfill access and allow for the temporary storage and unloading of rail cars. Additionally, three of the four preferred landfill sites are located in Illinois, which would require trains to travel through the congested St. Louis rail network to cross the Mississippi River. Rail is most efficient when transporting bulk materials over long distances. Given the relatively short travel distance to each landfill site, rail would not be cost-competitive with truck hauling.

This assessment assumed truck hauling to be the most cost-effective and feasible mode of transport. All subsequent analyses reflect truck hauling.

Truck Hauling

To determine a timeframe for extraction and removal of all CCR from its current, impounded location, the following was assumed:

- Truck hauling via 40-foot end load dump trucks loaded via conventional equipment – each trailer has a payload capacity of 25 tons based on a typical 80,000 lb. gross loaded maximum;
- 8-hour daily operation and a range of 155 to 193 days of annual operation (accounting for weekends, holidays, and time lost due to weather and imperfect execution);
- Loading operations on the Rush Island site occur adjacent to the impoundment and on the south portion of the site; and
- A maximum daily haul rate of 5,000 tons.

The resulting transportation haul assumptions are summarized in **Table 1**.

Table 1: Transportation Haul Summary

Total Tons of CCR Removed	Annual Tons of CCR Removed	Closure Duration*
21.6 million	742,772 to 928,465	28-34 Years

*Measured from the decision to begin extraction until fully removed

To accommodate the volume of truck traffic identified in **Table 1**, roadways internal to the Rush Island site would need to be improved. Specifically, a heavy-duty concrete roadway would need to be constructed along the western perimeter of the site extending from Big Hollow Road south to the ash pond area. Multiple at-grade railroad crossings with the site's rail spur would be required.

In the vicinity of the pond area, staging would need to be provided to accommodate several trucks in queue for multiple loading stations. Hence, a large loading station would need to be constructed. Once loaded, trucks would need to proceed to a washout area and scaled to verify the truck is loaded properly. A quick route back to the loading pad from the scale area would be needed for any overweight trucks.

Landfill Options

Four preferred landfills were identified as potential destinations for the CCR removed from the Rush Island site as shown in **Table 2**. Landfill disposal costs supplied by Ameren are similar across the four locations. With costs paid to the landfill being essentially equal, transportation costs would drive the landfill location decision. Assumed haul rates per ton to each landfill location were also supplied by Ameren. The lowest cost haul rate would be to the Progressive Waste site in Richwoods, which is also significantly closer to Rush Island than the other sites. Therefore, this assessment prioritized CCR disposal at the Progressive Waste landfill.

Table 2: Preferred Landfill Locations

Landfill Site	Address	Distance to Site (mi)	Travel Time to Site (min)
Progressive Waste	12581 State Hwy H, Richwoods, MO	34.7	44
Republic Services	4601 Cahokia Road, Roxana, IL	67.3	67
Waste Management	10400 Hillstown Road, Marissa, IL	73.4	82
Perry Ridge	6305 Sacred Heart Road, DuQuoin, IL	79.8	97

Capacity calculations were performed to determine the total space available for CCR disposal in aggregate. The annual disposal amount currently received by the landfill was assumed to remain constant over time and the incremental annual disposal amount due to the Rush Island CCR was added. Based on the capacity of the Progressive Waste site, at the combined disposal volume, it was estimated that the Progressive Waste landfill would become full upon receiving approximately 80 percent of the total CCR from Rush Island.

It was also assumed that the Progressive Waste site could feasibly accept the maximum daily load of trucks (192) and that Progressive Waste would be willing to receive the maximum amount of CCR possible and dedicate the necessary space on site for monofill construction to isolate the CCR material from other waste on site.

Given these assumptions, the calculations indicate that a second landfill site with available capacity would need to receive the final 20 percent of Rush Island CCR material once Progressive Waste reaches capacity. However, for purposes of the subsequent routing and transportation evaluations, it was assumed that the entire Rush Island CCR volume would be disposed at Progressive Waste.

Transportation Route

Many factors were considered when establishing a preferred route suitable for the removal of the CCR from the Rush Island site to the Progressive Waste landfill, including roadway functional classification and the available connectivity between the two sites using the existing roadway network. The selected route is approximately 36.5 miles long and utilizes the following roadways:

- Begin at the Rush Island site on Big Hollow Road
- Johnson Road west
- Danby Road west
- Highway 61 south
- Highway TT west
- Interstate 55 north
- Highway 67 south
- MO-110 west
- MO-21 south
- Highway H west
- End off Highway H at Progressive Waste

This route prioritizes roadways with the highest functional classifications along a reasonably direct line of travel. While a shorter route may be possible, it would rely upon roadways less suitable for truck traffic and therefore was not considered. The selected route emphasizes major numbered state routes, with the exception of leaving the Rush Island site (via Big Hollow Road, Johnson Road, and Danby Road) and accessing Progressive Waste (via Highway H).

The egress route from the Rush Island site utilizes Johnson Road and Danby Road instead of remaining on Big Hollow Road to Drury Road. Johnson Road/Danby Road is the designated route for truck traffic in and out of the Rush Island site. This route also promotes use of the half diamond interchange on Interstate 55 at Route TT, which was constructed approximately 10 years ago for purposes of serving truck traffic to/from the nearby Holcim Cement Plant.

Transportation Impacts

The following transportation impacts would be anticipated as a result of the hauling operation.

Traffic Flow

The selected route between Rush Island and Progressive Waste was evaluated in terms of its ability to accommodate the additional truck traffic, including both loaded and unloaded trucks. Overall, the truck volume distributed over the course of the day would not be expected to generate significant traffic flow impacts. The route emphasizes major roadways, which would be capable of handling the additional traffic. In fact, no improvements were assumed for Interstate 55 or Highway 67.

That said, the following transportation improvements would be recommended to mitigate anticipated impacts of the additional truck traffic at select locations:

- Big Hollow Road, Johnson Road, and Danby Road, which connect the Rush Island site with Highway 61, are not suitable for the volume of truck traffic anticipated. These roadways typically have 11-foot lanes and no shoulders. The horizontal and vertical geometry is substandard in places. The existing asphalt pavement would not likely withstand the effects of heavy truck traffic. It is recommended that this corridor be upgraded to provide an appropriate truck route between Rush Island and Highway 61. The assumed improvements consist of heavy-duty concrete pavement and alignment corrections along the existing roadway.
- The intersection of Danby Road with Highway 61 should be improved to include a dedicated northbound right-turn lane on Highway 61 and enlarged right-turn radius. This turn lane would serve trucks en route to Rush Island from Interstate 55. This intersection would be expected to remain unsignalized.
- The intersection of Route TT with Highway 61 should be improved to include a dedicated southbound right-turn lane on Highway 61 and enlarged right-turn radius. This turn lane would serve trucks en route to Progressive Waste. This intersection would be expected to remain unsignalized.
- The intersection of Highway 21 and Highway 110 was recently realigned and upgraded to current standards, so it should be well-equipped to serve truck turning maneuvers. However, the intersection remains unsignalized. Installation of a signal would be recommended in order to safely and efficiently serve trucks turning from westbound Highway 110 to southbound Highway 21 en route to Progressive Waste.
- The intersection of Highway 21 with Route H is signalized and currently includes a dedicated southbound right-turn lane and dedicated eastbound left-turn lane to serve truck turning movements along the selected route. It is recommended that the eastbound left-turn lane be extended to provide additional storage capacity. The existing turn lane is approximately 75 feet in length, which would accommodate only a single truck and possibly one additional vehicle.
- Route H is a low-volume and narrow two-lane highway with lane widths of approximately 10 feet, low shoulders, and substandard alignment in select areas. While upgrades to this corridor would be beneficial, given the length of the route, significant upgrades for purposes of the hauling operation would likely be deemed cost prohibitive.

Safety & Environment

The safety implications of the truck hauling operation were evaluated using information provided in the Highway Safety Manual (HSM), published by the American Association of State Highway and Transportation Officials (AASHTO). The HSM relates traffic volumes and roadway character to crash expectancy. Changes in volumes would then cause an increase or decrease in the crash expectancy. It is anticipated that the additional truck traffic would result in an increase of 6 crashes total on an annual basis along the entirety of the haul route, as follows:

- Net increase of 2 Severe (Fatal or Injury) Crashes per year
- Net increase of 4 PDO (Property Damage Only) Crashes per year

Additional environmental costs would also be incurred as a result of the hauling operation.¹ In total, transportation safety and environmental costs are estimated to be approximately \$490 million to \$611 million over the duration of the hauling operation. These costs would not be borne directly by Ameren but instead would be incurred by the general population.

Pavement

The additional truck volume would depreciate the pavement design life and accelerate pavement deterioration along the selected route. To compensate for the increased wear, pavement mill and overlay were assumed at 5-year increments along all segments of the route, with the exception of Interstate 55 (which as an interstate should be built to withstand truck traffic) and the upgraded access route to the Rush Island site (which would be reconstructed with heavy duty concrete).

¹ According to the Environmental Protection Agency's (EPA) publication on National Average In-Use Emissions from Heavy-Duty Trucks, semi-tractor trailer rigs are responsible for emitting 12.5 grams of pollutants per mile into the air. The economic cost attributable to truck emissions using EPA's methodology was estimated to be \$434M. This accounts for increased healthcare costs, lost productivity, welfare costs, environmental remediation, etc.

Conclusion

Lochmueller Group completed the preceding planning-level assessment of the methods and impacts associated with extracting, stabilizing, and transporting CCR from the existing Rush Island Power Generation Center. The purpose of this assessment was to determine the impacts and quantify the order-of-magnitude costs associated with completely removing all CCR from the Rush Island site and transporting it to a private landfill for permanent storage. The information contained herein is provided at a planning-level.

This study assumed that 12,725,000 cubic yards of coal combustion residuals would ultimately need to be removed from the Rush Island site. This would equate to approximately 21,650,000 tons of material to transport. This transport weight was calculated by multiplying the in place cubic yards by a swell factor to account for the uncompacted volume after excavation. The weight of the uncompacted unit volume was established from geotechnical testing data that provided the pounds per cubic foot and the percent moisture content. Based on a range of operating days per calendar year, it would take from 28 to 34 years to extract all material from the site.

Restoration of the site would include backfilling and stabilization with vegetative and structural practices. Restoration costs could be significant in that the resulting 70 – 100 foot depression may need to be backfilled via a dredging operation within the Mississippi River.

The total cost to extract, stabilize, transport, and dispose of the CCR material is summarized below in 2019 dollars. The total cost to Ameren could range from \$1.9 to \$2.1 Billion, depending upon the total period of removal operations. This includes transportation infrastructure upgrades both internal and external to the Rush Island site as discussed.

Extraction of CCR and Transport to Offsite Landfill	
Ameren Project Costs	
Extraction, Stabilization, Loading, and Restoration	\$773-891 Million
Hauling	\$372-375 Million
Landfill Placement Costs	\$691-757 Million
Transportation Infrastructure (on and off-site)	\$66-77 Million
Project Cost Total	\$1.9-\$2.1 Billion

Costs in 2019 Dollars