

40 CFR Parts 257

Checklist for Inspection Requirements for CCR Landfills 257.84 (b)

Labadie Power Station – LCL1 (Landfill Cell 1)

1. Annual Inspection

Requirements	Signs of actual or potential structural weakness	Disruptions or potential disruption to the operation and safety of the unit
CCR Unit and appurtenant structures 257.84(b)(ii)	None Observed	None Observed

The 2020 Annual Inspection included a review of available information regarding the status and condition of the CCR unit, including, but not limited to, files available in the operating record in general accordance with 257.84(b)(i).

Minor maintenance items (e.g. animal burrows, ruts, etc.) associated with routine upkeep observed during the 2020 Annual Inspection, presently do not impact the structural integrity of the embankment. Ameren plans to address these items in a timely manner through Ameren’s work control process.

Engineer’s Seal



Jeff Bertel, P.E.

License: PE-2010025265

Date: December 14, 2020

LABADIE ENERGY CENTER

Cell 1 (LCL1) and Pond 1

Date	10/28/2020
Inspector	J. Bertel, M. Lueckenhoff
Weather	45°
Temperature	Cloudy

Date of Previous Annual Inspection: 09/17/2019

Date of Previous Periodic Inspection: 12/14/2016

Description of Emergency (EC) or Immediate Maintenance (IM) conditions observed since the last annual inspection:

None

Describe any action taken to restore or improve safety and integrity of impounding structure:

None

Describe any modifications to the geometry of the impounding structure since the previous annual inspection:

None.

Describe any modifications to the operation of the impounding structure since the previous annual inspection:

Currently installing the UWL return water line to help manage water levels in Pond 1.

List the approximate remaining storage capacity of the impounding structure:

2,293,608 CY

List the approximate maximum, minimum and present depth and elevation of the impounded CCR in Cell 1 since the previous annual inspection:

	Maximum		Minimum		Present	
	Elevation (ft)	Depth (ft)	Elevation (ft)	Depth (ft)	Elevation (ft)	Depth (ft)
Cell 1	484	6	479	2	484	6

Approximate volume of CCR at the time of the inspection:

121,353 CY

Describe any changes to the downstream watershed:

None.