



To: Ameren Electric Service Manual Holders

April 1, 2019

The latest catalog number information for the Ameren approved meter mounting devices list dated April 1st, 2019 is available on the Ameren website: <http://www.ameren.com/servicemanual>

The changes are list as the follow:

- Milbank
 - ❖ Removed cold Sequence Combo Units
- Erickson
 - ❖ Add CT enclosures CT-43, 44 and CT-81, 83
 - ❖ Remove CT enclosure with fused disconnect for 201 to 400 amp services
- Siemens
 - ❖ Added Metering PAK
- **Talon**
 - ❖ Add new CT rated Pre-wired meter socket for 8 terminal and 13 terminal
- AMP
 - ❖ Added 400-800A Bussed Bar Type Wall Mount CT Cabinets
- GE
 - ❖ Changed the brand to GE/ABB
- Eaton
 - ❖ Changed the part #1009722 to #1008792CH
 - ❖ Removed 125 Amp meter socket from meter stacks with "1MM".
 - ❖ Revised catalog number for horizontal bus products.

At this site, you will also be able to get the latest Ameren Service Manual as well as register your company to receive immediate notice of any updates.

If you have any questions, please email them to ElectricServiceManual@ameren.com .

SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
CURRENT TRANSFORMER "CT" ENCLOSURES - WALL MOUNTED						
3	3	600	400 to 600	400A-600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead" (Grd B Ph)	AMECT46-3GBL	48 x 30 x 10
3	3	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead" (Grd B Ph)	AMECT8-3GBL	48 x 30 x 10
3	3	600	1200	1200A Bussed Bar Type Wall Mtd CT Cabinet "Overhead" (Grd B Ph)	AMECT12-3GBL	60 x 36 x 15
3	1	600	400 to 600	400-600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT46-3L	48 x 30 x 10
3	1	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT8-3L	48 x 30 x 10
3	1	600	400 to 800	400-800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT468-3L	48 x 30 x 10
4	3	600	400 to 600	400-600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT46-4L	48 x 30 x 10
4	3	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT8-4L	48 x 30 x 10
4	3	600	400 to 800	400-800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT468-4L	48 x 30 x 10
4	3	600	1200	1200A Bussed Bar Type Wall Mtd CT Cabinet "Overhead"	AMECT12-4	60 x 36 x 15
4	3	600	1600	1600A Bussed Window Type Wall Mtd CT Cabinet "Overhead"	AMECT16-4	72 x 42 x 21
4	3	600	2000	2000A Bussed Window Type Wall Mtd CT Cabinet "Overhead"	AMEFCT20-4	72 x 42 x 21
4	3	600	2500	2500A Bussed Window Type Wall Mtd CT Cabinet "Overhead"	AMECT25-4	72 x 42 x 21
4	3	600	3000	3000A Bussed Window Type Wall Mtd CT Cabinet "Overhead"	AMECT30-4	72 x 42 x 21
3	3	600	400	400A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground" (Grd B Ph)	AMECT4-3GB	48 x 36 x 15
3	3	600	600	600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground" (Grd B Ph)	AMECT6-3GB	48 x 36 x 15
3	3	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground" (Grd B Ph)	AMECT8-3GB	48 x 36 x 15
3	3	600	800	1200A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground" (Grd B Ph)	AMECT12-3GB	60 x 48 x 15
3	1	600	400	400A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT4-3B	48 x 36 x 15
3	1	600	600	600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT6-3B	48 x 36 x 15
3	1	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT8-3B	48 x 36 x 15
3	1	600	400 to 800	400-800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT468-3B	48 x 36 x 15



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
CURRENT TRANSFORMER "CT" ENCLOSURES - WALL MOUNTED						
4	3	600	400	400A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT4-4B	48 x 36 x 15
4	3	600	600	600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT6-4B	48 x 36 x 15
4	3	600	800	800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT8-4B	48 x 36 x 15
4	3	600	400 to 800	400-800A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT468-4B	48 x 36 x 15
4	3	600	1200	1200A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT12-4B	60 x 48 x 15
4	3	600	1600	1600A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT16-4B	72 x 54 x 21
4	3	600	2000	2000A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT20-4B	72 x 54 x 21
4	3	600	2500	2500A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT25-4B	72 x 54 x 21
4	3	600	3000	3000A Bussed Bar Type Wall Mtd CT Cabinet "Overhead & Underground"	AMECT30-4B	72 x 54 x 21
CURRENT TRANSFORMER "CT" ENCLOSURES - PAD MOUNTED						
3	1	600	400	400A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT4-3	60 x 36 x 15
3	1	600	600	600A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT6-3	60 x 36 x 15
3	1	600	800	800A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT8-3	60 x 36 x 15
3	1	600	400 to 800	400-800A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT468-3	60 x 36 x 15
4	3	600	400	400A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT4-4	60 x 36 x 15
4	3	600	600	600A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT6-4	60 x 36 x 15
4	3	600	800	800A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT8-4	60 x 36 x 15
4	3	600	400 to 800	400-800A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT468-4	60 x 36 x 15
4	3	600	1200	1200A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT12-4	72 x 54 x 21
4	3	600	1600	1600A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT16-4	72 x 54 x 21
4	3	600	2000	2000A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT20-4	72 x 54 x 21
4	3	600	2500	2500A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT25-4	72 x 54 x 21



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
CURRENT TRANSFORMER "CT" ENCLOSURES - PAD MOUNTED						
4	3	600	3000	3000A Bussed Bar Type Pad Mtd CT Cabinet "Design #1 / One Sided"	AMEPCT30-4	72 x 54 x 21
4	3	600	800	800A Bussed Bar Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC8-4ACT	60 x 39 x 24
4	3	600	1200	1200A Bussed Bar Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC12-4ACT	75 x 51 x 24
4	3	600	1600	1600A Bussed Window Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC16-4ACT	75 x 51 x 24
4	3	600	2000	2000A Bussed Window Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC20-4ACT	75 x 51 x 24
4	3	600	2500	2500A Bussed Window Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC25-4ACT	75 x 51 x 24
4	3	600	3000	3000A Bussed Window Type Pad Mtd CT Cabinet "Design #2 / One Sided Stepped Bus"	AMESCC30-4ACT	75 x 51 x 24
COMBINATION "CT" CABINET & MAIN DISCONNECT						
3	1	600	600	600A Bussed Bar type CT Cabinet w/ 600A Main Switch	AMEMCT266J	72 x 33 x 13
3	1	600	800	800A Bussed Bar type CT Cabinet w/ 800A Main Switch	AMEMCT267J	72 x 33 x 13
4	3	600	400	400A Bussed Bar type CT Cabinet w/ 400A Main Switch	AMEMCT365J	72 x 33 x 13
4	3	600	600	600A Bussed Bar type CT Cabinet w/ 600A Main Switch	AMEMCT366J	72 x 33 x 13
4	3	600	800	800A Bussed Bar type CT Cabinet w /800A Main Switch	AMEMCT367L	72 x 33 x 13
4	3	600	1200	1200A Bussed Bar type CT Cabinet w/ 1200A Main Switch	AMEMCT368L	84 x 39 x 15
COMBINATION "CT" CABINET & SIX DISCONNECT						
3	1	600	400-800	400 to 800A Bussed Bar Type CT Cabinet & 6 Disc Panel	AMESCT8-3	72 x 33 x 13
4	3	600	400-800	400 to 800A Bussed Bar Type CT Cabinet & 6 Disc Panel	AMESCT8-4	72 x 33 x 13
4	3	600	1200	1200A Bussed Bar Type CT Cabinet & 6 Disc Panel	AMESCT12-4	84 x 39 x 15
PT CABINET						
NA	3	600	NA	PT Enclosure Galvanized	AMEPTB36GALV	36 x 12 x 71/4
NA	3	600	NA	PT Enclosure Painted Transformer Green	AMEPTB36GRN	36 x 12 x 71/4
NA	3	600	NA	PT Enclosure Painted ASA61 Gray	AMEPTB36GRY	36 x 12 x 71/4



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
METER STACKS - RESIDENTIAL (INDOOR)						
3	1	120/240	1200A	1 to 12 1PH Sockets Indoor Encl Max 125A CB	RM Style	90 x 30 x 91/2
4	3	120/208	1200A	1 to 12 1PH Sockets Indoor Encl Max 125A CB	RM Style	90 x 30 x 91/2
METER STACKS - RESIDENTIAL (OUTDOOR)						
3	1	120/240	1200A	1 to 10 1PH Sockets N3R Encl Max 125A CB	RMR90 Style	90 x 32 x 11
4	3	120/208	1200A	1 to 10 1PH Sockets N3R Encl Max 125A CB	RMR90 Style	90 x 32 x 11
3	1	120/240	1200A	1 to 8 1PH Sockets N3R Encl Max 200A CB	RMR90-2 Style	90 x 32 x 11
4	3	120/208	1200A	1 to 8 1PH Sockets N3R Encl Max 200A CB	RMR90-2 Style	90 x 32 x 11
METER SOCKET & MAIN DISCONNECT COMBO						
3	1	120/240	100A	Self Contained OH Lever Bypass Hot Sequence Line Top w/ 100A Disconnect Vertical	SESMH223VT	41 x 12 x 51/2
3	1	120/240	200A	Self Contained OH Lever Bypass Hot Sequence Line Top w/ 200A Disconnect Vertical	SESMH224VT	41 x 12 x 51/2
3	1	120/240	400A	Self Contained OH Lever Bypass Hot Sequence Line Top w/ 400A Disconnect Vertical	SESMH225VT	69 x 17 x 7
3	1	120/240	100A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 100A Disconnect Vertical	SESMH223VB	41 x 12 x 51/2
3	1	120/240	200A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 200A Disconnect Vertical	SESMH224VB	41 x 12 x 51/2
3	1	120/240	400A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 400A Disconnect Vertical	SESMH225VB	69 x 17 x 7
3	1	120/240	100A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 100A Disconnect Horizontal	SESMH223H	20 x 24 x 51/2
3	1	120/240	200A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 200A Disconnect Horizontal	SESMH224H	20 x 24 x 51/2
3	1	120/240	400A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 400A Disconnect Horizontal	SESMH225H	34 x 34 x 7



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
METER SOCKET & MAIN DISCONNECT COMBO						
4	3	120/208	100A	Self Contained OH/UG Lever Bypass Hot Sequence Line Top w/ 100A Disconnect Vertical	SESMH323VT	41 x 12 x 5 1/2
4	3	120/208	200A	Self Contained OH Lever Bypass Hot Sequence Line Top w/ 200A Disconnect Vertical	SESMH324VT	41 x 12 x 5 1/2
4	3	120/208	400A	Self Contained OH Lever Bypass Hot Sequence Line Top w/ 400A Disconnect Vertical	SESMH325VT	69 x 17 x 7
4	3	120/208	100A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 100A Disconnect Vertical	SESMH323VB	41 x 12 x 5 1/2
4	3	120/208	200A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 200A Disconnect Vertical	SESMH324VB	41 x 12 x 5 1/2
4	3	120/208	400A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 400A Disconnect Vertical	SESMH325VB	69 x 17 x 7
4	3	120/208	100A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 100A Disconnect Horizontal	SESMH323H	20 x 24 x 5 1/2
4	3	120/208	200A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 200A Disconnect Horizontal	SESMH324H	20 x 24 x 5 1/2
4	3	120/208	400A	Self Contained OH/UG Lever Bypass Hot Sequence Line Bottom w/ 400A Disconnect Horizontal	SESMH325H	34 x 34 x 7
480V COLD SEQUENCE SOCKET AND METER DISCONNECT						
4	3	600	100A	Self Contained OH Lever Bypass Cold Sequence Line Top w/ 100A Disc Non Fused Vertical	AMESESMC363VT	41 x 12 x 5 1/2
4	3	600	200A	Self Contained OH Lever Bypass Cold Sequence Line Top w/ 200A Disc Non Fused Vertical	AMESESMC364VT	41 x 12 x 5 1/2
4	3	600	400A	Self Contained OH Lever Bypass Cold Sequence Line Top w/ 400A Disc Non Fused Vertical	AMESESMC365VT	69 x 17 x 7
4	3	600	100A	Self Contained OH Lever Bypass Cold Sequence Line Bottom w/ 100A Disc Non Fused Vertical	AMESESMC363VB	41 x 12 x 5 1/2
4	3	600	200A	Self Contained OH Lever Bypass Cold Sequence Line Bottom w/ 200A Disc Non Fused Vertical	AMESESMC364VB	41 x 12 x 5 1/2
4	3	600	400A	Self Contained OH Lever Bypass Hot Sequence Line Bottom w/ 400A Disc Non Fused Vertical	AMESESMC365VB	69 x 17 x 7
4	3	600	100A	Self Contained OH/UG Lever Bypass Cold Sequence Line Bottom w/ 100A Disc Non Fused Horizontal	AMESESMC363H	20 x 24 x 5 1/2



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
480V COLD SEQUENCE SOCKET AND METER DISCONNECT						
4	3	600	200A	Self Contained OH/UG Lever Bypass Cold Sequence Line Bottom w/ 200A Disc Non Fused Horizontal	AMESESMC364H	20 x 24 x 5 1/2
4	3	600	400A	Self Contained OH/UG Lever Bypass Cold Sequence Line Bottom w/ 400A Disc Non Fuses Horizontal	AMESESMC365H	34 x 34 x 7
4	3	600	100A	Self Contained OH/UG Lever Bypass Cold & Hot Sequence Line Bottom w/ 100A Disc Non Fused Horizontal	AMESESMCH363H	34 x 34 x 7
4	3	600	200A	Self Contained OH/UG Lever Bypass Cold & Hot Sequence Line Bottom w/ 200A Disc Non Fused Horizontal	AMESESMCH364H	34 x 34 x 7
4	3	600	400A	Self Contained OH/UG Lever Bypass Cold & Hot Sequence Line Bottom w/ 400A Disc Non Fuses Horizontal	AMESESMCH365H	34 x 34 x 7
METER AND MAINS COMBO WITH TRANSFER SWITCH FOR EMERGENCY POWER						
3	1	120/240	30A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 30A Double Throw Disconnect Horizontal	SEDPM221-1N	20 x 24 x 5 1/2
3	1	120/240	60A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 60A Double Throw Disconnect Horizontal	SEDPM222-2N	20 x 24 x 5 1/2
3	1	120/240	100A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 100A Double Throw Disconnect Horizontal	SEDPM223-3N	20 x 24 x 5 1/2
3	1	120/240	200A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 200A Double Throw Disconnect Horizontal	SEDPM224-4N	20 x 24 x 5 1/2
3	1	120/240	400A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 400A Double Throw Disconnect Horizontal	SEDPM225-5N	34 x 34 x 7
4	3	120/208	30A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 30A Double Throw Disconnect Horizontal	SEDPM321-1N	20 x 24 x 5 1/2
4	3	120/208	60A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 60A Double Throw Disconnect Horizontal	SEDPM322-2N	20 x 24 x 5 1/2
4	3	120/208	100A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 100A Double Throw Disconnect Horizontal	SEDPM323-3N	20 x 24 x 5 1/2
4	3	120/208	200A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 200A Double Throw Disconnect Horizontal	SEDPM324-4N	20 x 24 x 5 1/2



SECTION 1100. AMEREN APPROVED METER MOUNTING PRODUCTS LIST

AMERICAN MIDWEST POWER (AMP) PRODUCTS

Wires	Phase	Max Volts	Max Amps	Installation Type	Catalog #	Dim: - H x W x D (Inches)
METER AND MAINS COMBO WITH TRANSFER SWITCH FOR EMERGENCY POWER						
4	3	120/208	400A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 400A Double Throw Disconnect Horizontal	SEDPM325-5N	34 x 34 x 7
4	3	600	30A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 30A Double Throw Disconnect Horizontal	SEDPM361-1N	20 x 24 x 51/2
4	3	600	60A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 60A Double Throw Disconnect Horizontal	SEDPM362-2N	20 x 24 x 51/2
4	3	600	100A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 100A Double Throw Disconnect Horizontal	SEDPM363-3N	20 x 24 x 51/2
4	3	600	200A	Self Contained OH/UG Lever Bypass Hot Sequence w/ 200A Double Throw Disconnect Horizontal	SEDPM364-4N	20 x 24 x 51/2
TERMINATION BOX					Catalog #	Dim: - H x W x D (Inches)
3	1	600	800	800A Step Bus Pad Mtd Termination Cabinet	AMESCC8-3A	45 x 39 x 24
4	3	600	800	800A Step Bus Pad Mtd Termination Cabinet	AMESCC8-4A	45 x 39 x 24
4	3	600	1000	1000A Step Bus Pad Mtd Termination Cabinet	AMESCC10-4A	45 x 39 x 24
4	3	600	1200	1200A Step Bus Pad Mtd Termination Cabinet	AMESCC12-4A	45 x 39 x 24
4	3	600	1600	1600A Step Bus Pad Mtd Termination Cabinet	AMESCC16-4A	45 x 39 x 24
4	3	600	2000	2000A Step Bus Pad Mtd Termination Cabinet	AMESCC20-4A	60 x 39 x 24
4	3	600	2500	2500A Step Bus Pad Mtd Termination Cabinet	AMESCC25-4A	60 x 39 x 24
4	3	600	3000	3000A Step Bus Pad Mtd Termination Cabinet	AMESCC30-4A	60 x 39 x 24



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

COOPER B-LINE METER SOCKETS LIST

APPLICATION						AMEREN METER SOCKETS APPROVAL LIST			NUMBER OF TERMINALS	MAX HUB SIZE
WIRES	PHASE	SERVICE AMPS	VOLTS	SERVICE TYPE	MAX AMPS	INSTALLATION TYPE	BY-PASS	CATALOG NUMBER		
METER/MAIN COMBO - 320AMP										
4	3	320A	120/240	-	320A	SELF-CONTAINED OH/UG	LEVER	EL32T76GRST	7	4"
3	1	320A	120/240	-	320A	SELF-CONTAINED UG W/2-200A CB	LEVER	ELCB32C25A4GR1F	5	NONE
METER/MAIN COMBO - 200AMP AND BELOW										
4	3	200A/POSITION	120/240	-	0-200A	SELF-CONTAINED OH/UG	LEVER	EL20L73GRST	7	4"
3	1	200A/POSITION	120/240	-	0-200A	SELF-CONTAINED OH/UG	LEVER	EL20L53GRST	5	4"
4	3	200A/POSITION	240V MAX.	2 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20732CGR1N	7	2 1/2"
3	1	200A/POSITION	120/240	2 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20432CGR1N	5	2 1/2"
3	1	200A/POSITION	120/240	3 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20433CGR1N	5	2 1/2"
3	1	200A/POSITION	120/240	4 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20434CGR1N	5	2 1/2"
3	1	200A/POSITION	120/240	2 GANG	0-200A	SELF-CONTAINED OH/UG w/ CB PROVISION	LEVER	VELMP20432LGRST5K9	5	2 1/2"
3	1	200A/POSITION	120/240	3 GANG	0-200A	SELF-CONTAINED OH/UG (with 2 1/2" k.O Left)	LEVER	VELMP20433CGRST5K9	5	2 1/2"
3	1	200A/POSITION	120/240	4 GANG	0-200A	SELF-CONTAINED OH/UG w/ CB PROVISION	LEVER	VELMP20434CGRST5K9	5	2 1/2"
3	1	200A/POSITION	120/240	5 GANG	0-200A	SELF-CONTAINED OH/UG w/ CB PROVISION	LEVER	VELMP20435CGRST5K9	5	2 1/2"
4	3	200A/POSITION	240V MAX.	3 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20733CGR1N	7	2 1/2"
4	3	200A/POSITION	240V MAX.	4 GANG	0-200A	SELF-CONTAINED OH/UG	LEVER	HEL20734CGR1N	7	2 1/2"

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

EATON/CH

WIRES	PHASE	VOLTS	SERVICE AMPS	CATALOG NUMBER	Max Hub Size	Height	Width	Depth
INDIVIDUAL METER SOCKETS								
3	1 (5-Terminal)	120/240	200	UTTE5213*CH	4"	19"	13"	4 15/16"
4	3 (7-terminal)	120/208	200	UTTE7213*CH	4"	19"	13"	4 15/16"
3	1 (5-Terminal)	120/240	320	1008792*CH	4"	34 5/8"	15"	5 11/16"
4	3 (7-terminal)	120/208	320	1009771*CH	4"	36 5/8"	15"	5 11/16"
*Denotes Overhead Hub Style B= small hub opening C=small hub with closing plate mounted T=Large hub opening hub								
INDIVIDUAL - INSTRUMENT RATED METER SOCKETS -- Illinois Only								
3 OR 4	1 & 3 (8-Terminal)	120/240	20	ULTS81C227CH (ILLINOIS ONLY)	2-1/2"	22"	12"	4 15/16"
4	3 (13-terminal)	120/240	20	ULTS131C228CH (ILLINOIS ONLY)	2-1/2"	22"	12"	4 15/16"
METER STACKS - HORIZONTAL MOUNTED								
3	3 (5-terminal)	120/240	200	UT2H52353TCH	2-GANG HORIZONTAL	23 9/16"	32 25/32"	6"
3	3 (5-terminal)	120/240	200	UT3H52353TCH	3-GANG HORIZONTAL	23 9/16"	43 29/32"	6"
3	3 (5-terminal)	120/240	200	UT4H52353TCH	4-GANG HORIZONTAL	23 9/16"	61 1/32"	6"
3	3 (5-terminal)	120/240	200	UT5H52353TCH	5-GANG HORIZONTAL	23 9/16"	72 5/32"	6"
3	3 (5-terminal)	120/240	200	UT6H52353TCH	6-GANG HORIZONTAL	23 9/16"	83 9/32"	6"
4	3 (7-terminal)	120/208	200	UT2H72353TCH	2-GANG HORIZONTAL	23 9/16"	32 25/32"	6"
4	3 (7-terminal)	120/208	200	UT3H72393TCH	3-GANG HORIZONTAL	23 9/16"	43 29/32"	6"
4	3 (7-terminal)	120/208	200	UT4H72393TTCH	4-GANG HORIZONTAL	23 9/16"	61 1/32"	6"
4	3 (7-terminal)	120/208	200	UT5H72393TTCH	5-GANG HORIZONTAL	23 9/16"	72 5/32"	6"
4	3 (7-terminal)	120/208	200	UT6H72393TTCH	6-GANG HORIZONTAL	23 9/16"	83 9/32"	6"



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

EATON/CH

WIRES	PHASE	VOLTS	SERVICE AMPS	CATALOG NUMBER	Max Hub Size	Height	Width	Depth
Meter Combo Unit with Branch Circuit Breakers								
3	1	200	120/240	2P, 200A Main Breaker, no interior	CMBXB200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker, 12 ckt LC interior	CMBX1212B200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker Provision, 12 ckt LC interior	CMBX1212P200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker, 32 sp/42 ckt LC interior	CMBX3242B200BTS	41 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker provision, no interior	CMBXP200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	150A	120/240	2P, 150A Main Breaker, 20 sp/40 ckt LC interior	MBX2040B150BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker, 20 sp/40 ckt LC interior	MBX2040B200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker, 20 sp/40 ckt LC interior	MBX2040PV200BTS	39 13/16"	14 3/16"	4 15/16"
3	1	150A	120/240	2P, 150A Main Breaker, 8 sp/16 ckt LC interior	MBX816B150BTS	39 13/16"	14 3/16"	4 15/16"
3	1	200A	120/240	2P, 200A Main Breaker, 8 sp/16 ckt LC interior	MBX816B200BTS	39 13/16"	14 3/16"	4 15/16"

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

EATON/CH

WIRES	PHASE	VOLTS	SERVICE AMPS	CATALOG NUMBER	Max Hub Size	Height
METER MAINS/METER STACKS						
3	1	1200	120/240	1 Gang	225	35MM120R12*
3	1	1200	120/240	2 Gang	225	35MM220R12*
3	1	1200	120/240	3 Gang	225	35MM320R12*
3	1	1200	120/240	4 Gang	225	35MM420R12*
3	1	1200	120/240	5 Gang	225	35MM420R12*
3	1	1200	120/240	4 Gang	400	35MM140R1240*
4	3	1200	120/208	1 Gang	225	37MM120R12*
4	3	1200	120/208	2 Gang	225	37MM220R12*
4	3	1200	120/208	3 Gang	225	37MM320R12*
4	3	1200	120/208	4 Gang	225	37MM420R12*
4	3	1200	120/208	1 Gang W/ Provisions for 2-200A Main Breakers	400	37MM140R12*
4	3	1200	120/208	1 Gang	400	37MM140R1240*
3	1	800	120/208	2 Gang	125	3MM212RRLV
3	1	800	120/208	3 Gang	125	3MM312RRLV
3	1	800	120/208	4 Gang	125	3MM412RRLV
3	1	800	120/208	5 Gang	125	3MM512RRLV
METER MAINS/METER STACKS						
3	1	800	120/208	5 Gang	125	3MM512RRLVH
3	1	800	120/208	6 Gang	125	3MM612RRLV
3	1	800	120/208	6 Gang	125	3MM612RRLVH
3	1	1200	120/208	2 Gang	125	3MM212RRLV12RLV
METER MAINS/METER STACKS						
3	1	1200	120/208	3 Gang	125	3MM312RRLV12RLV
3	1	1200	120/208	4 Gang	125	3MM412RRLV12RLV



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

EATON/CH

WIRES	PHASE	VOLTS	SERVICE AMPS	CATALOG NUMBER	Max Hub Size	Height
3	1	1200	120/208	5 Gang	125	3MM512RRLV12RLV
3	1	1200	120/208	5 Gang	125	3MM512RRLV12H
3	1	1200	120/208	6 Gang	125	3MM612RRLV12RLV
3	1	1200	120/208	6 Gang	125	3MM612RRLV12H
3	1	200	120/208	2 Gang	125	1MP2122RRLV
3	1	400	120/208	3 Gang	125	1MP3124RRLV
3	1	400	120/208	4 Gang	125	1MP4124RRLV
3	1	600	120/208	5 Gang	125	1MP5126RRLV
3	1	600	120/208	6 Gang	125	1MP6126RRLV
3	1	400	120/208	2 Gang	125	1MP2204RRLV
3	1	400	120/209	3 Gang	126	1MP2204RRLV
3	1	600	120/208	4 Gang	125	1MP4206RRLV
3	1	600	120/208	5 Gang	125	1MP5206RRLV
3	1	600	120/208	6 Gang	125	1MP6206RRLV
*Add C to suffix for copper meter stacks if required						
Temporary Power Pole						
3	1	600	120/240	Temporary Power Pole 100 MB		CHR7N7NSU100M
400-800A CT Sections (TOP) with Disconnects (Bottom), Wall Mounted Line Entry at Top, Load Exit at Bottom						
4	3	201-400	120/240 OR 120/208	400A CT METERING BAR TYPE BUSSED CT WITH FUSED CLASS T PULLOUT DISCONNECT SWITCH LUGS FOR 500MCM OR 2-4/0		CTAP425NCM8CH
4	3	601-800A	120/240 OR 120/208	800A CT METERING BAR TYPE BUSSED CT WITH FUSED CLASS T DISCONNECT SWITCH WITH 3-500MCM LUGS		CTAT427NCM8CH



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

EATON/CH

WIRES	PHASE	VOLTS	SERVICE AMPS	CATALOG NUMBER	Max Hub Size	Height
4	3	401-600	120/240 OR 120/208	600A CT METERING BAR TYPE BUSSED CT WITH FUSED CLASS T DISCONNECT SWITCH WITH 2-500MCM LUGS		CTAT426NCM8CH
4	3	201-400	120/240 OR 120/208	400A CT METERING BAR TYPE BUSSED CT WITH FUSED CLASS T PULLOUT DISCONNECT SWITCH WITH 600MCM LUGS		CTAT425NCM8CH
4	3	201-400	120/240 OR 120/208	400A CT METERING BAR TYPE BUSSED CT WITH FUSED 2-200A CLASS T PULLOUTS DISCONNECT SWITCH		CTAP4244NCM8CH
Cold Sequency Meter Tap Enclosure						
3	1	600	277/480	2 Gang		ETNPRL3COLDSEQ

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC**BUSSED CT CABINETS - WALL MOUNTED, SEE NOTE 1 AND 2**

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	1	120/240	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-41-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-43-AMR	N/A
3	3	120/240	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-44-AMR	N/A
4	3Y	120/208	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-44-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-43-PTL-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING -BAR TYPE CT'S BUSSED CABINET	CT-44-PTL-AMR	N/A
3	1	120/240	401-800A	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-81-AMR	N/A
3	3 DELTA	240	401-800A	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-83-AMR	N/A
4	3	120/240	401-800A	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-84-AMR	N/A
4	3Y	120/208	401-800A	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-84-AMR	N/A
3	3 DELTA	480	401-800	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-83-PTL-AMR	N/A
4	3Y	277/480	401-800A	600/800A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-84-PTL-AMR	N/A
3	3 DELTA	240	801-1200A	1200A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-123-AMR	N/A
4	3	120/240	801-1200A	1200A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-124-AMR	N/A
4	3Y	120/208	801-1200A	1200A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-124-AMR	N/A
3	3 DELTA	480	801-1200A	1200A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-123-PTL-AMR	N/A
4	3Y	277/480	801-1200A	1200A CT METERING BAR TYPE CT'S BUSSED CABINET	CT-124-PTL-AMR	N/A
3	3 DELTA	240	1201-1600A	1600 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-163-AMR	N/A
4	3	120/240	1201-1600A	1600 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-164-AMR	N/A
4	3Y	120/208	1201-1600A	1600 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-164-AMR	N/A
3	3 DELTA	480	1201-1600A	1600 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-163-PTL-AMR	N/A

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

BUSSED CT CABINETS - WALL MOUNTED, SEE NOTE 1 AND 2

4	3Y	277/480	1201-1600A	1600 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-164-PTL-AMR	N/A
3	3 DELTA	240	1601-2000A	2000 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-203-AMR	N/A
4	3	120/240	1601-2000A	2000 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-204-AMR	N/A
4	3Y	120/208	1601-2000A	2000 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-204-AMR	N/A
3	3 DELTA	480	1601-2000A	2000 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-203-PTL-AMR	N/A
4	3Y	277/480	1601-2000A	2000 CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-204-PTL-AMR	N/A
3	3 DELTA	240	2001-2500	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-253-AMR	N/A
4	3	120/240	2001-2500	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-254-AMR	N/A
4	3Y	120/208	2001-2500	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-254-AMR	N/A
3	3 DELTA	480	2001-2500	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-253-PTL-AMR	N/A
4	3Y	277/480	2001-2500	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-254-PTL-AMR	N/A
3	3 DELTA	240	2501-3000A	3000A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-303-AMR	N/A
4	3	120/240	2501-3000A	3000A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-304-AMR	N/A
4	3Y	120/208	2501-3000A	3000A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-304-AMR	N/A
3	3 DELTA	480	2501-3000A	3000A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-303-PTL-AMR	N/A
4	3Y	277/480	2501-3000A	3000A CT METERING WINDOW TYPE CT'S BUSSED CABINET	CT-304-PTL-AMR	N/A

- Note:
1. CATALOG NUMBERS SERIES "CT" MUST ORDER SIDE WIRING GUTTER FOR USE WITH UNDERGROUND SERVICE CONDUCTORS (BOTTOM ENTRY/BOTTOM EXIT) FOR 1200A AND ABOVE, AND THE SIDE GUTTER CAN BE MOUNTED ON EITHER RIGHT OR LEFT SIDE OF CT CABINET
 2. CATALOG NUMBER SERIES "CT" CAN ALSO ORDER WITH SERIES VL OR VLS SERVICE DISCONNECT SWITCH



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

CT & PT ENCLOSURES - PAD MOUNTED, FREE STANDING

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	1	120/240	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-41-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-43-AMR	N/A
4	3	120/240	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-44-AMR	N/A
4	3Y	120/208	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-44-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-43-PTL-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-44-PTL-AMR	N/A
3	1	120/240	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-81-AMR	N/A
3	3 DELTA	240	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-83-AMR	N/A
4	3	120/240	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-84-AMR	N/A
4	3Y	120/208	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-84-AMR	N/A
3	3 DELTA	480	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-83-PTL-AMR	N/A
4	3Y	277/480	401-800A	600A/800A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-84-PTL-AMR	N/A
3	3	240	801-1200A	1200A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-123-AMR	N/A
4	3	120/240	801-1200A	1200A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-124-AMR	N/A
4	3Y	120/208	801-1200A	1200A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-124-AMR	N/A
3	3 DELTA	480	801-1200A	1200A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-123-PTL-AMR	N/A
4	3Y	277/480	801-1200A	1200A CT METERING - BAR TYPE CT'S BUSSED CT CABINET	PMCT-124-PTL-AMR	N/A
3	3	240	1201-1600A	1600A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-163-AMR	N/A
4	3	120/240	1201-1600A	1600A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-164-AMR	N/A
4	3Y	120/208	1201-1600A	1600A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-164-AMR	N/A
3	3 DELTA	480	1201-1600A	1600A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-163-PTL-AMR	N/A
4	3Y	277/480	1201-1600A	1600A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-164-PTL-AMR	N/A
3	3	240	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-203-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

CT & PT ENCLOSURES - PAD MOUNTED, FREE STANDING

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
4	3	120/240	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-204-AMR	N/A
4	3Y	120/208	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	CT-254-AMR	N/A
3	3 DELTA	480	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-203-PTL-AMR	N/A
4	3Y	277/480	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-204-PTL-AMR	N/A
3	3	240	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-253-AMR	N/A
4	3	120/240	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-254-AMR	N/A
4	3Y	120/208	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-254-AMR	N/A
3	3 DELTA	480	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-253-PTL-AMR	N/A
4	3Y	277/480	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-254-PTL-AMR	N/A
3	3	240	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-303-AMR	N/A
4	3	120/240	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-304-AMR	N/A
4	3Y	120/208	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-304-AMR	N/A
3	3 DELTA	480	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-303-PTL-AMR	N/A
4	3Y	277/480	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCT-304-PTL-AMR	N/A
3	3	240	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3210-AMR	N/A
4	3	120/240	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4210N-AMR	N/A
4	3Y	120/208	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4210N-AMR	N/A
3	3 DELTA	480	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3610-PTL-AMR	N/A
4	3Y	277/480	1601-2000A	2000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4610N-PTL-AMR	N/A
3	3	240	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3211-AMR	N/A
4	3	120/240	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4211N-AMR	N/A
4	3Y	120/208	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4211N-AMR	N/A
3	3 DELTA	480	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3611-PTL-AMR	N/A
4	3Y	277/480	2001-2500A	2500A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4611N-PTL-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

CT & PT ENCLOSURES - PAD MOUNTED, FREE STANDING

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	3	240	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3212-AMR	N/A
4	3	120/240	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4212N-AMR	N/A
4	3Y	120/208	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4212N-AMR	N/A
3	3 DELTA	480	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-3612-PTL-AMR	N/A
4	3Y	277/480	2501-3000A	3000A CT METERING - WINDOW TYPE CT'S BUSSED CT CABINET	PMCTCC-4612N-PTL-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
400-800A CT & PT SECTIONS (BOTTOM) WITH DISCONNECTS (TOP) - WALL MOUNTED LINE ENTRY AT BOTTOM, LOAD EXIT AT TOP						
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBDK-325N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBDK-325-AMR	N/A
4	3	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBDK-425N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBDK-425N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-325N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-325-AMR	N/A
4	3	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-425N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-425N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-3244N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-3244-AMR	N/A
4	3	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-4244N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-4244N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-325N-AMR	N/A
3	3 DELTA	240	1601-2000A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-325-AMR	N/A
4	3	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-425N-AMR	N/A
4	3	120/208	201-400A	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	BFCTMS-425N-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBKD-365-PT-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-365-PT-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-3644-PT-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-365-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTBKD-465N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTBP-465N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTBP-4644N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-465N-PT-AMR	N/A
3	1	120/240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-326N-AMR	N/A
3	3 DELTA	240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-326-AMR	N/A
3	3 DELTA	480	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-366-PT-AMR	N/A
4	3	120/240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-426N-AMR	N/A
4	3Y	120/208	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-426N-AMR	N/A
4	3Y	277/480	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-466N-PT-AMR	N/A
3	1	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-327N-AMR	N/A
3	3 DELTA	240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-327-AMR	N/A
3	3 DELTA	480	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-367-PT-AMR	N/A
4	3	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-427N-AMR	N/A
4	3Y	120/208	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-427N-AMR	N/A
4	3Y	277/480	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	BFCTMS-467N-PT-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
400-800A CT & PT SECTIONS (TOP) WITH DISCONNECTS (BOTTOM) - WALL MOUNTED LINE ENTRY AT TOP, LOAD EXIT AT BOTTOM						
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTADK-325N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTADK-325-AMR	N/A
4	3 DELTA	120/240	201-400A	400A METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTADK-425N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTADK-425N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-325N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-325-AMR	N/A
4	3 DELTA	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-425N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-425N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-3244N-AMR	N/A
3	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-3244-AMR	N/A
4	3 DELTA	240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-4244N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-4244N-AMR	N/A
3	1	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-325N-AMR	N/A
3	3 DELTA	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-325-AMR	N/A
4	3 DELTA	120/240	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-425N-AMR	N/A
4	3	120/208	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-425N-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTAKD-365-PT-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-365-PT-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-3644-PT-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-365-PT-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH CIRCUIT BREAKER DISCONNECT	CTAKD-465N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTAP-465N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCHES	CTAP-4644N-PT-AMR	N/A
4	3Y	277/480	201-400A	400A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-465N-PT-AMR	N/A
3	1	120/240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-326N-AMR	N/A
3	3 DELTA	240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-326-AMR	N/A
3	3 DELTA	480	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-366-PT-AMR	N/A
4	3	120/240	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-426N-AMR	N/A
400-800A CT & PT SECTIONS (BOTTOM) WITH DISCONNECTS (TOP) - WALL MOUNTED LINE ENTRY AT BOTTOM, LOAD EXIT AT TOP						
4	3Y	120/208	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-426N-AMR	N/A
4	3Y	277/480	401-600A	600A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-466N-PT-AMR	N/A
3	1	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-327N-AMR	N/A
3	3 DELTA	240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-327-AMR	N/A
3	3 DELTA	480	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-367-PT-AMR	N/A
4	3	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-427N-AMR	N/A
4	3Y	120/208	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-427N-AMR	N/A
4	3Y	277/480	601-800A	800A CT METERING BAR TYPE BUSSED CT WITH FUSED DISCONNECT SWITCH	CTMS-467N-PT-AMR	N/A
NOTE: CATALOG NUMBERS SERIES "CTMS" MAY BE USED WITH AN OPTIONAL SIDE WIRING GUTTER FOR USE WITH UNDERGROUND SERVICE CONDUCTORS						



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
MULTI MAINS - HOT SEQUENCE (See Notes) - WALL MOUNTED						
3	1	120/240	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-1	5
3	1	120/240	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-2	5
3	1	120/240	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-3	5
3	1	120/240	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-4	5
3	1	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-1	5
3	1	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-2	5
3	1	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-3	5
3	1	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)4-4	5
4	3	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)7-1	7
4	3	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)7-2	7
4	3	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)7-3	7
4	3	120/208	0-200A	SELF-CONTAINED OH/UG HOT SEQUENCE MODULAR METERING W/ BRKR OR CLASS "T" FUSE PULL OUT	CM(7/8/9)7-4	7
Notes:						
1) CM = Commercial Metering, Hot Sequence, Lever Bypass						
2) (7, 8, 9) Main Bus Rating 7 = 800A, 8 = 1200A, 9 = 1600A						
3) 4 = 4 Jaw Socket, 7 = 7 Jaw Socket						
4) Last # Indicates Number of Meter Positions						
C/T SECTION AT TOP, DISCONNECT AT BOTTOM (HOT SEQUENCE) - WALL MOUNTED						
3	1	120/240	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTAP325NCM(7/8/9)	SWITCH
					AMRCTAT325NCM(7/8/9)	SWITCH
3	1	120/240	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTADK325NCM(7/8/9)	BREAKER
					AMRCTAT326NCM(7/8/9)	SWITCH
3	1	120/240	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTALD326NCM(7/8/9)	BREAKER



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	1	120/240	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET AND 800A MAIN SWITCH COMBINATION	AMRCTAT327NCM(7/8/9)	SWITCH
					AMRCTAMD327NCM(7/8/9)	BREAKER
4	3	120/208	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTAT425NCM(7/8/9)	SWITCH
					AMRCTAP425NCM(7/8/9)	SWITCH
4	3	120/208	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTADK425NCM(7/8/9)	BREAKER
4	3	120/208	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTAT426NCM(7/8/9)	SWITCH
4	3	120/208	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTALD426NCM(7/8/9)	BREAKER
4	3	120/208	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET AND 800A MAIN SWITCH COMBINATION	AMRCTAT427NCM(7/8/9)	SWITCH
					AMRCTAMD427NCM(7/8/9)	BREAKER
3	1	120/240	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTBP325NCM(7/8/9)	SWITCH
3	1	120/240	201-400A	400A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTBDK325NCM(7/8/9)	BREAKER
3	1	120/240	201-400A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTBDK325NCM(7/8/9)	BREAKER
3	1	120/240	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTBLD326NCM(7/8/9)	BREAKER
3	1	120/240	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET AND 800A MAIN SWITCH COMBINATION	AMRCTBMD327NCM(7/8/9)	BREAKER
4	3	120/240	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET AND 400A MAIN SWITCH COMBINATION	AMRCTBP425NCM(7/8/9)	SWITCH
4	3	120/240	201-400A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET AND 600A MAIN SWITCH COMBINATION	AMRCTBDK425NCM(7/8/9)	BREAKER
4	3	120/208	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET AND 800A MAIN SWITCH COMBINATION	AMRCTBMD427NCM(7/8/9)	BREAKER
Note:	* (7/8/9) 7 = 800A MAIN BUS, 8 = 1200A MAIN BUS, 9 = 1600A MAIN BUS					

MULTI MAINS - COLD SEQUENCE - 480 VOLT (See Notes) - WALL MOUNTED

3	1	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CMDD(7/8/9)5-1	5
3	1	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CMDD(7/8/9)5-2	5
3	1	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CMDD(7/8/9)5-3	5



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
4	3	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CMDD(7/8/9)7-1	7
4	3	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CSCM(7/8/9)7-2	7
4	3	277/480	0-200A	SELF-CONTAINED OH/UG COLD SEQUENCE MODULAR METERING W/NON-FUSED PULL OUT METER DISCONNECT AND CLASS "T" FUSED PULL OUT MAIN DISCONNECT	6CMDD(7/8/9)7-3	7

Note:
 1) 6 CMDD = Commercial Metering Dual Disconnect (480V)
 2) (7, 8, 9) Main Bus Rating 7 = 800A, 8 = 1200A, 9 = 1600A
 3) 5 = 5 Jaw Socket, 7 = 7 Jaw Socket
 4) Last # Indicates Number of Meter Positions.

C/T & P/T SECTION AT TOP, DISCONNECT AT BOTTOM (HOT SEQUENCE) - WALL MOUNTED

4	3Y	277/480	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET W/PT PROVI. AND 400A MAIN SWITCH COMBINATION	AMRCTAP465N6CM(7/8/9)	SWITCH
					AMRCTAT465N6CM(7/8/9)	SWITCH
					AMRCTAKD465N6CM(7/8/9)	BREAKER
4	3Y	277/480	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET W/PT PROVI. AND 600A MAIN SWITCH COMBINATION	AMRCTAT466N6CM(7/8/9)	SWITCH
					AMRCTALD466N6CM(7/8/9)	BREAKER
4	3Y	277/480	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET W/PT PROVI. AND 800A MAIN SWITCH COMBINATION	AMRCTAT467N6CM(7/8/9)	SWITCH
					AMRCTAMD467N6CM(7/8/9)	BREAKER
4	3Y	277/480	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET W/PT PROVI. AND 400A MAIN SWITCH COMBINATION	AMRCTBKD465N6CM(7/8/9)	BREAKER
					AMRCTBP465N6CM(7/8/9)	SWITCH
4	3Y	277/480	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET W/PT PROVI. AND 600A MAIN SWITCH COMBINATION	AMRCTBLD466N6CM(7/8/9)	BREAKER
4	3Y	277/480	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET W/PT PROVI. AND 400A MAIN SWITCH COMBINATION	AMRCTBKD465N6CM(7/8/9)	BREAKER
4	3Y	277/480	201-400A	400A CT METERING - BAR TYPE CT'S - 400A CT CABINET W/PT PROVI. AND 400A MAIN SWITCH COMBINATION	AMRCTBP465N6CM(7/8/9)	SWITCH
4	3Y	277/480	401-600A	600A CT METERING - BAR TYPE CT'S - 600A CT CABINET W/PT PROVI. AND 600A MAIN SWITCH COMBINATION	AMRCTBLD466N6CM(7/8/9)	BREAKER
4	3Y	277/480	601-800A	800A CT METERING - BAR TYPE CT'S - 800A CT CABINET W/PT PROVI. AND 800A MAIN SWITCH COMBINATION	AMRCTBMD467N6CM(7/8/9)	BREAKER

Note: * (7/8/9) 7 = 800A MAIN BUS, 8 = 1200A MAIN BUS, 9 = 1600A MAIN BUS



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

CT & PT ENCLOSURES, PAD MOUNTED WITH MAIN SWITCH						
WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	1	120/240	321-600A	400A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-325N-AMR	N/A
3	1	120/240	321-600A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-326N-AMR	N/A
3	1	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-327N-AMR	N/A
3	3 DELTA	240	321-600A	400A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-325-AMR	N/A
3	3 DELTA	240	321-600A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-326-AMR	N/A
3	3 DELTA	240	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-327-AMR	N/A
3	3 DELTA	480	201-400A	400A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-365-PT-AMR	N/A
3	3 DELTA	480	401-600A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-366-PT-AMR	N/A
3	3 DELTA	480	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-367-PT-AMR	N/A
4	3	120/240	321-600A	400A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-425N-AMR	N/A
4	3	120/240	321-600A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-426N-AMR	N/A
4	3	120/240	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-427N-AMR	N/A
4	3Y	120/208	321-600A	400A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-425N-AMR	N/A
4	3Y	120/208	1601-2000A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-426N-AMR	N/A
4	3Y	120/208	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-427N-AMR	N/A
4	3Y	277/480	201-400A	2500A CT METERING WINDOW TYPE CT'S BUSSED CABINET	PMCTMS-465N-PT-AMR	N/A
4	3Y	277/480	401-600A	600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-466N-PT-AMR	N/A
4	3Y	277/480	601-800A	800A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-467N-PT-AMR	N/A
3	3	240	801-1200A	1200A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-328-AMR	N/A
4	3	120/240	801-1200A	1200A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-428N-AMR	N/A
4	3Y	120/208	801-1200A	1200A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-428N-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

ERICKSON ELECTRIC

CT & PT ENCLOSURES, PAD MOUNTED WITH MAIN SWITCH						
WIRES	PHASE	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBER	Terminals
3	3 DELTA	480	801-1200A	1200A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-368-PT-AMR	N/A
4	3Y	277/480	801-1200A	1200A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-468NG6-PT-AMR	N/A
3	3	240	1201-1600A	1600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-329-AMR	N/A
4	3	120/240	1201-1600A	1600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-429N-AMR	N/A
4	3Y	120/208	1201-1600A	1600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-429N-AMR	N/A
3	3 DELTA	480	1201-1600A	1600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-369-PT-AMR	N/A
4	3Y	277/480	1201-1600A	1600A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-469NG6-PT-AMR	N/A
3	3	240	1601-2000A	2000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3210-AMR	N/A
4	3	120/240	1601-2000A	2000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4210N-AMR	N/A
4	3Y	120/208	1601-2000A	2000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4210N-AMR	N/A
3	3 DELTA	480	1601-2000A	2000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3610-PT-AMR	N/A
4	3Y	277/480	1601-2000A	2000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4610NG6-PT-AMR	N/A
3	3	240	2001-2500A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3211-AMR	N/A
4	3	120/240	2001-2500A	2500A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4211N-AMR	N/A
4	3Y	120/208	2001-2500A	2500A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4211N-AMR	
3	3 DELTA	480		2500A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3611-PT-AMR	N/A
4	3Y	277/480	2001-2500A	2500A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4611NG6-PT-AMR	N/A
3	3	240	2501-3000A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3212-AMR	N/A
4	3	120/240	2501-3000A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4212N-AMR	N/A
4	3Y	120/208	2501-3000A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4212N-AMR	N/A
3	3 DELTA	480	2501-3000A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-3612-PT-AMR	N/A
4	3Y	277/480	2501-3000A	3000A CT METERING BAR TYPE BUSSED CT PAD MOUNTED CABINET WITH DISCONNECT	PMCTMS-4612NG6-PT-AMR	N/A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

GE/ABB

WIRES	PHASE	MAX SERVICE	VOLTS	SERVICE TYPE	MAX AMPS	CATALOG NUMBER	NO OF TERMINALS	Max Hub	DRAWING NUMBER
Meter Stacks									
3	1	1200	120/240	1 Gang	225	TMPR12122R	5	3 "	96-1988
3	1	1200	120/240	2 Gang	225	TMPR12222R	5	3 "	96-1988
3	1	1200	120/240	3 Gang	225	TMPR12322R	5	3 "	96-1988
3	1	1200	120/240	4 Gang	225	TMPR12422R	5	3 "	96-1988
3	1	1200	120/240	1 Gang	400	TMPR12140RB	5	3 "	96-4754
3	1	1200	120/240	2 Gang	400	TMPR12240RB	5	3 "	96-5814
4	3	1200	120/208	1 Gang	225	TMPR312122R	5	3 "	96-1988
4	3	1200	120/208	2 Gang	225	TMPR312222R	5	3 "	96-1988
4	3	1200	120/208	3 Gang	225	TMPR312322R	5	3 "	96-1988
4	3	1200	120/208	4 Gang	225	TMPR312422R	5	3 "	96-1988
4	3	1200	120/208	1 Gang W/ Provisions for 2 200A Main Breakers	400	TMPR312140TR	5	3 "	96-1988
4	3	1200	120/208	1 Gang	400	TMPR312140RB	5	3 "	96-4754
4	3	1200	120/208	2 Gang	400	TMPR312240RB	5	3 "	96-5814
4	3	up to 5000	480/277	3 gang in switchboard	200	Spectra Switchboard - Milbank #Z911500-AC	7	4"	10094423



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

GE/ABB

WIRES	PHASE	MAX SERVICE	VOLTS	SERVICE TYPE	MAX AMPS	CATALOG NUMBER	NO OF TERMINALS	Max Hub	DRAWING NUMBER
Meter Mains									
3	1	400	120/240	UG/OH	400	TMPU4R	Main Pull Box	Lugs	
3	1	800	120/240	UG/OH	800	TMPU8R	Main Pull Box	Lugs	
3	1	1200	120/240	UG/OH	1200	TMPU12R	Main Pull Box	Lugs	
3	4	400	120/208	UG/OH	400	TMP3U4R	Main Pull Box	Lugs	
3	4	800	120/208	UG/OH	800	TMP3U8R	Main Pull Box	Lugs	
3	4	1200	120/208	UG/OH	1200	TMP3U12R	Main Pull Box	Lugs	
4	3	1600 or 2000	120/208	UG	1600 or 2000	Tap Box per GE drawing 75A662689	Main Lugs	Lugs	
3	1	400	120/240	use with TMPU4R	400	TMPSB4R	Main breaker	SGH400	65 kAIC
3	1	400	120/240	use with TMPU4R	400	TMPSHB4R	Main breaker	SGH400	100 kAIC
3	1	600	120/240	use with TMPU8R	600	TMPSB6R	Main breaker	SGH600	65 kAIC
3	1	600	120/240	use with TMPU8R	600	TMPSHB6R	Main breaker	SGH600	100 kAIC
3	1	800	120/240	use with TMPU8R	800	TMPSB8R	Main breaker	SKH800	65 kAIC
3	1	1200	120/240	use with TMPU12R	1200	TMPSB12R	Main breaker	SKH1200	65 kAIC
3	1	1400	120/240	use with tap box	1400	TMPB(B or T)14R	Main breaker	RG	100 kAIC
3	1	1600	120/240	use with tap box	1600	TMPB(B or T)16R	Main breaker	RG	100 kAIC
3	1	1600	120/240	use with tap box	1600	TMPB(B or T)16RST	Main breaker	RG	100 kAIC
3	1	2000	120/240	use with tap box	2000	TMPB(B or T)20R	Main breaker	RG	100 kAIC
4	3	400	120/208	use with TMP3U4R	400	TMP3SB4R	Main breaker	SGH400	65 kAIC
4	3	400	120/208	use with TMP3U4R	400	TMP3SHB4R	Main breaker	SGH400	100 kAIC
4	3	600	120/208	use with TMP3U8R	600	TMP3SB6R	Main breaker	SGH600	65 kAIC
4	3	600	120/208	use with TMP3U8R	600	TMP3SHB6R	Main breaker	SGH600	100 kAIC
4	3	800	120/208	use with TMP3U8R	800	TMP3SB8R	Main breaker	SKH800	65 kAIC
4	3	1200	120/208	use with TMP3U12R	1200	TMP3SB12R	Main breaker	SKH1200	65 kAIC
4	3	1400	120/208	use with tap box	1400	TMP3B(B or T)14R	Main breaker	RG	100 kAIC



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

GE/ABB

WIRES	PHASE	MAX SERVICE	VOLTS	SERVICE TYPE	MAX AMPS	CATALOG NUMBER	NO OF TERMINALS	Max Hub	DRAWING NUMBER
Meter Mains									
4	3	1600	120/208	use with tap box	1600	TMP3B(B or T)16R	Main breaker	RG	100 kAIC
4	3	1600	120/208	use with tap box	1600	TMP3B(B or T)16RST	Main breaker	RG	100 kAIC
4	3	1600	120/208	use with tap box	1600	TMP3BB16RCLL	Main breaker	RG	100 kAIC
4	3	2000	120/208	use with tap box	2000	TMP3B(B or T)20R	Main breaker	RG	100 kAIC
4	3	2000	120/208	use with tap box	2000	TMP3B(B or T)20RST	Main breaker	RG	100 kAIC
4	3	2000	120/208	use with tap box	2000	TMP3BB20RCLL	Main breaker	RG	100 kAIC
3	1	400	120/240	use with TMPU4R	400	TMPF(T or B)4R	Main Fused Switch	Class T	100 kAIC
3	1	600	120/240	use with TMPU8R	600	TMPF(T or B)6R	Main Fused Switch	Class T	100 kAIC
3	1	800	120/240	use with TMPU8R	800	TMPF(T or B)8R	Main Fused Switch	Class T	100 kAIC
3	1	1200	120/240	use with TMPU12R	1200	TMPF(T or B)12R	Main Fused Switch	Class L	100 kAIC
3	1	1200	120/240	use with TMPU12R	1200	TMPFB12RT	Main Fused Switch	Class T	100 kAIC
4	3	400	120/208	use with TMP3U4R	400	TMP3F(T or B)4R	Main Fused Switch	Class T	100 kAIC
4	3	600	120/208	use with TMP3U8R	600	TMP3F(T or B)6R	Main Fused Switch	Class T	100 kAIC
4	3	800	120/208	use with TMP3U8R	800	TMP3F(T or B)8R	Main Fused Switch	Class T	100 kAIC
4	3	1200	120/208	use with TMP3U12R	1200	TMP3F(T or B)12R	Main Fused Switch	Class L	100 kAIC
4	3	1200	120/208	use with TMP3U12R	1200	TMP3FB12RT	Main Fused Switch	Class T	100 kAIC
4	3	1200	120/208	use with TMP3U12R	1200	TMP3FB12RST	Main Fused Switch	Class L	100 kAIC
4	3	1600	120/208	use with tap box	1600	TMP3FB16R	Main Fused Switch	Class L	100 kAIC
4	3	1600	120/208	use with tap box	1600	TMP3FB16RST	Main Fused Switch	Class L	100 kAIC
4	3	2000	120/208	use with tap box	2000	TMP3FB20R	Main Fused Switch	Class L	100 kAIC
4	3	2000	120/208	use with tap box	2000	TMP3FB20RST	Main Fused Switch	Class L	100 kAIC



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MIDWEST ELECTRIC SOCKET & BREAKER COMBINATIONS LIST

Wires	Phase	Terminals	Volts	Service Type	Amps	Installation	Bypass	Catalog#
Temporary Power - Surface Mount - Residential								
3	1	4 or 5*	120/240	Temp with 3 circuit spaces	100	UG (1.5")	Horn	R011C010U
3	1	4 or 5*	120/240	Temp with 3 circuit spaces	100	OH	Horn	R011C010
3	1	4 or 5*	120/240	Temp with 6 circuit spaces	100	OH	Horn	R101CB2010
		*5th jaw kit	120/208					MS5
Combination Sockets - Surface Mount								
3	1	5	120/240	Main with 4 circuit spaces	200	OH/UG (3")	Lever	R281CB1034
3	1	5	120/240	Main with 4 circuit spaces	200	OH	Lever	R281C1034
Metered Combination Pedestal Units								
3	1	5	120/240	Main with 4 circuit spaces	200	UG	Lever	R481C1P6H034
3	1	5	120/240	Main with 4 circuit spaces	200	UG	Lever	R281C1P6H034
3	1	5	120/240	Main with 4 circuit spaces	200	UG	Lever	R281E1P6H034



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
TEMPORARY POWER - METER MAINS									
3	1	100	120/240	0-125A	SELF-CONTAINED OH ONLY	U5101-XL-100MB-11GR	4	2 1/2"	19 1/4 X 9 1/8 X 5 5/5
						U5101-XL-11GR			19 1/4 X 9 1/8 X 5 5/5
3	1	100	120/240	0-125A	SELF-CONTAINED UG ONLY	U4908-O-100MB-11GR	4	2 1/2"	24 15/16 X 9 x 3 5/16
						U4908-O-11GR			24 15/16 X 9 x 3 5/16
3	1	200	120/240	0-200A	SELF-CONTAINED OH ONLY	U5098-XL-200S-10GR	4	2 1/2"	32 X 14 X 5 1/2
METER MAINS WITH TRANSFER SWITCH FOR EMERGENCY POWER									
WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1	125	120/240	0-125A	SELF-CONTAINED OH ONLY- METER MAIN COMBO W/ DISCONNECT FOR AUXILARY GENERATOR APPLICATIONS	U5871-XL-100-5T9-AMS W/ K5830 KIT	5	2 1/2"	33 1/2 X 14 1/8 X 4 1/2
3	1	125	120/240	0-125A	SELF-CONTAINED OH ONLY- METER MAIN COMBO W/ DISCONNECT FOR AUXILARY GENERATOR APPLICATIONS	U6012-XL-100-K1-5T6-AMS W/ K5830 KIT	5	2 1/2"	39.25 X 14.13 X 4.5
3	1	200	120/240	0-200A	SELF-CONTAINED OH ONLY- METER MAIN COMBO W/ DISCONNECT FOR AUXILARY GENERATOR APPLICATIONS	U5871-XL-200-5T9-AMS W/ K5820 OR K5815 KIT	5	2 1/2"	33 1/2 X 14 1/8 X 4 1/2
3	1	200	120/240	0-200A	SELF-CONTAINED OH/UG- METER MAIN COMBO W/ DISCONNECT FOR AUXILARY GENERATOR APPLICATIONS	U6012-XL-200-K1-5T6-AMS W/ K5815 KIT OR K5820	5	2 1/2"	39.25 X 14.13 X 4.5
3	1	200	120/240	0-200A	SELF-CONTAINED OH ONLY- METER MAIN COMBO W/ DISCONNECT FOR AUXILARY GENERATOR APPLICATIONS	U4834-XL-200-5T9-AMS W/ AUXILARY BREAKER ORDERED SEPARATELY-UQFP SERIES BREAKER	5	2 1/2"	39X17X5 1/2
INDIVIDUAL METER SOCKETS									
3	1	125	120/240	0-125A	SELF-CONTAINED OH ONLY	U6193-YL-QG-AMS	5	1 1/4"	18.5 X 10 X 4.844
						U6193-RL-QG-AMS		2 1/2"	18.5 X 10 X 4.844
3	1	200	120/240	0-200A	SELF-CONTAINED OH/UG	U9551-RXL-QG-AMS	5	4"	19 X 13 X 4.844
3	1	200	120/240	0-200A	SELF-CONTAINED OH ONLY	U9550-RRL-QG-AMS	5	4"	18.5 X 10 X 4.844
						U9550-RDL-QG-AMS		2"	18.5 X 10 X 4.844

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

METER MAINS COMBO									
WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1	125	120/240	0-125A	SELF -CONTAINED OH ONLY -METER MAIN COMBO WITH DISCONNECT	U3791N-RXL-100-5T9-AMS	5	4"	34 X 13 X 4.844
						U5871-XL-100-5T9-AMS	5	2 1/2"	33 1/2 X 14 1/8 X4 1/2
						U6012-XL-100-K1-5T6-AMS	5	2 1/2"	39.25 X 14.13 X 4.5
						U6281-XL-100-5T6-AMS	5	2 1/2"	34 X 14 1/8" x 4.5"
3	1	200	120/240	0-200	SELF-CONTAINED OH/UG WITH DISC.	U6281-XL-200-5T6-AMS	5	2 1/2"	35 X 14 1/8" x 4.5"
					SELF-CONTAINED OH/UG WITH DISC.	U6012-XL-200-K1-5T6-AMS	5	2 1/2"	39.25 X 14.13 X 4.5
					SELF-CONTAINED OH WITH DISC.	U3791N-RXL-200-5T9-AMS	5	4"	34 X 13 X 4.844
3	1	200	120/240	0-200A	SELF-CONTAINED OH WITH DISC.	U5871-XL-200-5T9-AMS	5	2 1/2"	33 1/2 X 14 1/8 X 4 1/2
4	3	200	120/208 120/240	0-200A	SELF-CONTAINED OH/UG	U5750-RXL-200-BL-AMS	7	4"	34 X 17 3/8 X 5 3/4"
					SELF-CONTAINED OH/UG W/ 2-200A DISC	U5059-X-2/200-K3L5T6-AMS		4"	42x15x4 7/8
					SELF-CONTAINED OH/UG W/ 2-200A DISC	U5890-X-2/200-K3L-5T6-AMS		4"	35x24.5x6
					SELF-CONTAINED OH/UG W/ 2-200A DISC	U5891-X-2/200-K3L-5T6-MLK-AMS		4"	35x29.5x6
					SELF-CONTAINED OH/UG W/ 2-200A DISC	U5892-X-2/200-K3L-5T6-MLK-AMS		4"	35x29.5x6
3	1	400	120/240	201-400A	SELF-CONTAINED OH/UG W/ 400A DISC	U6227-X-400-K3L-5T6-AMS	5	4"	34x36.25x6
					SELF-CONTAINED OH/UG W/ 2/200 A DISC	U6115-X-2/200-K7L-AMS		4"	34x36.25x6
4	3	400	120/240 120/208	201-400	SELF-CONTAINED OH/UG W/ 400A DISC	U6229-X-400-K7L-AMS	7	4"	34x36.25x6

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

INDIVIDUAL METER SOCKETS									
WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1	400	120/240	201-400A	SELF-CONTAINED OH/UG	U5786-X-2/K2-5T6-BL-AMS U5786-X-K3-K2-5T6-BL-AMS	5	4"	38 3/4 x 17 3/4 x 6 1/2 38 3/4 x 17 3/4 x 6 1/2
					SELF-CONTAINED OH/UG	U4778-X-BL W/ K3865 KIT			38 3/4 x 17 3/4 x 6 1/2
					SELF-CONTAINED OH/UG	U5740-X-K3L-K2L-5T6-AMS			31.69 X 15 X 4.85
					SELF-CONTAINED OH ONLY	U1079-X-QG-K3-K2-5T6-AMS			38 3/4 X 13 X 4 7/8
					SELF-CONTAINED OH ONLY	U4363-X-QG-K3-K2-5T6-AMS			28 1/4x13x4 27/32
3	1	200	120/240	0-200A	SELF-CONTAINED OH/UG	U9551-RXL-QG-AMS	5	4"	19 X 13 X 4 7/8
					SELF-CONTAINED OH	U9550-RDL-QG-AMS	5	2"	18 1/2 X 10 X 4 7/8
					SELF-CONTAINED OH/UG	U9581-RXL-QG-AMS	5	4"	19 x 13 x 4 7/8
					SELF-CONTAINED OH/UG	UAP9551-XL-QG-HSP	5	2 1/2"	19 x 13 x 4 25/32
					SELF-CONTAINED OH/UG	UAP9581-XL-QG	5	2 1/2"	19 x 13 x 4 25/32
3	NETWORK	200	120/208	0-200A	SELF-CONTAINED OH/UG	U9551-RXL-QG-AMS	5	4"	19 X 13 X 4 7/8
					SELF-CONTAINED OH	U9550-RDL-QG-AMS	5	2"	18 1/2 X 10 X 4 7/8
					SELF-CONTAINED OH/UG	UAP9581-XL-QG	5	2 1/2"	19 x 13 x 4 25/32
					SELF-CONTAINED OH/UG	U9581-RXL-QG-AMS	5	4"	19 x 13 x 4 25/32
					SELF-CONTAINED OH/UG	UAP9551-XL-QG-HSP	5	2 1/2"	19 x 13 x 4 25/32
3	3 DELTA	200	240	0-200A	SELF-CONTAINED OH/UG	U9551-RXL-QG-AMS	5	4"	19 X 13 X 4 7/8
					SELF-CONTAINED OH	U9550-RDL-QG-AMS	5	2"	18 1/2 X 10 X 4 7/8
					SELF-CONTAINED OH/UG	U9581-RXL-QG-AMS	5	4"	19 x 13 x 4 25/32
					SELF-CONTAINED OH/UG	UAP9551-XL-QG-HSP	5	2 1/2"	19 x 13 x 4 25/32
					SELF-CONTAINED OH/UG	UAP9581-XL-QG	5	2 1/2"	19 x 13 x 4 25/32
4	3	200	120/240 120/208	0-200A	SELF-CONTAINED OH/UG	U9701-RXL-QG-AMS	7	4"	19 X 13 X 4 7/8
					SELF-CONTAINED OH	U9700-RRL-QG-AMS	7	4"	18 1/2 X 10 X 4 7/8
3	3 DELTA	400	240	201-400	SELF-CONTAINED OH ONLY	U1079-X-QG-K3-K2-5T6-AMS	5	4"	38 3/4 X 13 X 4 7/8
3	3 DELTA	400	240	201-400	SELF-CONTAINED OH/UG	U5740-X-K3L-K2L-5T6-AMS W/ K5979	5	4"	31.69 X 15 X 4.85
4	3	400	120/240	201-400A	SELF-CONTAINED OH/UG	U4911-X-QG-BL-AMS	7	4"	38 3/4x17 3/4x6 1/2
4	3Y	400	120/208	201-400A	SELF-CONTAINED OH/UG	U4911-X-QG-BL-AMS	7	4"	38 3/4x17 3/4x6 1/2

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

METER PEDESTALS -COMMERCIAL									
WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B51C1PAAOMO1	5	N/A	48 X 16 X 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B51C1PBAOMO2	5	N/A	48 X 24 X 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B51C1PBAOMO3	5	N/A	48 X 24 X 17
3	1	200A	480	0-200A	SELF-CONTAINED UNDERGROUND ONLY - (REPLACED BY NEXT MODEL W/ CS1 SUFFIX)	CP3B51D1PBAOMO1	5	N/A	48 x 24 x 17
3	1	200A	480	0-200A	SELF-CONTAINED UNDERGROUND ONLY - COLD SEQUENCE (FUSED DISC.)	CP3B51D1PBAOMO1CS1	5	N/A	48 x 24 x 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B62C2NBAOMO1	5	N/A	48 x 24 x 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B51110A22SL1 - K3865	5	N/A	48 x 16 x 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B52110A22SL1 - K3865	5	N/A	48x16x17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B51115A22 - K3865	5	N/A	48 x 16 x 17
3	1	200A	120/240	0-200A	SELF-CONTAINED UNDERGROUND ONLY	CP3B52119A22 - K3865	5	N/A	48 x 16 x 17
WALL MOUNTED METER PEDESTAL (Also available Stand-Alone for additional burial kit)									
3	1	200	120/240	0-200A	Self-contained	U9108-0-CECHA	5		62"x9"x4 1/8"
3	1	320	120/240	400A	Self-contained	U1748-0-5T9-WI	5		64" x 13" x 4 27/32"
MOBILE HOME PEDESTALS									
3	1	100A/200A	120/240	0-200A	MOBILE HOME SINGLE POSITION DIRECT BURIAL	U5701-0-100S-5T6-AMS & K5415 0-200S-5T6-AMS & K5415	U5701-5	N/A	80 X 9.88 X 4.13
3	1	100A/200A	120/241		MOBILE HOME SINGLE POSITION PAD MOUNT	U5703-0-100S-5T9 U5703-0-200S-5T9	5	N/A	80 X 9.88 X 4.13
3	1	100A/200A	120/240	0-200A	MOBILE HOME 2 GANG POSITION DIRECT BURIAL	U5702-0-100S-5T6-AMS & K5415 0-200S-5T6-AMS & K5415	U5702-5	N/A	80 X 9.88 X 4.13

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

480V COLD SEQUENCE SOCKET									
WIRES	PHASE	SERVICE AMPS	VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG #	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1	200	480	0-200A	SELF-CONTAINED OH/UG METER SOCKET ONLY	U9551-RXL-QG-AMS	5	4"	19x13x4 25/32
						U9581-RXL-QG-AMS			19x13x4 25/32
3	3 DELTA	200	480	0-200A	SELF-CONTAINED OH/UG METER SOCKET ONLY	U9551-RXL-QG-AMS	5	4"	19x13x4 25/32
4	3Y	200	277/480	0-200A	SELF-CONTAINED OH/UG METER SOCKET ONLY	U9701-RXL-QG-AMS	7	4"	19x13x4 7/8
3	3 DELTA	320	480	201-400	SELF-CONTAINED OH/UG METER SOCKET ONLY	U5740-X-K3L-K2L-5T6-AMS	5	4"	31 3/4 X 15 X4 7/8
4	3Y	320	277/480	201-400	SELF-CONTAINED OH/UG METER SOCKET ONLY	U4911-X-QG-BL-AMS	7	4"	38 3/4 X 17 3/4 X 6 1/2

ILLINOIS CT Rated Pre-Wired Meter Sockets (Customer Supplied) FOR ALL CT RATED 600 VOLTS & BELOW APPLICATIONS

WIRES	PHASE		VOLTS	MAX AMPS	INSTALLATION TYPE	CATALOG NUMBERS LEVER BY PASS	No. Terminal	Max Hub Size (in)	DIMENSIONS-HxWxD (in)
3	1		120/240		8 Terminal	U4496-XL-WC-41-AMS	8	1 1/2	22x12x4.84
3	1		480		8 Terminal	U4496-XL-WC-41-AMS	8	1 1/2	22x12x4.84
3	3 DELTA		240		8 Terminal	U4496-XL-WC-41-AMS	8	1 1/2	22x12x4.84
3	3 DELTA		480		8 Terminal	U4496-XL-WC-41-AMS	8	1 1/2	22x12x4.84
4	3		120/240		13 Terminal	U4497-XL-WC-61-AMS	13	1 1/2	22x12x4.84
4	3Y		120/208		13 Terminal	U4497-XL-WC-61-AMS	13	1 1/2	22x12x4.84
4	3Y		277/480		13 Terminal	U4497-XL-WC-61-AMS	13	1 1/2	22x12x4.84

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

METER PACKS							
WIRES	PHASE	SERVICE AMPS	VOLTS	SERVICE TYPE	INSTALLATION TYPE	CATALOG NUMBERS	DIMENSIONS-HxWxD - WxHxD(in)
3	1	200A/ Position	120/240	2 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2872-XT-QG-AMS	25 1/4 X 32 1/8 X 6
3	1	200A/ Position	120/240	3 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2873-XT-QG-AMS	25 1/4 X 42 3/16 X 6
3	1	200A/ Position	120/240	4 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2874-XT-QG-AMS	25 1/4 X 52 1/4 X 6
3	1	200A/ Position	120/240	5 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2875-XT	25 1/4 X 62 5/16 X 6
3	1	200A/ Position	120/240	6 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2876-XT	31 1/4 X 72 3/8 X 6
3	1	200A/ Position	120/240	2 GANG HORIZONTAL AND VERTICAL	SELF-CONTAINED OH/UG W/ DISC.	U4372-XT-5T9-AMS U5972-XT-5T9	VERT-48 x 27 3/4 x 6 HORIZ- 34 X 36 3/8 X 5 31/32
3	1	200A/ Position	120/240	3 GANG HORIZONTAL AND VERTICAL	SELF-CONTAINED OH/UG W/ DISC.	U4373-XT-5T9-AMS U5973-XT-5T9	VERT-60 x 27 3/4 x 6 HORIZ-34 x 46 1/2 x 5 31/32
3	1	200A/ Position	120/240	4 GANG HORIZONTAL AND VERTICAL	SELF-CONTAINED OH/UG W/ DISC.	U4374-XT-5T9-AMS U5974-XT-5T9	VERT-48 x 45 x 6 HORIZ-34 X 57 1/16 X 5 31/32
3	1	200A/ Position	120/240	5 GANG HORIZONTAL AND VERTICAL	SELF-CONTAINED OH/UG W/ DISC.	U4375-XT-5T9-AMS U5975-XT-5T9	VERT-60 x 45 x 6 HORIZ-34 X 67 1/8 X 5 31/32
3	1	200A/ Position	120/240	6 GANG HORIZONTAL AND VERTICAL	SELF-CONTAINED OH/UG W/ DISC.	U4376-XT-5T9-AMS U5976-XT-5T9	VERT-60 x 45 x 6 HORIZ- 34 X 77 9/16 X 5 31/32
4	3	200A/ Position	240V MAX.	2 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2732-XT	25 1/4 X 32 1/8 X 6
4	3	200A/ Position	240V MAX.	3 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2733-XT	25 1/4 X 42 3/16 X 6
4	3	200A/ Position	240V MAX.	4 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2734-XT	25 1/4 X 52 1/4 X 6
4	3	200A/ Position	240V MAX.	5 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2735-XT	25 1/4 X 62 5/16 X 6
4	3	200A/ Position	240V MAX.	6 GANG HORIZONTAL	SELF-CONTAINED OH/UG	U2736-XT	31 1/4 X 72 3/8 X 6

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT CABINETS - UG ENTRANCE AND TOP EXIT OR TOP ENTRY AND BOTTOM EXIT WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	250	400	AMRM-413	48H X 25W X 10D
3	3	250	400	AMRM-433	48H X 25W X 10D
4	3	250	400	AMRM-434	48H X 25W X 10D
3	1	250	600	AMRM-613	48H X 25W X 10D
3	3	250	600	AMRM-633	48H X 25W X 10D
4	3	250	600	AMRM-634	48H X 25W X 10D
3	1	250	800	AMRM-813	48H X 25W X 10D
3	3	250	800	AMRM-833	48H X 25W X 10D
4	3	250	800	AMRM-834	48H X 25W X 10D
3	3	250	1200	AMRM-1233	54H X 36W X 14D
4	3	250	1200	AMRM-1234	54H X 36W X 14D
3	3	250	1600	AMRM-1633	60H X 38W X 16D
4	3	250	1600	AMRM-1634	60H X 38W X 16D
3	3	250	2000	AMRM-2033	66H X 42W X 14D
4	3	250	2000	AMRM-2034	66H X 42W X 14D
3	3	250	2500	AMRM-2533	72H X 42W X 20D
4	3	250	2500	AMRM-2534	72H X 42W X 20D
3	3	250	3000	AMRM-3033	72H X 42W X 20D
4	3	250	3000	AMRM-3034	72H X 42W X 20D



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT-PT CABINETS - UG ENTRANCE AND TOP EXIT OR TOP ENTRY AND BOTTOM EXIT WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	3	600	400	AMRM-463	48H X 37W X 10D
4	3	600	400	AMRM-464	48H X 37W X 10D
3	3	600	600	AMRM-663	48H X 37W X 10D
4	3	600	600	AMRM-664	48H X 37W X 10D
3	3	600	800	AMRM-863	48H X 37W X 10D
4	3	600	800	AMRM-864	48H X 37W X 10D
3	3	600	1200	AMRM-1263	54H X 48W X 14D
4	3	600	1200	AMRM-1264	54H X 48W X 14D
3	3	600	1600	AMRM-1663	60H X 50W X 16D
4	3	600	1600	AMRM-1664	60H X 50W X 16D
3	3	600	2000	AMRM-2063	66H X 54W X 14D
4	3	600	2000	AMRM-2064	66H X 54W X 14D
3	3	600	2500	AMRM-2563	72H X 54W X 20D
4	3	600	2500	AMRM-2564	72H X 54W X 20D
3	3	600	3000	AMRM-3063	72H X 54W X 20D
4	3	600	3000	AMRM-3064	72H X 54W X 20D



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT CABINETS - UG ENTRANCE AND BUTTOM EXIT OR TOP ENTRANCE AND TOP EXIT WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	250	800	AMRM-813UGBX	48H X 36W X 14D
3	3	250	800	AMRM-833UGBX	48H X 36W X 14D
4	3	250	800	AMRM-834UGBX	48H X 36W X 14D
3	3	250	1200	AMRM-1233UGBX	54H X 46W X14D
4	3	250	1200	AMRM-1234UGBX	54H X 46W X14D
3	3	250	1600	AMRM-1633UGBX	66H X 54W X 14D
4	3	250	1600	AMRM-1634UGBX	66H X 54W X 14D
3	3	250	2000	AMRM-2033UGBX	66H X 54W X 14D
4	3	250	2000	AMRM-2034UGBX	66H X 54W X 14D
3	3	250	2500	AMRM-2533UGBX	72H X 50W X 20D
4	3	250	2500	AMRM-2534UGBX	72H X 50W X 20D
3	3	250	3000	AMRM-3033UGBX	72H X 50W X 20D
4	3	250	3000	AMRM-3034UGBX	72H X 50W X 20D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT-PT CABINETS - UG ENTRANCE AND BUTTOM EXIT OR TOP ENTRANCE AND TOP EXIT WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
4	3	600	800	AMRM-864UBGX	48H X 47W X 14D
4	3	600	1200	AMRM-1264UBGX	54H X 57W X 14D
4	3	600	1600	AMRM-1664UBGX	66H X 66W X 14D
4	3	600	2000	AMRM-2064UBGX	66H X 66W X 14D
4	3	600	2500	AMRM-2564UBGX	72H X 62W X 20D
4	3	600	3000	AMRM-3064UBGX	72H X 62W X 20D
3	3	600	800	AMRM-863UBGX	48H X 47W X 14D
3	3	600	1200	AMRM-1263UBGX	54H X 57W X 14D
3	3	600	1600	AMRM-1663UBGX	66H X 66W X 14D
3	3	600	2000	AMRM-2063UBGX	66H X 66W X 14D
3	3	600	2500	AMRM-2563UBGX	72H X 62W X 20D
3	3	600	3000	AMRM-3063UBGX	72H X 62W X 20D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT CABINETS - UG ENTRANCE AND BOTTOM EXIT PAD MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	250	400	AMRM-413PM	58H X 25W X 14D
3	3	250	400	AMRM-433PM	58H X 25W X 14D
4	3	250	400	AMRM-434PM	58H X 25W X 14D
3	1	250	600	AMRM-613PM	58H X 36W X 14D
3	3	250	600	AMRM-633PM	58H X 36W X 14D
4	3	250	600	AMRM-634PM	58H X 36W X 14D
3	1	250	800	AMRM-813PM	58H X 36W X 14D
3	3	250	800	AMRM-833PM	58H X 36W X 14D
4	3	250	800	AMRM-834PM	58H X 36W X 14D
3	3	250	1200	AMRM-1233PM	64H X 46W X 14D
4	3	250	1200	AMRM-1234PM	64H X 46W X 14D
3	3	250	1600	AMRM-1633PM	66H X 54W X 14D
4	3	250	1600	AMRM-1634PM	66H X 54W X 14D
3	3	250	2000	AMRM-2033PM	66H X 54W X 14D
4	3	250	2000	AMRM-2034PM	66H X 54W X 14D
3	3	250	2500	AMRM-2533PM	72H X 50W X 20D
4	3	250	2500	AMRM-2534PM	72H X 50W X 20D
3	3	250	3000	AMRM-3033PM	72H X 50W X 20D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

480V COLD SEQUENCE SOCKET FOR COLD SEQUENCE					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	480	200	U9551-RXL-QG-AMS	19Hx13Wx4 25/32D
				U9581-RXL-QG-AMS	19Hx13Wx4 25/32D
3	3 DELTA	480	200	U9551-RXL-QG-AMS	19Hx13Wx4 25/32D
				U9581-RXL-QG-AMS	19Hx13Wx4 25/32D
4	3Y	277/480	200	U9701-RXL-QG-AMS	19Hx13Wx4 7/8D
3	3 DELTA	480	320	U5740-X-K3L-K2L-5T6-AMS	31 3/4H X 15W X4 7/8D
4	3Y	277/480	320	U4911-X-QG-BL-AMS	38 3/4H X 17 3/4W X 6 1/2D
3	3	600	800	AMRM-863PM	58H X 47W X 14D
3	3	600	1200	AMRM-1263PM	64H X 57W X14D
3	3	600	1600	AMRM-1663PM	66H X 66W X 14D
3	3	600	2000	AMRM-2063PM	66H X 66W X 14D
3	3	600	2500	AMRM-2563PM	72H X 62W X 20D
3	3	600	3000	AMRM-3063PM	72H X 62W X 20D

NOTES:

UGBX AND PAD MOUNT(PM) HAVE A WIREWAY INSTALLED ON THE LEFT. FOR WIREWAY ON THE RIGHT ADD "REV WW" TO THE PART NUMBER.

WIRE BENDING SPACE MEETS NEC REQUIREMENTS PER TABLES 373-6(A) AND 373-6(B).

ALL CABINETS ARE CONSTRUCTED OF ALUMINUM AND RATED 3R FOR INDOOR OR OUTDOOR USE.

THE HINGED DOOR EMPLOYS A 3 POINT LATCH AND HAS PROVISIONS FOR PADLOCKING

PT CABINETS WILL BE INSTALLED ON THE LEFT SIDE FROM THE FACTORY. FOR RIGHT SIDE MOUNTING ADD "REV PT" TO THE PART NUMBER

TO CHANGE THE WIREWAY AND THE PT CABINET TO THE RIGHT SIDE ADD "REV PT WW" TO THE PART NUMBER.

TERMINATION BOXES OH OR UG ENTRANCE WALL MOUNTING

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT OR CT/PT CABINETS WITH MAIN DISCONNECTS - WALL MOUNTED*					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
4	3	600	400	AMRM-CTPT14L-464UGBX	48H X 46W X 15D
4	3	600	400	AMRM-CTPT14L-464PM	58H X 48W X 15D
4	3	600	400	AMRM-CTPTJGL24L-464UGBX	48H X 46W X 15D
4	3	600	400	AMRM-CTPTJL24L-464UGBX	48H X 46W X 15D
4	3	600	400	AMRM-CTPTLGL14L-464UGBX	48H X 46W X 15D
4	3	600	400	AMRM-CTPTLJL14L-464UGBX	48H X 46W X 15D
3	1	240	600	AMRM-CTMGL12L-613UGBX	54H X 46W X 15D
4	3	240	600	AMRM-CTMGL12L-634UGBX	54H X 46W X 15D
4	3	600	600	AMRM-CTPTMGL14L-664UGBX	54H X 46W X 15D
4	3	600	600	AMRM-CTPTMJL14L-664UGBX	54H X 46W X 15D
3	1	240	800	AMRM-CTMGL12L-813UGBX	54H X 46W X 15D
4	3	240	800	AMRM-CTMGL12L-834UGBX	54H X 46W X 15D
4	3	600	800	AMRM-CTPTMGL14L-864UGBX	54H X 46W X 15D
4	3	600	800	AMRM-CTPTMJL14L-864UGBX	54H X 46W X 15D
4	3	240	1200	AMRM-CTPGL12L-1234UGBX	54H X 46W X 15D
4	3	600	1200	AMRM-CTPTPGL14L-1264UGBX	60H X 54W X 15D
4	3	600	1200	AMRM-CTPTPJL14L-1264UGBX	60H X 54W X 15D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

CT OR CT/PT CABINETS WITH MAIN DISCONNECTS - PAD MOUNTED*					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
4	3	600	400	AMRM-CTPTJGL24L-464PM	58H X 46W X 15D
4	3	600	400	AMRM-CTPTJL24L-464PM	58H X 46W X 15D
4	3	600	400	AMRM-CTPTLGL14L-464PM	58H X 46W X 15D
4	3	600	400	AMRM-CTPTLJL14L-464PM	58H X 46W X 15D
3	1	240	600	AMRM-CTMGL12L-613PM	64H X 46W X 15D
4	3	240	600	AMRM-CTMGL12L-634PM	64H X 46W X 15D
4	3	600	600	AMRM-CTPTMGL14L-664PM	64H X 46W X 15D
4	3	600	600	AMRM-CTPTMJL14L-664PM	64H X 46W X 15D
3	1	240	800	AMRM-CTMGL12L-813PM	64H X 46W X 15D
4	3	240	800	AMRM-CTMGL12L-834PM	64H X 46W X 15D
4	3	600	800	AMRM-CTPTMGL14L-864PM	64H X 46W X 15D
4	3	600	800	AMRM-CTPTMJL14L-864PM	64H X 46W X 15D
4	3	240	1200	AMRM-CTPGL12L-1234PM	64H X 46W X 15D
4	3	600	1200	AMRM-CTPTPGL14L-1264PM	70H X 54W X 15D
4	3	600	1200	AMRM-CTPTPJL14L-1264PM	70H X 54W X 15D

* REVERSING THE UTILITY ENTRANCE, MOVES THE BREAKER TO THE RIGHT SIDE OF THE CABINET TO ALLOW FOR LEFT SIDE INCOMING LINE CONDUCTORS AND RIGHT SIDE EXITING LOAD CONDUCTORS

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

TERMINATION CABINETS- UG ENTRANCE AND BOTTOM EXIT OR TOP ENTRANCE AND TOP EXIT PAD MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	600	400	TBPMAMRM-413-1	48H X 25W X 14D
3	3	600	400	TBPMAMRM-433-1	48H X 25W X 14D
4	3	600	400	TBPMAMRM-434-1	48H X 25W X 14D
3	1	600	600	TBPMAMRM-613-2	48H X 25W X 14D
3	3	600	600	TBPMAMRM-633-2	48H X 25W X 14D
4	3	600	600	TBPMAMRM-634-2	48H X 25W X 14D
3	1	600	800	TBPMAMRM-813-2	48H X 25W X 14D
3	3	600	800	TBPMAMRM-833-2	48H X 25W X 14D
4	3	600	800	TBPMAMRM-834-2	48H X 25W X 14D
3	3	600	1200	TBPMAMRM-1233-3	48H X 36W X 14D
4	3	600	1200	TBPMAMRM-1234-3	48H X 36W X 14D
3	3	600	1600	TBPMAMRM-1633-4	54H X 36W X 14D
4	3	600	1600	TBPMAMRM-1634-4	54H X 36W X 14D
3	3	600	2000	TBPMAMRM-2033-5	60H X 34W X 16D
4	3	600	2000	TBPMAMRM-2034-5	60H X 34W X 16D
3	3	600	2500	TBPMAMRM-2533-7	72H X 42W X 20D
4	3	600	2500	TBPMAMRM-2034-7	72H X 42W X 20D
3	3	600	3000	TBPMAMRM-3033-8	72H X 42W X 20D
4	3	600	3000	TBPMAMRM-3034-8	72H X 42W X 20D

TBBX AND PAD MTD (PM) CABINETS HAVE A INTERNAL WIREWAY INSTALLED ON THE LEFT. FOR A WIREWAY ON THE RIGHT SIDE ADD "REV WW" TO THE PART NUMBER.

WIRE BENDING SPACE MEETS NEC REQUIREMENTS PER TABLES 373-6(A) AND 373-6(B).

ALL CABINETS ARE CONSTRUCTED OF ALUMINUM AND RATED 3R FOR INDOOR OR OUTDOOR USE.

THE HINGED DOOR EMPLOYS A 3 POINT LATCH AND HAS PROVISIONS FOR PADLOCKING

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

TERMINATION CABINETS - OH OR UG ENTRANCE WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	600	400	TBAMRM-413-1	48H X 25W X 14D
3	3	600	400	TBAMRM-433-1	48H X 25W X 14D
4	3	600	400	TBAMRM-434-1	48H X 25W X 14D
3	1	600	600	TBAMRM-613-2	48H X 25W X 14D
3	3	600	600	TBAMRM-633-2	48H X 25W X 14D
4	3	600	600	TBAMRM-634-2	48H X 25W X 14D
3	1	600	800	TBAMRM-813-2	48H X 25W X 14D
3	3	600	800	TBAMRM-833-2	48H X 25W X 14D
4	3	600	800	TBAMRM-834-2	48H X 25W X 14D
3	3	600	1200	TBAMRM-1233-3	48H X 36W X 14D
4	3	600	1200	TBAMRM-1234-3	48H X 36W X 14D
3	3	600	1600	TBAMRM-1633-4	54H X 36W X 14D
4	3	600	1600	TBAMRM-1634-4	54H X 36W X 14D
3	3	600	2000	TBAMRM-2033-5	60H X 34W X 16D
4	3	600	2000	TBAMRM-2034-5	60H X 34W X 16D
3	3	600	2500	TBAMRM-2533-7	72H X 42W X 20D
4	3	600	2500	TBAMRM-2034-7	72H X 42W X 20D
3	3	600	3000	TBAMRM-3033-8	72H X 42W X 20D
4	3	600	3000	TBAMRM-3034-8	72H X 42W X 20D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

TERMINATION CABINETS - UG ENTRANCE AND EXIT - WALL MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	600	400	TBBXAMRM-413-1	48H X 25W X 14D
3	3	600	400	TBBXAMRM-433-1	48H X 25W X 14D
4	3	600	400	TBBXAMRM-434-1	48H X 25W X 14D
3	1	600	600	TBBXAMRM-613-2	48H X 25W X 14D
3	3	600	600	TBBXAMRM-633-2	48H X 25W X 14D
4	3	600	600	TBBXAMRM-634-2	48H X 25W X 14D
3	1	600	800	TBBXAMRM-813-2	48H X 25W X 14D
3	3	600	800	TBBXAMRM-833-2	48H X 25W X 14D
4	3	600	800	TBBXAMRM-834-2	48H X 25W X 14D
3	3	600	1200	TBBXAMRM-1233-3	48H X 36W X 14D
4	3	600	1200	TBBXAMRM-1234-3	48H X 36W X 14D
3	3	600	1600	TBBXAMRM-1633-4	54H X 36W X 14D
4	3	600	1600	TBBXAMRM-1634-4	54H X 36W X 14D
3	3	600	2000	TBBXAMRM-2033-5	60H X 34W X 16D
4	3	600	2000	TBBXAMRM-2034-5	60H X 34W X 16D
3	3	600	2500	TBBXAMRM-2533-7	72H X 42W X 20D
4	3	600	2500	TBBXAMRM-2034-7	72H X 42W X 20D
3	3	600	3000	TBBXAMRM-3033-8	72H X 42W X 20D
4	3	600	3000	TBBXAMRM-3034-8	72H X 42W X 20D

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK

TERMINATION CABINETS- UG ENTRANCE AND BOTTOM EXIT OR TOP ENTRANCE AND TOP EXIT PAD MOUNT					
WIRES	PHASE	VOLTS	MAX AMPS	CATALOG NUMBER	DIMENSIONS-HxWxD(in)
3	1	600	400	TBPMAMRM-413-1	48H X 25W X 14D
3	3	600	400	TBPMAMRM-433-1	48H X 25W X 14D
4	3	600	400	TBPMAMRM-434-1	48H X 25W X 14D
3	1	600	600	TBPMAMRM-613-2	48H X 25W X 14D
3	3	600	600	TBPMAMRM-633-2	48H X 25W X 14D
4	3	600	600	TBPMAMRM-634-2	48H X 25W X 14D
3	1	600	800	TBPMAMRM-813-2	48H X 25W X 14D
3	3	600	800	TBPMAMRM-833-2	48H X 25W X 14D
4	3	600	800	TBPMAMRM-834-2	48H X 25W X 14D
3	3	600	1200	TBPMAMRM-1233-3	48H X 36W X 14D
4	3	600	1200	TBPMAMRM-1234-3	48H X 36W X 14D
3	3	600	1600	TBPMAMRM-1633-4	54H X 36W X 14D
4	3	600	1600	TBPMAMRM-1634-4	54H X 36W X 14D
3	3	600	2000	TBPMAMRM-2033-5	60H X 34W X 16D
4	3	600	2000	TBPMAMRM-2034-5	60H X 34W X 16D
3	3	600	2500	TBPMAMRM-2533-7	72H X 42W X 20D
4	3	600	2500	TBPMAMRM-2034-7	72H X 42W X 20D
3	3	600	3000	TBPMAMRM-3033-8	72H X 42W X 20D
4	3	600	3000	TBPMAMRM-3034-8	72H X 42W X 20D
<p>TBBX AND PAD MTD (PM) CABINETS HAVE A INTERNAL WIREWAY INSTALLED ON THE LEFT. FOR A WIREWAY ON THE RIGHT SIDE ADD "REV WW" TO THE PART NUMBER.</p> <p>WIRE BENDING SPACE MEETS NEC REQUIREMENTS PER TABLES 373-6(A) AND 373-6(B).</p> <p>ALL CABINETS ARE CONSTRUCTED OF ALUMINUM AND RATED 3R FOR INDOOR OR OUTDOOR USE.</p> <p>THE HINGED DOOR EMPLOYS A 3 POINT LATCH AND HAS PROVISIONS FOR PADLOCKING</p>					

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MILBANK						
WIRES	PHASE	MAX AMPS	VOLTS	CATALOG NUMBER	PT#	DIMENSIONS-WxHxD(in)
3	1	800A MAXIMUM	120/240	CT244811HC & K4797 INSERT	NOT REQUIRED	24 X 48 X 11
				CT304811HCAMS W/ K5931 OR K4797		30 X 48 X 11
				CT364811HCAMS W/ K5931 OR K4797		36 X 48 X 11
3	3 DELTA	800A MAXIMUM	240	CT244811HC W/ K4797 INSERT	NOT REQUIRED	24 X 48 X 11
				CT304811HCAMS W/ K5931 OR K4797		30 X 48 X 11
				CT364811HCAMS W/ K5931 OR K4797		36 X 48 X 11
3	3 DELTA	800A MAXIMUM	480	CT244811HC W/ K4797 INSERT	PT48 (AL or AR)	24 X 48 X 11
				CT304811HCAMS W/ K5931 OR K4797		30 X 48 X 11
				CT364811HCAMS W/ K5931 OR K4797		36 X 48 X 11
4	3	800A MAXIMUM	120/240	CT304811HCAMS W/ K5930 OR K4798	NOT REQUIRED	30 X 48 X 11
				CT364811HCAS W/ K5930 OR K4798		36 X 48 X 11
4	3Y	800A MAXIMUM	120/208	CT304811HCAMS W/ K5930 OR K4798	NOT REQUIRED	30 X 48 X 11
				CT364811HCAMS W/ K5930 OR K4798		36 X 48 X 11
4	3Y	800A MAXIMUM	277/480	CT304811HCAMS W/ K5930 OR K4798	PT48 (AL or AR)	30 X 48 X 11
				CT364811HCAMS W/ K5930 OR K4798		36 X 48 X 11

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

MURRY

Meter Mains - Residential												
Wire	Phase	Terminal	Volt	Amps	Type	Type	Catalog #	Max Hub	Min/Max Cdr. Size	Height(in)	Width(in)	Depth(in)
3	1	5	120/240	320	OH	Lever	JC0404L1400RLM	3.0"	Line: One #6 - 350kcmil	19.70	17.10	5.00
3	3	5	120/240	320	OH/UG	Lever	JA0816B1400RLTM	4.0"	Line: One #4-600kCMIL	29	27	6
ILLINOIS CT RATED PRE-WIRED SOCKET (CUSTOMER SUPPLIED)												
3	1	8	600	20			9837-0914AC			24.00	12.00	4 15/16
4	3	13	600	20			9837-0915ac			24.00	12.00	4 15/16



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SIEMENS

Wires	Phase	Terminals	Volts	Service Type	Service Amp	Installation	Catalog #	MAX HUB	Max. # Cdr's	LENGTH (in)	WIDTH (in)	DEPTH (in)
Meter Mains												
3	1	5	120/240	Residential	320	OH/UG	MM0404L1400RLM	4.0"	One: One #4 - 600kcr	29.00	27.00	6.00
3	1	5	120/240	Main Brkr. Disconnect (Side by Side)	320	OH/UG	MC0816B1400RLTM	L.C.P. / 4"	One: One #4 - 600kcr	29.00	27.00	6.00
Modular Meter Stacks												
3	1	5	120/240	1 Gang	225	OH/UG	WML11225RJ	Bussed	Line: Bussed	27.75	19.50	9.00
3	1	5	120/240	2 Gang	225	OH/UG	WML21225RJ	Bussed	Line: Bussed	40.75	19.50	9.00
3	1	5	120/240	3 Gang	225	OH/UG	WML31225RJ	Bussed	Line: Bussed	49.75	19.50	9.00
3	1	5	120/240	4 Gang	225	OH/UG	WML41225RJ	Bussed	Line: Bussed	62.75	19.50	9.00
3	1	5	120/240	1 Gang	320	OH/UG	WML11400RJ	Bussed	Line: Bussed	44.00	16.31	9.69
3	1	5	120/240	2 Gang	320	OH/UG	WML21400RJ	Bussed	Line: Bussed	70.38	23.00	9.69
3	1	5	120/240	1 Gang	225	OH/UG	WML12225RJ	Bussed	Line: Bussed	27.75	19.50	9.00
3	1	5	120/240	2 Gang	225	OH/UG	WML22AB225RJ	Bussed	Line: Bussed	40.75	19.50	9.00
3	1	5	120/240	2 Gang	225	OH/UG	WML22BC225RJ	Bussed	Line: Bussed	40.75	19.50	9.00
3	1	5	120/240	2 Gang	225	OH/UG	WML22CA225RJ	Bussed	Line: Bussed	40.75	19.50	9.00
3	1	5	120/240	3 Gang	225	OH/UG	WML32225RJ	Bussed	Line: Bussed	49.75	19.50	9.00
3	1	5	120/240	4 Gang	225	OH/UG	WML42AB225RJ	Bussed	Line: Bussed	62.75	19.50	9.00
3	1	5	120/240	4 Gang	225	OH/UG	WML42BC225RJ	Bussed	Line: Bussed	62.75	19.50	9.00
3	1	5	120/240	4 Gang	225	OH/UG	WML42CA225RJ	Bussed	Line: Bussed	62.75	19.50	9.00
3	1	5	120/240	1 Gang	320	OH/UG	WML12400RJ	Bussed	Line: Bussed	44.00	16.31	9.69
3	1	5	120/240	2 Gang	320	OH/UG	WML22400RJ	Bussed	Line: Bussed	70.38	23.00	9.69



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SIEMENS

Wires	Phase	Terminals	Volts	Service Type	Service Amp	Installation	Catalog #	MAX HUB	Max. # Cdr's	LENGTH (in)	WIDTH (in)	DEPTH (in)
4	3	7	208Y/120V	1 Gang	100	OH/UG	WML13100RJ	Bussed	Line: Bussed	27.75	23.50	9.00
4	3	7	208Y/120V	2 Gang	100	OH/UG	WML23100RJ	Bussed	Line: Bussed	40.75	23.50	9.00
4	3	7	208Y/120V	3 Gang	100	OH/UG	WML33100RJ	Bussed	Line: Bussed	49.75	23.50	9.00
4	3	7	208Y/120V	4 Gang	100	OH/UG	WML43100RJ	Bussed	Line: Bussed	62.75	23.50	9.00
4	3	7	240V	1 Gang	225	OH/UG	WML13225RJ	Bussed	Line: Bussed	27.75	23.50	9.00
4	3	7	240V	2 Gang	225	OH/UG	WML23225RJ	Bussed	Line: Bussed	40.75	23.50	9.00
4	3	7	240V	3 Gang	225	OH/UG	WML33225RJ	Bussed	Line: Bussed	49.75	23.50	9.00
4	3	7	240V	4 Gang	225	OH/UG	WML43225RJ	Bussed	Line: Bussed	62.75	23.50	9.00
4	3	7	240V	1 Gang	320	OH/UG	WML13400RJ	Bussed	Line: Bussed	44.00	16.31	9.69
4	3	7	240V	2 Gang	320	OH/UG	WML23400RJ	Bussed	Line: Bussed	70.38	23.00	9.69
3	1	5	208Y/120	2 Gang	125	OH/UG	ML22125RJ	Bussed	Line: Bussed	36.00	14.50	11.50
3	1	5	208Y/120	3 Gang	125	OH/UG	ML32125RJ	Bussed	Line: Bussed	46.00	14.50	11.50
3	1	5	208Y/120	4 Gang	125	OH/UG	ML42125RJ	Bussed	Line: Bussed	56.00	14.50	11.50
3	1	5	208Y/120	5 Gang	125	OH/UG	ML52125RJ	Bussed	Line: Bussed	66.00	14.50	11.50
3	1	5	208Y/120	6 Gang	125	OH/UG	ML62125RJ	Bussed	Line: Bussed	76.00	14.50	11.50
3	1	5	208Y/120	2 Gang	125	OH/UG	WML22125RJ	Bussed	Line: Bussed	36.00	14.50	11.50
3	1	5	208Y/120	3 Gang	125	OH/UG	WML32125RJ	Bussed	Line: Bussed	46.00	14.50	11.50
3	1	5	208Y/120	4 Gang	125	OH/UG	WML42125RJ	Bussed	Line: Bussed	56.00	14.50	11.50
3	1	5	208Y/120	5 Gang	125	OH/UG	WML52125RJ	Bussed	Line: Bussed	66.00	14.50	11.50
3	1	5	208Y/120	6 Gang	125	OH/UG	WML62125RJ	Bussed	Line: Bussed	76.00	14.50	11.50



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SIEMENS

Wires	Phase	Terminals	Volts	Service Type	Service Amp	Installation	Catalog #	MAX HUB	Max. # Cdr's	LENGTH (in)	WIDTH (in)	DEPTH (in)
3	1	5	120/240	2 Gang	125	OH/UG	ML21125RJ	Bussed	Line: Bussed	36.00	14.50	11.50
3	1	5	120/240	3 Gang	125	OH/UG	ML31125RJ	Bussed	Line: Bussed	46.00	14.50	11.50
3	1	5	120/240	4 Gang	125	OH/UG	ML41125RJ	Bussed	Line: Bussed	56.00	14.50	11.50
3	1	5	120/240	5 Gang	125	OH/UG	ML51125RJ	Bussed	Line: Bussed	66.00	14.50	11.50
3	1	5	120/240	6 Gang	125	OH/UG	ML61125RJ	Bussed	Line: Bussed	76.00	14.50	11.50
3	1	5	120/240	2 Gang	125	OH/UG	WML12125RJ	Bussed	Line: Bussed	36.00	14.50	11.50
3	1	5	120/240	3 Gang	125	OH/UG	WML31125RJ	Bussed	Line: Bussed	46.00	14.50	11.50
3	1	5	120/240	4 Gang	125	OH/UG	WML41125RJ	Bussed	Line: Bussed	56.00	14.50	11.50
3	1	5	120/240	5 Gang	125	OH/UG	WML51125RJ	Bussed	Line: Bussed	66.00	14.50	11.50
3	1	5	120/240	6 Gang	125	OH/UG	WML61125RJ	Bussed	Line: Bussed	76.00	14.50	11.50
PAK Metering												
3	1	5	120/240	Residential	200	OH/UG	WPL4212RJ	(2) - 4.0"	3/8" studs	36.75	33.50	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL4312RJ	(2) - 4.0"	3/8" studs	49.75	33.50	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL4412RJ	(2) - 4.0"	3/8" studs	62.75	33.50	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL6412RJ	(2) - 4.0"	3/8" studs	62.75	33.50	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL6512RJ	(2) - 4.0"	3/8" studs	49.75	53.38	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL6612RJ	(2) - 4.0"	3/8" studs	49.75	53.38	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL8612RJ	(2) - 4.0"	3/8" studs	49.75	57.63	9.00
3	1	5	120/240	Residential	200	OH/UG	WPL10612RJ	(2) - 4.0"	3/8" studs	49.75	57.63	9.00



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
Individual Meter Sockets							
3	1	120/240	200A	OH	UTH4203T	Series A-L	L(1)6-350 G14-2
3	1	120/240	200A	OH/UG	UTH4213T	Series A-L	L(1)6-350 G14-2
3	1	120/240	200A	OH	UTH5203T	Series A-L	L(1)6-350 G14-2
3	1	120/240	200A	OH/UG	UTH5213T	Series A-L	L(1)6-350 G14-2
4	3	120/240	200A	OH/UG	UTH7213T	Series A-L	L(1)6-350 G14-2
3	1	120/240	320A	OH/UG	1009722-SQD		
4	3	120/240	320A	OH	UTH7300T	Series A-L	Studs Only
Meter/Main Combination							
3	1	120/240	200A	OH/UG	RCM200SL	Series A	(1) 6 - 350
3	1	120/240	200A	OH/UG	RC2M200SL	Series A	(1) 6 - 350
3	1	120/240	400A	UG	QU12L400SL	Series A-L	(2) Stubs G(1)4-250
3	1	120/240	150A	OH/UG	QC816F150SL	Series A	(1) 6- 350
3	1	120/240	200A	OH/UG	QC816F200SL	Series A	(1) 6-350
3	1	120/240	400A	OH/UG	QUM400CL	Series A	Lugs ordered separately
3	1	120/240	400A	UG	QU816D400FL	Series A	Lugs ordered separately
3	1	120/240	400A	UG	QU816D400SL	Series A-L	(2) Stubs G(1)4-250
3	1	120/240	400A	UG	QU816D400CL	Series A-L	(2) Stubs G(1)4-250
3	1	120/240	400A	UG	QU12L400CL	Series A	Lugs ordered separately
3	1	120/240	400A	UG	QU12L400FL	Series A	Lugs ordered separately
3	1	120/240	150A	OH/UG	RC3040M150SL	Series A or B300	Lugs ordered separately
3	1	120/240	200A	OH/UG	RC3040M200SL	Series A or B300	Lugs ordered separately
3	1	120/240	400A	UG	RU3040D400FL	Series A	Lugs ordered separately
3	1	120/240	400A	UG	RU3040D400CL	Series A-L	(2) Stubs G(1)4-250

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
Meter-Pak Meter Centers						Amps Per Pos.	
3	1	120/240	350	OH/UG	MPL32225	225A	(1)1/0-600 or (2)1/0-250
3	1	120/240	500	OH/UG	MPL53225	225A	(1)1/0-600 or (2)1/0-250
3	1	120/240	600	OH/UG	MPL64225	225A	(1)1/0-600 or (2)1/0-250
EZ Meter-Pak Meter Centers - Single Phase (Note: order single phase meter sockets in addition to the meter center)						Main Device	
3	1	120/240	400A	OH/UG	EZM1400CB	Circuit Breaker	L(1)600 or (2)1-250
3	1	120/240	600A	OH/UG	EZM1600CB	Circuit Breaker	L(3)3/0-500
3	1	120/240	800A	OH/UG	EZM1800CB	Circuit Breaker	L(3)3/0-500
3	1	120/240	1000A	OH/UG	EZM11000CB	Circuit Breaker	L(3)3/0-500
3	1	120/240	1200A	OH/UG	EZM11200CB	Circuit Breaker	L(4)1/0-750
3	1	120/240	1600A	OH/UG	EZM11600CB	Circuit Breaker	L(6)1/0-750
3	1	120/240	2000A	OH/UG	EZM12000CB	Circuit Breaker	L(6)1/0-750 or (12)1/0-250
3	1	120/240	400A	OH/UG	EZM1400FS	Fusible	L(1)1-600 or (2)1-250
3	1	120/240	600A	OH/UG	EZM1600FS	Fusible	L(3)3/0-500
3	1	120/240	800A	OH/UG	EZM1800FS	Fusible	L(3)3/0-500
3	1	120/240	1200A	OH/UG	EZM11200FS	Fusible	L(4)1/0-750
3	1	120/240	225A	OH/UG	EZM1225TB	Main Lugs	L(1)4-300
3	1	120/240	400A	OH/UG	EZM1400TB	Main Lugs	L(2)3/0-500
3	1	120/240	600A	OH/UG	EZM1600TB	Main Lugs	L(2)1/0-750 or (4)1/0-300
3	1	120/240	800A	OH/UG	EZM1800TB	Main Lugs	L(4)3/0-500
3	1	120/240	800A	OH/UG	EZM1800TBCU	Main Lugs	L(4)3/0-500
3	1	120/240	1600A	OH/UG	EZM11600TB	Main Lugs	L(6)3/0-600
3	1	120/241	2000A	OH/UG	EZM12000TB	Main Lugs	Lugs Ordered Separately
3	1	120/240	400A	UG	EZM1400CBU	Circuit Breaker	Factory Installed Lug Landings

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
3	1	120/240	600A	UG	EZM1600CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	800A	UG	EZM1800CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	1000A	UG	EZM11000CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	1200A	UG	EZM11200CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	1600A	UG	EZM11600CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	2000A	UG	EZM12000CBU	Circuit Breaker	Factory Installed Lug Landings
3	1	120/240	400A	UG	EZM1400FSU	Fusible	Factory Installed Lug Landings
3	1	120/240	600A	UG	EZM1600FSU	Fusible	Factory Installed Lug Landings
3	1	120/240	800A	UG	EZM1800FSU	Fusible	Factory Installed Lug Landings
3	1	120/240	1200A	UG	EZM11200FSU	Fusible	Factory Installed Lug Landings
3	1	120/240	400A	UG	EZM1400TBU	Main Lugs	Factory Installed Lug Landings
3	1	120/240	800A	UG	EZM1800TBU	Main Lugs	Factory Installed Lug Landings
3	1	120/240	1200A	UG	EZM11200TBU	Main Lugs	Factory Installed Lug Landings
EZ Meter-Pak Meter - Single Phase Sockets						Branch Device	Maximum Circuit Breaker
3	1	120/240	1200A	Branch Units	EZML111225	1 Socket	225A
3	1	120/240	1200A	Branch Units	EZML111225CU	1 Socket	225A
3	1	120/240	1200A	Branch Units	EZML111225D	1 Socket	225A
3	1	120/240	1200A	Branch Units	EZML112225	2 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML112225CU	2 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML112225D	2 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML113225	3 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML113225CU	3 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML113225D	3 Sockets	225A
3	1	120/240	1200A	Branch Units	EZML111400	1 Socket	400A
3	1	120/240	1200A	Branch Units	EZML112400	2 Sockets	400A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
EZ Meter-Pak Meter Centers - Three Phase (Note:order three-phase meter sockets in addition to the meter center)						Main Device	
4	3	208Y/120 or 240/120	400A	OH/UG	EZM3400CB	Circuit Breaker	L(1)1-600 or (2)1-250
4	3	208Y/120 or 240/120	600A	OH/UG	EZM3600CB	Circuit Breaker	L(3)3/0-500
4	3	208Y/120 or 240/120	800A	OH/UG	EZM3800CB	Circuit Breaker	L(3)3/0-500
4	3	208Y/120 or 240/120	1000A	OH/UG	EZM31000CB	Circuit Breaker	L(3)3/0-500
4	3	208Y/120 or 240/120	1200A	OH/UG	EZM31200CB	Circuit Breaker	L(4)1/0-750
4	3	208Y/120 or 240/120	1600A	OH/UG	EZM31600CB	Circuit Breaker	L(6)1/0-750
4	3	208Y/120 or 240/120	2000A	OH/UG	EZM32000CB	Circuit Breaker	L(6)1/0-750 or (12)1/0-250
4	3	208Y/120 or 240/120	400A	OH/UG	EZM3400FS	Fusible	L(1)1-600 or (2)1-250
4	3	208Y/120 or 240/120	600A	OH/UG	EZM3600FS	Fusible	L(3)3/0-500
4	3	208Y/120 or 240/120	800A	OH/UG	EZM3800FS	Fusible	L(3)3/0-500
4	3	208Y/120 or 240/120	225A	OH/UG	EZM3225TB	Main Lugs	L(1)4-300
4	3	208Y/120 or 240/120	400A	OH/UG	EZM3400TB	Main Lugs	L(2)3/0-500
4	3	208Y/120 or 240/120	600A	OH/UG	EZM3600TB	Main Lugs	L(2)1/0-750 or (4)1/0-300
4	3	208Y/120 or 240/120	800A	OH/UG	EZM3800TB	Main Lugs	L(4)3/0-500
4	3	208Y/120 or 240/120	800A	OH/UG	EZM3800TBCU	Main Lugs	L(4)3/0-500
4	3	208Y/120 or 240/120	1600A	OH/UG	EZM31600TB	Main Lugs	L(6)3/0-600
4	3	208Y/120 or 240/120	2000A	OH/UG	EZM32000TB	Main Lugs	Lugs Ordered Separately

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
EZ Meter-Pak Meter Sockets - Three Phase						Branch Device	Maximum Circuit Breaker
4	3	208Y/120	1200A	Branch Units	EZML311225	1 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML311225CU	1 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML311225D	1 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML312225	2 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML312225CU	2 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML312225D	2 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML313225	3 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML313225CU	3 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML313225D	3 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML314225	4 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML314225CU	4 Sockets	225A
4	3	208Y/120	1200A	Branch Units	EZML314225D	4 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML331225	1 Socket	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML331225CU	1 Socket	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZM331225D	1 Socket	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML332225	2 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML332225CU	2 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML332225D	2 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML333225	3 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML333225CU	3 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML333225D	3 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML334225	4 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML334225CU	4 Sockets	225A



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

SQUARE D

Wires	Phase	Volts	Max Amps	Installation Type	Catalog #	Hub (separate)	Lug Wire Range
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML334225D	4 Sockets	225A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML311400	1 Socket	400A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML312400	2 Sockets	400A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML331400	1 Socket	400A
4	3	208Y/120 or 240/120	1200A	Branch Units	EZML332400	2 Sockets	400A

SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

TALON/LANDIS&GYR

Wires	Phase	Volts	Service Amp	Installation	Catalog #	Closure Plate	DIMENSIONS - HxWxD(in)		
Individual Meter Sockets - Temporary Power									
3	1	120/240	100	OH	LGP77RTS	C.P. / 2.5"			
3	1	120/240	100	UG	LGP77RBS	N/A			
Meter Pedestal									
3	1	120/240	200	UG	MP0606L1200RJL	N/A	96	12	9
3	1	120/240	200	UG	MP0406B1200JL2	N/A	96	12	20
3	1	120/240	200	UG	MPS0406B1200JL	N/A	96	13.38	9
3	1	120/240	125	UG	MPS0406B1125JL	N/A	96	13.38	9
3	1	120/240	150	UG	MPS0406B1150JL	N/A	96	13.38	9
3	1	120/240	100	UG	MPS0406B1100JL	N/A	96	13.38	9
3	1	120/240	200	UG	MPS0406B1200L2	N/A	96	13.38	20
Individual Meter Sockets									
3	1	120/240	320	OH/UG	49905-026	Up to 4" KO	36	20.25	6 1/5
3	1	120/240	320	OH/UG	48104-82WI	L.C.P. / 4"	31	16	5
3	1	120/240	125	OH	42305-02MR	C.P. / 2.5"	18.5	10	4.8
3	1	120/240	125	OH	42395-02MR	C.P. / 2.5"	18.5	10	4.8
3	1	120/240	200	OH	40804-01QG	H.O. / 2.5"	17.5	10	5.2
3	1	120/240	200	OH/UG	40404-02QG	C.P. / 2.5"	19	13	5.2
3	1	120/240	200	OH	41005-01F	H.O. / 2.5"	17.5	10	5.2
3	1	120/240	200	OH	40005-01QG	H.O. / 2.5"	17.5	10	5.2
3	1	120/240	200	OH/UG	40405-02QG	C.P. / 2.5"	19	13	5.2
3	1	120/240	200	OH/UG	9804-8592	C.P. / 2.5"	19	13	5.2
3	1	120/240	200	OH/UG	44305-02MR	C.P. / 4"	19	13	4.9



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

TALON/LANDIS&GYR

Individual Meter Sockets									
Wires	Phase	Volts	Service Amp	Installation	Catalog #	Closure Plate	DIMENSIONS - HxWxD(in)		
3	1	120/240	200	OH/UG	42705-02MR	C.P. / 4"	19	13	4.9
3	1	120/240	200	OH/UG	41405-02MR	C.P. / 2.5"	19	13	4.9
3	1	120/240	200	OH/UG	40405-02MR	C.P. / 4"	19	13	4.9
3	1	120/240	200	OH	42405-01MR	C.P. / 4"	18.5	10	4.9
3	1	120/240	200	OH	42425-02MR	C.P. / 4"	18.5	10	4.9
3	1	120/240	320/400	OH/UG	42805-42MR	C.P. / 4"	38.75	17.75	6.5
3	1	120/240	320/400	OH/UG	43005-42MR	C.P. / 4"	38.75	17.75	6.5
3	1	120/240	320/400	OH	47605-82MR	C.P. / 4"	31.7	15	4.9
4	3	120/208	200	OH	42407-01MR	C.P. / 4"	18.5	10	4.9
4	3	120/208	200	OH/UG	44307-02MR	C.P. / 4"	19	13	4.9
4	3	120/208	200	OH	40007-01QG	N.P. / 2.5"	17.5	10	5.2
4	3	120/208	200	OH/UG	40407-02QG	C.P. / 2.5"	19	13	5.2
4	3	120/208	320/400	OH/UG	9804-9109	L.C.P. / 4"	34	20.25	6
4	3	120/208	320/400	OH/UG	49007-02FL	L.C.P. / 4"	34	20.25	6
4	3	120/208	320/400	OH/UG	49807-026	L.C.P. / 4"	34	20.25	6
4	3	120/208	320/400	OH/UG	43005-82MR	L.C.P. / 4"	31.7	15	4.9
4	3	120/208	320/400	OH/UG	42807-02MR	L.C.P. / 4"	38.8	17.8	6.5



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

TALON/LANDIS&GYR

Meter Mains (Side by Side)									
Wires	Phase	Volts	Service Amp	Installation	Catalog #	Closure Plate	DIMENSIONS - HxWxD(in)		
3	1	120/240	320	OH/UG	LG0816B1400RLTM	L.C.P. / 4"	29	27	6
3	1	120/240	320	OH/UG	LG0404L1400RLM	L.C.P. / 4"	29	27	6
3	1	120/240	200	OH/UG	LG0202L1200JL6	L.C.P. / 4"	36.2	16	5
3	1	120/240	200	OH/UG	LG0202B1200JL6	L.C.P. / 4"	36.2	16	5
3	1	120/240	200	OH/UG	LG0202L 1200JLC	L.C.P. / 4"	36.2	16	5
3	1	120/240	200	OH/UG	LG0202B1200JLC	L.C.P. / 4"	36.2	16	5
4	3	120/208	200	OH/UG	LG0303B3200JLC	L.C.P. / 4"	36.2	16	5

Meter Stacks

Wires	Phase	Volts	Service Amp	Installation	Catalog #	Type
3	1	120/240	200	OH/UG	404052-023NU	2 Gang Horizontal
3	1	120/240	200	OH/UG	404053-023NU	3 Gang Horizontal
3	1	120/240	200	OH/UG	404054-223NU	4 Gang Horizontal
3	1	120/240	200	OH/UG	404055-223NU	5 Gang Horizontal
3	1	120/240	200	OH/UG	404056-223NU	6 Gang Horizontal
4	3	120/208	200	OH/UG	404072-023NU	2 Gang Horizontal
4	3	120/208	200	OH/UG	404073-023NU	3 Gang Horizontal
4	3	120/208	200	OH/UG	404074-223NU	4 Gang Horizontal
4	3	120/208	200	OH/UG	404075-223NU	5 Gang Horizontal
4	3	120/208	200	OH/UG	404076-223NU	6 Gang Horizontal
3	1	120/240	200	OH/UG	404052-223MR	2 Gang Horizontal
3	1	120/240	200	OH/UG	404053-223MR	3 Gang Horizontal
3	1	120/240	200	OH/UG	404054-223MR	4 Gang Horizontal
3	1	120/240	200	OH/UG	404055-223MR	5 Gang Horizontal
3	1	120/240	200	OH/UG	404056-223MR	6 Gang Horizontal
4	3	120/208	200	OH/UG	404072-223MR	2 Gang Horizontal
4	3	120/208	200	OH/UG	404073-223MR	3 Gang Horizontal
4	3	120/208	200	OH/UG	404074-223MR	4 Gang Horizontal
4	3	120/208	200	OH/UG	404075-223MR	5 Gang Horizontal
4	3	120/208	200	OH/UG	404076-223MR	6 Gang Horizontal



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

TALON/LANDIS&GYR

PAK Metering

Wires	Phase	Volts	Service Amp	Installation	Catalog #	MAX HUB	Max. # Cdr's	Height (in)	WIDTH (in)	DEPTH (in)
3	1	120/240	200	OH/UG	WTGL4212RJ	(2) - 4.0"	3/8" studs	36.75	33.50	9.00
3	1	120/240	200	OH/UG	WTGL4312RJ	(2) - 4.0"	3/8" studs	49.75	33.50	9.00
3	1	120/240	200	OH/UG	WTGL4412RJ	(2) - 4.0"	3/8" studs	62.75	33.50	9.00
3	1	120/240	200	OH/UG	WTGL6412RJ	(2) - 4.0"	3/8" studs	62.75	33.50	9.00
3	1	120/240	200	OH/UG	WTGL6512RJ	(2) - 4.0"	3/8" studs	49.75	53.38	9.00
3	1	120/240	200	OH/UG	WTGL6612RJ	(2) - 4.0"	3/8" studs	49.75	53.38	9.00
3	1	120/240	200	OH/UG	WTGL8612RJ	(2) - 4.0"	3/8" studs	49.75	57.63	9.00
3	1	120/240	200	OH/UG	WTGL10612RJ	(2) - 4.0"	3/8" studs	49.75	57.63	9.00

BUSSED CT CABINETS-WALL MOUNTED

Wires	Phase	Volts	Service Amp	Catalog #	Service Type
3	1	120/240	201-400A	CT-41-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
3	3	240	201-400A	CT-43-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
3	3	120/240	201-400A	CT-44-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
4	3	120/208	201-400A	CT-44-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
3	3 DELTA	480	201-400A	CT-43-PTL-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
4	3	277/480	201-400A	CT-44-PTL-AMR	400A CT METERING -BAR TYPE CT'S BUSSED CABINET
3	1	120/240	401-800A	CT-81-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET
3	3	240	401-800A	CT-83-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET



SECTION 1100. AMEREN APPROVED METER MOUNTING DEVICES LIST

TALON/LANDIS&GYR

4	3	120/240	4011-800A	CT-84-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET
4	3Y	120/208	401-800A	CT-84-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET
3	3 DELTA	480	401-800	CT-83-PTL-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET
4	3Y	277/480	401-800A	CT-84-PTL-AMR	800A CT METERING BAR TYPE CT'S BUSSED CABINET

